



EVALUATION REPORT

FLORIDA BUILDING CODE, 7TH EDITION (2020)

Manufacturer: BOSTIK, INC. *Issued August 10, 2020*
11320 Watertown Plank Rd
Wauwatosa, WI 53226
(414) 774-2250
www.bostik.com

Manufacturing Plants: Conyers, GA

Quality Assurance: PRI Construction Materials Technologies (QUA9110)

SCOPE

Category: Roofing
Subcategory: Roof Tile Adhesives
Code Edition: Florida Building Code, 7th Edition (2020) including High-Velocity Hurricane Zones (HVHZ)
Code Sections: 1523.6.5.2.16
Properties: Physical Properties

REFERENCES

<u>Entity</u>	<u>Report No.</u>	<u>Standard</u>	<u>Year</u>
PRI Construction Materials Technologies (TST5878)	BOST-002-02-01	TAS 123(A)	1995
Miami-Dade BCCO – EVL (EVL1528)	15-0520.01	TAS 123(A)	1995

PRODUCT DESCRIPTION & APPLICATION


Bostik 915/915 RT A single component adhesive used for supplemental attachment of roof tiles and repairs of existing roof tiles.

LIMITATIONS

1. Fire classification is not within the scope of this evaluation.
2. Structural integrity of the roofing substrate or assembly is not within scope of this evaluation. Refer to the appropriate product approval for installation of these components within an *Approved* roof assembly.
3. Bostik 915/915RT shall be applied to clean, dry substrates, which are free of dirt, grease, mold, mildew, and other contaminants.
4. Installation of the evaluated products and the existing roof to be repaired shall be in strict compliance with this evaluation report, the FBC, and the manufacturer's published installation instructions. In the event of conflict, the more restrictive and FBC compliant installation shall be enforced. Applications are valid for new and existing roof systems.
5. No more than 25 adjacent loose tiles are to be adhered in any one area with a maximum of 25% of total roof tiles per given roof or roof section. No allowance for loose roof tiles shall be made where Bostik 915/915RT has been used to adhere loose roof tiles.
6. All products listed in this report shall be manufactured under a quality assurance program in compliance with Rule 61G20-3.

COMPLIANCE STATEMENT

The products evaluated herein by Zachary R. Priest have demonstrated compliance with the Florida Building Code, 7th Edition (2020) including High-Velocity Hurricane Zones (HVHZ) as evidenced in the referenced documents submitted by the named manufacturer.


Digitally signed by Zachary R. Priest
CREEK Technical Services, LLC

2020.08.10
11:37:55
-04'00'

Zachary R. Priest, P.E.
Florida Registration No. 74021
Organization No. ANE9641

CERTIFICATION OF INDEPENDENCE

CREEK Technical Services, LLC does not have, nor will it acquire, a financial interest in any company manufacturing or distributing products under this evaluation.

CREEK Technical Services, LLC is not owned, operated, or controlled by any company manufacturing or distributing products under this evaluation.

Zachary R. Priest, P.E. does not have, nor will acquire, a financial interest in any company manufacturing or distributing products under this evaluation.

Zachary R. Priest, P.E. does not have, nor will acquire, a financial interest in any other entity involved in the approval process of the product.

END OF REPORT