

INDEX OF DRAWING	
SHEET NO.	DESCRIPTION
1	COVER PAGE, GENERAL NOTES
1.1 & 1.2	GLAZING DETAILS
2, 2.1 & 2.2	SINGLE & DOUBLE DOORS TYP. ELEVATIONS & CAPACITY
3 & 3.1	SINGLE & DOUBLE DOORS WITH TRANSOM, ELEVATIONS & CAPACITY CHART
4 THRU 4.2	LOCK OPTIONS & LIMITATIONS
5 & 5.1	HORIZONTAL RAILS, HEAD/SILL DETAILS & TYPICAL ANCHORS
6	VERTICAL STILES, JAMB DETAILS
7	TRANSOM HEAD/SILL/JAMB DETAILS
7.1 & 7.2	WATER INFILTRATION RESISTANT DOOR DETAILS
7.3	ADA COMPLIANT THRESHOLD DETAILS
8	PARTS DRAWINGS
9	BILL OF MATERIALS & HINGE OPTIONS
10	CORNER CONSTRUCTION DETAILS

SERIES ENV-350

ALUMINUM OUTSWING ENTRANCE DOOR

DOORS WITH STANDARD SECTION DETAILS NOT APPROVED FOR INSTALLATIONS WHERE WATER INFILTRATION RESISTANCE IS REQUIRED. SEE SHEETS 5 & 6 FOR DETAILS.

DOORS WITH WATER RESISTANT COMPONENTS APPROVED FOR INSTALLATIONS WHERE WATER INFILTRATION RESISTANCE IS REQUIRED. SEE SHEETS 7.1 & 7.2 FOR DETAILS.

THESE DOORS MAY BE USED IN CONJUNCTION WITH F.B.C. APPROVED LARGE MISSILE IMPACT RESISTANT STOREFRONT SYSTEM. LOWER DESIGN PRESSURE FROM DOOR OR STOREFRONT APPROVAL WILL APPLY TO ENTIRE SYSTEM.

CODE REQUIREMENTS FOR SAFEGUARDS MUST BE OBSERVED.

THIS PRODUCT HAS BEEN DESIGNED AND TESTED TO COMPLY WITH THE REQUIREMENTS OF THE 2017 (6TH EDITION) FLORIDA BUILDING CODE INCLUDING HIGH VELOCITY HURRICANE ZONE (HVHZ).

1BY OR 2BY WOOD BUCKS & BUCK FASTENERS BY OTHERS, MUST BE DESIGNED AND INSTALLED ADEQUATELY TO TRANSFER APPLIED PRODUCT LOADS TO THE BUILDING STRUCTURE.

ANCHORS SHALL BE CORROSION RESISTANT, SPACED AS SHOWN ON DETAILS AND INSTALLED PER MANUF'S INSTRUCTIONS. SPECIFIED EMBEDMENT TO BASE MATERIAL SHALL BE BEYOND WALL DRESSING OR STUCCO.

A LOAD DURATION INCREASE IS USED IN DESIGN OF ANCHORS INTO WOOD ONLY. ALL SHIMS TO BE HIGH IMPACT, NON-METALLIC AND NON-COMPRESSIBLE.

MATERIALS INCLUDING BUT NOT LIMITED TO STEEL/METAL SCREWS, THAT COME INTO CONTACT WITH OTHER DISSIMILAR MATERIALS SHALL MEET THE REQUIREMENTS OF THE 2017 FLORIDA BLDG. CODE & ADOPTED STANDARDS.

THIS PRODUCT APPROVAL IS GENERIC AND DOES NOT PROVIDE INFORMATION FOR A SITE SPECIFIC PROJECT, i.e. LIFE SAFETY OF THIS PRODUCT, ADEQUACY OF STRUCTURE RECEIVING THIS PRODUCT AND SEALING AROUND OPENING FOR WATER INFILTRATION RESISTANCE ETC. CONDITIONS NOT SHOWN IN THIS DRAWING ARE TO BE ANALYZED SEPARATELY, AND TO BE REVIEWED BY BUILDING OFFICIAL.

MANUFACTURER'S LABEL SHALL BE LOCATED ON A READILY VISIBLE LOCATION IN ACCORDANCE WITH SECTION 1709.9.3 OF FLORIDA BUILDING CODE. LABELING TO COMPLY WITH SECTION 1709.9.2.


INSTRUCTIONS:

USE DRAWING AS FOLLOWS.

1. SELECT SINGLE OR DOUBLE DOORS FROM SHEETS 2 & 2.1 OR SINGLE OR DOUBLE DOORS WITH TRANSOM FROM SHEETS 3 & 3.1.
2. SELECT DOOR AND FRAME SIZE.
3. DETERMINE IF THE DOOR WILL BE INSTALLED IN AN OPENING WHERE THE WATER REQUIREMENT IS NEEDED OR NOT.
4. DETERMINE Dp RATING FROM SHEET 2, 2.1 OR 3 & 3.1.
5. SELECT GLASS TYPE FROM SHEET 1.1.
6. SELECT LOCK OPTION AND CORRESPONDING MAX. DESIGN LOAD FROM SHEET 4 THRU 4.2.
7. SELECT ANCHORING CONDITION AND CORRESPONDING ANCHOR TYPE AND NUMBER OF ANCHORS FROM SHEET 5.
8. SELECT JAMB OPTIONS FROM SHEET 6.
9. SELECT HINGE OPTION FROM SHEET 9.
10. DETERMINE FINAL DESIGN PRESSURE FOR THE SYSTEM, TAKEN AS THE LOWEST OF ALL Dp VALUES OBTAINED.

DOORS ARE RATED FOR LARGE & SMALL MISSILE IMPACT. SHUTTERS ARE NOT REQUIRED.

- A- CONTRACTOR TO BE RESPONSIBLE FOR THE SELECTION, PURCHASE AND INSTALLATION OF THIS PRODUCT BASED ON THIS PRODUCT EVALUATION PROVIDED HE/SHE DOES NOT DEVIATE FROM THE CONDITIONS DETAILED ON THIS DOCUMENT.
- B- THIS PRODUCT EVALUATION DOCUMENT WILL BE CONSIDERED INVALID IF ALTERED BY ANY MEANS.
- C- SITE SPECIFIC PROJECTS SHALL BE PREPARED BY A FLORIDA REGISTERED ENGINEER OR ARCHITECT WHICH WILL BECOME THE ENGINEER OF RECORD (E.O.R.) FOR THE PROJECT AND WHO WILL BE RESPONSIBLE FOR THE PROPER USE OF THE P.E.D. ENGINEER OF RECORD, ACTING AS A DELEGATED ENGINEER TO THE P.E.D. ENGINEER SHALL SUBMIT TO THIS LATTER THE SITE SPECIFIC DRAWINGS FOR REVIEW.
- D- THIS P.E.D. SHALL BEAR THE DATE AND ORIGINAL SEAL AND SIGNATURE OF THE PROFESSIONAL ENGINEER OF RECORD THAT PREPARED IT.




afc

AL-FAROOQ CORPORATION
 ENGINEERS & PRODUCT DEVELOPMENT
 9360 SUNSET DRIVE, SUITE 220
 MIAMI, FLORIDA 33173 (C.A.N. 3538)
 TEL. (305) 264-8100 FAX. (305) 262-6978
 COMP-ANL\W17-42ENV


SERIES ENV-350 OUTSWING ENTRANCE DOOR (L.M.I.)
ENVIRALUM INDUSTRIES INC.
 5100 N.W. 72 AVENUE BLDG. C
 MIAMI, FL. 33166
 TEL. (305) 752-4411 FAX. (305) 406-3877

revisions:	no	date	description	by
	A	06.13.17	CLASS & LOCK OPTION ADDED	
	B	01.15.19	NEW TEST ADDED	

date: 04-11-17	scale: 3/8" = 1"	dr. by: TARIQ	chk. by:
drawing no. W17-42		sheet 1 of 10	




GLASS TYPE 'A'




GLASS TYPE 'A1'

GLAZING DETAILS DOOR
LEVEL 'D' IMPACT




GLASS TYPE 'B'




GLASS TYPE 'B1'

GLAZING DETAILS DOOR
LEVEL 'E' IMPACT




GLASS TYPE 'A'




GLASS TYPE 'A1'

GLAZING DETAILS TRANSOM
LEVEL 'D' IMPACT




GLASS TYPE 'B'



GLASS TYPE 'B1'

GLAZING DETAILS TRANSOM
LEVEL 'E' IMPACT

1/2" AIR SPACE CONSISTING OF:
SPACER:
 ALUMINUM BOX SPACER AROUND
 THE PERIMETER OF THE GLASS.
PERIMETER SEALANT:
 SILICONE
 DOWSIL 791
 GE 2000



FL #20701


Sealed 2/22/2019

af c
AL-FAROOQ CORPORATION
 ENGINEERS & PRODUCT DEVELOPMENT
 9360 SUNSET DRIVE, SUITE 220
 MIAMI, FLORIDA 33173 (C.A.N. 3538)
 TEL. (305) 262-6978
 FAX. (305) 262-6978
 COMP-ANL\W17-42ENV

SERIES ENV-350 OUTSWING ENTRANCE DOOR (L.M.I.)
ENVRALUM INDUSTRIES INC.
 5100 N.W. 72 AVENUE BLDG. C
 MIAMI, FL. 33166
 TEL. (305) 752-4411 FAX. (305) 406-3877

revisions:	no	date	by	description

date: 04-11-17
 scale: 3/8" = 1"
 dr. by: TARIQ
 chk. by:
 drawing no.
W17-42
 sheet 1.1 of 10




GLASS TYPE 'C'

GLASS TYPE 'C1'

**GLAZING DETAILS DOOR
LEVEL 'D' IMPACT**

1/2" AIR SPACE CONSISTING OF:
SPACER:
 ALUMINUM BOX SPACER AROUND
 THE PERIMETER OF THE GLASS.
PERIMETER SEALANT:
 SILICONE
 DOWSIL 791
 GE 2000



FL #20701

Sealed 2/22/2019


af c
AL-FAROOQ CORPORATION
 ENGINEERS & PRODUCT DEVELOPMENT
 9360 SUNSET DRIVE, SUITE 220
 MIAMI, FLORIDA 33173 (C.A.N. 3538)
 TEL. (305) 264-8100 FAX. (305) 262-6978
 COMP -ANL\W17-42ENV

SERIES ENV-350 OUTSWING ENTRANCE DOOR (L.M.I.)
ENVIRALUM INDUSTRIES INC.
 5100 N.W. 72 AVENUE BLDG. C
 MIAMI, FL. 33166
 TEL. (305) 752-4411 FAX. (305) 406-3877


revisions:	
no	date by description

date: 04-11-17
 scale: 3/8" = 1"
 dr. by: TARIQ
 chk. by:

drawing no.
W17-42
 sheet 1.2 of 10



ANCHOR TYPES	NO. OF ANCHORS AT MTG. STILE ENDS	
	1/4" SHIM	3/8" SHIM
A	6	8
B	6	8
C	5	6



(X)


(XX)

LEVEL 'D' IMPACT

	DESIGN PRESSURE RATING (GLASS TYPES 'A' & 'A1')		REMARKS
	WHERE WATER INFILTRATION REQUIREMENT IS NEEDED	WHERE WATER INFILTRATION REQUIREMENT IS NOT NEEDED	
POSITIVE	+60 PSF	+100 PSF	SEE SHEETS 4 & 4.1 FOR LOCK OPTIONS AND LIMITATIONS
NEGATIVE	-100 PSF	-100 PSF	
	WITH WATER RESISTANT COMPONENTS ADDED SEE SHEETS 7.1 & 7.2	WITH STANDARD DOOR SECTIONS SEE SHEETS 5 & 6	

GLASS D.L.O. DIMS.
 D.L.O. HEIGHT = DOOR FRAME HEIGHT - 14.9375"
 D.L.O. WIDTH (X DOORS) = FRAME WIDTH - 12.8125"
 D.L.O. WIDTH (XX DOORS) = (FRAME WIDTH - 21.875")/2

NOTE:
 GLASS CAPACITIES ON THIS SHEET ARE BASED ON ASTM E1300-09 (3 SEC. GUSTS) AND FLORIDA BUILDING COMMISSION DECLARATORY STATEMENT DCA05-DEC-219



FL #20701


Sealed 2/22/2019

af c
AL-FAROOQ CORPORATION
 ENGINEERS & PRODUCT DEVELOPMENT
 9360 SUNSET DRIVE, SUITE 220
 MIAMI, FLORIDA 33173 (C.A.N. 3538)
 TEL. (305) 264-8100 FAX. (305) 262-6978
 COMP-ANL\W17-42ENV


SERIES ENV-350 OUTSWING ENTRANCE DOOR (L.M.I.)
ENVIRALUM INDUSTRIES INC.
 5100 N.W. 72 AVENUE BLDG. C
 MIAMI, FL. 33166
 TEL. (305) 752-4411 FAX. (305) 406-3877

revisions:	
no	date by description

date: 04-11-17
 scale: 1/2"=1'-0"
 dr. by: TARIQ
 chk. by:
 drawing no. **W17-42**
 sheet 2 of 10



ANCHOR TYPES	NO. OF ANCHORS AT MTG. STILE ENDS	
	1/4" SHIM	3/8" SHIM
A	5	7
B	5	7
C	4	5



(X)

(XX)


LEVEL 'E' IMPACT

	DESIGN PRESSURE RATING (GLASS TYPE 'B' & 'B1')		REMARKS
	WHERE WATER INFILTRATION REQUIREMENT IS NEEDED	WHERE WATER INFILTRATION REQUIREMENT IS NOT NEEDED	
POSITIVE	+60 PSF	+100 PSF	SEE SHEET 4.2 FOR LOCK OPTIONS AND LIMITATIONS
NEGATIVE	-100 PSF	-100 PSF	
	WITH WATER RESISTANT COMPONENTS ADDED SEE SHEETS 7.1 & 7.2	WITH STANDARD DOOR SECTIONS SEE SHEETS 5 & 6	

GLASS D.L.O. DIMS.

D.L.O. HEIGHT = DOOR FRAME HEIGHT - 14.9375"
 D.L.O. WIDTH (X DOORS) = FRAME WIDTH - 12.8125"
 D.L.O. WIDTH (XX DOORS) = (FRAME WIDTH - 21.875")/2

NOTE:
 GLASS CAPACITIES ON THIS SHEET ARE BASED ON ASTM E1300-09 (3 SEC. GUSTS) AND FLORIDA BUILDING COMMISSION DECLARATORY STATEMENT DCA05-DEC-219




FL #20701

Sealed 2/22/2019


af c
AL-FAROOQ CORPORATION
 ENGINEERS & PRODUCT DEVELOPMENT
 9360 SUNSET DRIVE, SUITE 220
 MIAMI, FLORIDA 33173 (C.A.N. 3538)
 TEL. (305) 264-8100 FAX. (305) 262-6978
 COMP-ANL\W17-42ENV

SERIES ENV-350 OUTSWING ENTRANCE DOOR (L.M.I.)
ENVRALUM INDUSTRIES INC.
 5100 N.W. 72 AVENUE BLDG. C
 MIAMI, FL. 33166
 TEL. (305) 752-4411 FAX. (305) 406-3877

revisions:	no	date	by	description
date:	04-11-17			
scale:	1/2"=1'-0"			
dr. by:	TARIQ			
chk. by:				
drawing no.	W17-42			
sheet	2.1 of 10			



ANCHOR TYPES	NO. OF ANCHORS AT MTG. STILE ENDS	
	1/4" SHIM	3/8" SHIM
A	8	10
B	8	10
C	8	8




LEVEL 'D' IMPACT

DESIGN PRESSURE RATING (GLASS TYPES 'C' & 'C1')	REMARKS
WHERE WATER INFILTRATION REQUIREMENT IS NOT NEEDED	SEE SHEETS 4 & 4.1 FOR LOCK OPTIONS AND LIMITATIONS
POSITIVE +100 PSF	
NEGATIVE -144 PSF	
WITH STANDARD DOOR SECTIONS SEE SHEETS 5 & 6	

GLASS D.L.O. DIMS.
 D.L.O. HEIGHT = DOOR FRAME HEIGHT - 14.9375"
 D.L.O. WIDTH (X DOORS) = FRAME WIDTH - 12.8125"
 D.L.O. WIDTH (XX DOORS) = (FRAME WIDTH - 21.875")/2

NOTE:
 GLASS CAPACITIES ON THIS SHEET ARE BASED ON ASTM E1300-09 (3 SEC. GUSTS) AND FLORIDA BUILDING COMMISSION DECLARATORY STATEMENT DCA05-DEC-219



FL #20701

Sealed 2/22/2019



af c
AL-FAROOQ CORPORATION
 ENGINEERS & PRODUCT DEVELOPMENT
 9360 SUNSET DRIVE, SUITE 220
 MIAMI, FLORIDA 33173 (C.A.N. 3538)
 TEL. (305) 264-8100 FAX. (305) 262-6978
 COMP-ANL\W17-42ENV

SERIES ENV-350 OUTSWING ENTRANCE DOOR (L.M.I.)
ENVIRALUM INDUSTRIES INC.
 5100 N.W. 72 AVENUE BLDG. C
 MIAMI, FL. 33166
 TEL. (305) 752-4411 FAX. (305) 406-3877

no	date	by	description

date: 04-11-17
 scale: 1/2"=1'-0"
 dr. by: TARIQ
 chk. by:


drawing no. **W17-42**
 sheet 2.2 of 10



NO. OF ANCHORS AT TRANSOM ENDS		
ANCHOR TYPES	1/4\" SHIM	3/8\" SHIM
A	3	4
B	3	4
BB	5	5
C	3	3

DOORS WITH TRANSOM

SEE SHEET 3.1 FOR TRANSOM (HORIZ. MULLION) DESIGN LOAD CAPACITY,



FL #20701

Sealed 2/22/2019

af c
AL-FAROOQ CORPORATION
 ENGINEERS & PRODUCT DEVELOPMENT
 9360 SUNSET DRIVE, SUITE 220
 MIAMI, FLORIDA 33173 (C.A.N. 3538)
 TEL. (305) 264-8100 FAX. (305) 262-6978
 COMP-ANL\W17-42ENV

SERIES ENW-350 OUTSWING ENTRANCE DOOR (L.M.I.)
ENVIRALUM INDUSTRIES INC.
 5100 N.W. 72 AVENUE BLDG. C
 MIAMI, FL. 33166
 TEL. (305) 752-4411 FAX. (305) 406-3877


revisions:	no	date	by	description
date:	04-11-17	scale:	1/2"=1'-0"	
dr. by:	TARIQ	chk. by:		
drawing no.	W17-42			
sheet	3 of 10			

LEVEL 'D' & 'E' IMPACT


SINGLE OR DOUBLE DOORS WITH TRANSOM CAPACITY - PSF					
FRAME/TRANSOM WIDTH	DOOR HEIGHT	TRANSOM HEIGHT	WITHOUT REINF.	WITH REINF.	
			EXT.(+) INT.(-)	EXT.(+) INT.(-)	
37-3/4" (X)	75-1/2" (XX)	80"	24"	78.3	100.0
			30"	72.2	100.0
			36"	66.7	100.0
			42"	61.7	95.7
			48"	57.2	87.8
40-3/4" (X)	81-1/2" (XX)	80"	24"	65.7	100.0
			30"	60.3	95.1
			36"	55.4	86.4
			42"	50.9	78.6
43-3/4" (X)	87-1/2" (XX)	80"	24"	46.9	71.4
			30"	55.7	88.7
			36"	50.7	79.9
			42"	42.4	64.8
46-3/4" (X)	93-1/2" (XX)	80"	24"	38.8	58.3
			30"	47.5	75.6
			36"	43.0	67.5
			42"	35.4	53.6
49-3/4" (X)	99-1/2" (XX)	80"	24"	40.8	64.8
			30"	36.7	57.2
			36"	33.0	50.5
37-3/4" (X)	75-1/2" (XX)	84"	24"	75.4	100.0
			30"	69.7	100.0
			36"	64.4	100.0
			42"	59.7	92.7
			48"	55.4	85.1
40-3/4" (X)	81-1/2" (XX)	84"	24"	63.3	100.0
			30"	58.1	91.8
			36"	53.5	83.5
			42"	49.3	76.1
43-3/4" (X)	87-1/2" (XX)	84"	24"	45.5	69.3
			30"	53.6	85.4
			36"	44.8	69.6
			42"	41.0	62.8
46-3/4" (X)	93-1/2" (XX)	84"	24"	37.6	56.6
			30"	45.7	72.8
			36"	41.5	65.1
			42"	34.3	51.9
49-3/4" (X)	99-1/2" (XX)	84"	24"	39.3	62.4
			30"	35.4	55.2
			36"	31.9	48.8

SINGLE OR DOUBLE DOORS WITH TRANSOM CAPACITY - PSF					
FRAME/TRANSOM WIDTH	DOOR HEIGHT	TRANSOM HEIGHT	WITHOUT REINF.	WITH REINF.	
			EXT.(+) INT.(-)	EXT.(+) INT.(-)	
37-3/4" (X)	75-1/2" (XX)	90"	24"	71.5	100.0
			30"	66.2	100.0
			36"	61.4	96.2
			42"	57.0	88.5
			48"	53.0	81.4
40-3/4" (X)	81-1/2" (XX)	90"	24"	60.0	95.6
			30"	55.2	87.2
			36"	51.0	79.6
			42"	47.1	72.6
43-3/4" (X)	87-1/2" (XX)	90"	24"	43.5	66.3
			30"	50.8	80.9
			36"	46.5	73.2
			42"	39.2	59.9
46-3/4" (X)	93-1/2" (XX)	90"	24"	43.3	69.0
			30"	39.5	61.9
			36"	35.9	55.4
			42"	37.2	59.1
49-3/4" (X)	99-1/2" (XX)	90"	24"	33.6	52.5
			30"	37.2	59.1
			36"	33.6	52.5
37-3/4" (X)	75-1/2" (XX)	96"	24"	67.9	100.0
			30"	63.0	99.7
			36"	58.6	91.8
			42"	54.5	84.6
			48"	50.8	78.0
40-3/4" (X)	81-1/2" (XX)	96"	24"	57.0	90.9
			30"	52.6	83.1
			36"	48.7	75.9
			42"	45.0	69.5
43-3/4" (X)	87-1/2" (XX)	96"	24"	41.7	63.5
			30"	48.2	76.9
			36"	44.3	69.7
			42"	40.7	63.2
46-3/4" (X)	93-1/2" (XX)	96"	24"	41.2	65.5
			30"	37.6	58.9
49-3/4" (X)	99-1/2" (XX)	96"	24"	35.4	56.1
			30"	35.4	56.1

SINGLE OR DOUBLE DOORS WITH TRANSOM CAPACITY - PSF					
FRAME/TRANSOM WIDTH	DOOR HEIGHT	TRANSOM HEIGHT	WITHOUT REINF.	WITH REINF.	
			EXT.(+) INT.(-)	EXT.(+) INT.(-)	
37-3/4" (X)	75-1/2" (XX)	102"	24"	64.7	100.0
			30"	60.2	95.1
			36"	56.0	87.8
			42"	52.3	81.1
40-3/4" (X)	81-1/2" (XX)	102"	24"	54.2	86.5
			30"	50.2	79.8
			36"	46.5	72.6
			42"	43.2	66.6
43-3/4" (X)	87-1/2" (XX)	102"	24"	45.9	73.2
			30"	42.3	66.6
46-3/4" (X)	93-1/2" (XX)	102"	24"	39.2	62.4
			30"	39.2	62.4
37-3/4" (X)	75-1/2" (XX)	108"	24"	61.7	98.5
			30"	57.5	91.0
			36"	53.7	84.1
			42"	51.8	82.6
40-3/4" (X)	81-1/2" (XX)	108"	24"	48.0	75.8
			36"	44.6	69.6
43-3/4" (X)	87-1/2" (XX)	108"	24"	43.9	69.9
			36"	43.9	69.9



NOTE:
GLASS CAPACITIES ON THIS SHEET ARE
BASED ON ASTM E1300-09 (3 SEC. GUSTS)
AND FLORIDA BUILDING COMMISSION
DECLARATORY STATEMENT DCA05-DEC-219



FL #20701

af c
AL-FAROOQ CORPORATION
ENGINEERS & PRODUCT DEVELOPMENT
9360 SUNSET DRIVE, SUITE 220
MIAMI, FLORIDA 33173 (C.A.N. 3538)
TEL. (305) 264-8100 FAX. (305) 262-6978
COMP - ANL \ W17 - 42ENV

SERIES ENV-350 OUTSWING ENTRANCE DOOR (L.M.I.)
ENVRALUM INDUSTRIES INC.
5100 N.W. 72 AVENUE BLDG. C
MIAMI, FL. 33166
TEL. (305) 752-4411 FAX. (305) 406-3877

revisions:	no	date	by	description

date: 04-11-17
scale: 1/2"=1'-0"
dr. by: TARIQ
chk. by:

drawing no.
W17-42
sheet 3.1 of 10

LOCK OPTIONS: LEVEL 'D' IMPACT


STD. 3 POINT LOCK (LEVEL 'D' IMPACT ONLY)
 MAX. FRAME HEIGHT = 120 IN.
 MAX. LEAF WIDTH = 48 IN.
 MAX. DESIGN LOAD = 100 PSF

ACTIVE LEAF:

3 POINT LOCK SYSTEM BY 'INTERLOCK' AT 40" FROM BOTTOM
 HANDLE ACTIVATES DEAD BOLT AND SHOOT BOLTS ENGAGING AT HEAD AND SILL
 KEY OPERATED ON EXTERIOR AND THUMB TURN ON INTERIOR
 FASTENED TO ACTIVE LEAF LOCK STILE WITH
 (2) #8-32 X 2" OH MS

INACTIVE LEAF:

2 POINT LOCK SYSTEM BY 'INTERLOCK' AT 40" FROM BOTTOM
 HANDLE ACTIVATES SHOOT BOLTS ENGAGING AT HEAD AND SILL
 FASTENED TO INACTIVE LEAF LOCK STILE WITH
 (2) #8-32 X 2" OH MS




STD. 3 POINT LOCK (LEVEL 'D' IMPACT ONLY)
 MAX. FRAME HEIGHT = 120 IN.
 MAX. LEAF WIDTH = 48 IN.
 MAX. DESIGN LOAD = 100 PSF

ACTIVE LEAF:

THREE POINT LOCK SYSTEM SERIES 2222 BY 'REGENT HARDWARE'
 KEY OPERATED FROM EXTERIOR AND THUMB TURN ON INTERIOR WITH CONCEALED FLUSH BOLTS AT TOP & BOTTOM OF LOCK STILE
 LOCATED AT 40" FROM BOTTOM OF LEAF

INACTIVE LEAF:

MANUALLY OPERATED TWO POINT LOCK SYSTEM BY 'REGENT HARDWARE' WITH CONCEALED FLUSH BOLTS AT TOP & BOTTOM OF LOCK STILE
 FASTENED WITH
 (2) #8-32 X 1/4" PH MACHINE SCREWS



STD. 3 POINT LOCK (LEVEL 'D' IMPACT ONLY)
 MAX. FRAME HEIGHT = 109-3/4 IN.
 MAX. LEAF WIDTH = 48 IN.
 MAX. DESIGN LOAD = 144 PSF


STD. 3 POINT LOCK (LEVEL 'D' IMPACT ONLY)
 MAX. FRAME HEIGHT = 120 IN.
 MAX. LEAF WIDTH = 48 IN.
 MAX. DESIGN LOAD = 100 PSF

ACTIVE LEAF:

KEY OPERATED THREE POINT LOCK SYSTEM BY 'ADAMS RITE' WITH CONCEALED FLUSH BOLTS AT TOP & BOTTOM OF LOCK STILE AND A THUMB TURN ON THE INTERIOR, LOCATED AT 40" FROM BOTTOM OF PANEL
 FASTENED WITH
 (2) #12-24 X 1/2" FH MACHINE SCREWS


INACTIVE LEAF:

MANUALLY OPERATED TWO POINT LOCK SYSTEM BY 'ADAMS RITE' WITH CONCEALED FLUSH BOLTS AT TOP & BOTTOM OF LOCK STILE
 FASTENED WITH
 (2) #8-32 X 1/4" PH MACHINE SCREWS



STD. 3 POINT LOCK (LEVEL 'D' IMPACT ONLY)
 MAX. FRAME HEIGHT = 109-3/4 IN.
 MAX. LEAF WIDTH = 48 IN.
 MAX. DESIGN LOAD = 144 PSF

FRAME HEIGHTS DOES INCLUDE OPTIONAL TRANSOM



FL #20701

Sealed 2/22/2019

af c
AL-FAROOQ CORPORATION
 ENGINEERS & PRODUCT DEVELOPMENT
 9360 SUNSET DRIVE, SUITE 220
 MIAMI, FLORIDA 33173 (C.A.N. 3538)
 TEL. (305) 264-8100 FAX. (305) 262-6978
 COMP-ANL\W17-42ENY

SERIES ENV-350 OUTSWING ENTRANCE DOOR (L.M.I.)
ENVIRALUM INDUSTRIES INC.
 5100 N.W. 72 AVENUE BLDG. C
 MIAMI, FL. 33166
 TEL. (305) 752-4411 FAX. (305) 406-3877


revisions:	no	date	by	description
date:	04-11-17	scale:	3/8" = 1"	
dr. by:	TARIQ	chk. by:		
drawing no.	W17-42			
sheet	4 of 10			

LOCK OPTIONS: LEVEL 'D' IMPACT

PANIC EXIT DEVICE (LEVEL 'D' IMPACT ONLY)
 MAX. FRAME HEIGHT = 98 IN.
 MAX. LEAF WIDTH = 48 IN.
 MAX. DESIGN LOAD = 75 PSF

ACTIVE & INACTIVE LEAF:


CONCEALED VERTICAL ROD PANIC EXIT DEVICE # 5770 BY 'REGENT HARDWARE' LOCATED AT 40" FROM SILL AT EACH LEAF.
 FASTENED WITH
 (1) #10 X 3/8" FH SELF DRILLING SCREW AT ONE END AND
 (2) #10 X 1/2" FH SELF DRILLING SCREWS AT OTHER END



PANIC EXIT DEVICE (LEVEL 'D' IMPACT ONLY)
 MAX. FRAME HEIGHT = 120 IN.
 MAX. LEAF WIDTH = 48 IN.
 MAX. DESIGN LOAD = 100 PSF

ACTIVE & INACTIVE LEAF:


CONCEALED VERTICAL ROD PANIC EXIT DEVICE # G86 BY 'ADAMS RITE' LOCATED AT 40" FROM SILL AT EACH LEAF.
 FASTENED WITH
 (2) #10-32 X 3/4" FH MACHINE SCREWS AT ONE END AND
 (2) #10-24 X 1/2" FH MACHINE SCREWS AT OTHER END



PANIC EXIT DEVICE (LEVEL 'D' IMPACT ONLY)
 MAX. FRAME HEIGHT = 120 IN.
 MAX. LEAF WIDTH = 48 IN.
 MAX. DESIGN LOAD = 100 PSF

ACTIVE & INACTIVE LEAF:


CONCEALED VERTICAL ROD PANIC EXIT DEVICE PRECISION 2800 LOCATED AT 40" FROM SILL AT EACH LEAF.
 FASTENED WITH
 (2) #10-32 X 3/4" FH MACHINE SCREWS AT ONE END AND
 (2) #10-24 X 1/2" FH MACHINE SCREWS AT OTHER END



PANIC EXIT DEVICE (LEVEL 'D' IMPACT ONLY)
 MAX. FRAME HEIGHT = 109-3/4 IN.
 MAX. LEAF WIDTH = 48 IN.
 MAX. DESIGN LOAD = 144 PSF

ACTIVE & INACTIVE LEAF:



CONCEALED VERTICAL ROD PANIC EXIT DEVICE SERIES 8400/8600 BY 'SARGENT ASSA ABLBY' LOCATED AT 40" FROM SILL AT EACH LEAF.
 FASTENED WITH
 (2) #12 X 1" HH SELF DRILLING SCREW AT ONE END AND
 (2) #14 X 3/4" PH SELF DRILLING SCREWS AT OTHER END



PANIC EXIT DEVICE (LEVEL 'D' IMPACT ONLY)
 MAX. FRAME HEIGHT = 98 IN.
 MAX. LEAF WIDTH = 48 IN.
 MAX. DESIGN LOAD = 100 PSF

ACTIVE & INACTIVE LEAF:

'VON DUPRIN 98/99' CONCEALED VERTICAL ROD PANIC EXIT DEVICE LOCATED AT 40" FROM BOTTOM AT EACH LEAF.
 FASTENED TO ACTIVE LEAF WITH WITH
 (6) 10-24 X 1-1/8" PH MS



FL #20701

Sealed 2/22/2019

af c
AL-FAROOQ CORPORATION
 ENGINEERS & PRODUCT DEVELOPMENT
 9360 SUNSET DRIVE, SUITE 220
 MIAMI, FLORIDA 33173 (C.A.N. 3538)
 TEL. (305) 264-8100 FAX. (305) 262-6978
 COMP-ANL\W17-42ENV

SERIES ENV-350 OUTSWING ENTRANCE DOOR (L.M.I.)
ENVIRALUM INDUSTRIES INC.
 5100 N.W. 72 AVENUE BLDG. C
 MIAMI, FL. 33166
 TEL. (305) 752-4411 FAX. (305) 406-3877

no	date	by	description

date: 04-11-17
 scale: 3/8" = 1"
 dr. by: TARIQ
 chk. by:

drawing no.
W17-42
 sheet 4.1 of 10

LOCK OPTIONS: LEVEL 'E' IMPACT


STD. 3 POINT LOCK (LEVEL 'E' IMPACT)
 MAX. FRAME HEIGHT = 98 IN.
 MAX. LEAF WIDTH = 48 IN.
 MAX. DESIGN LOAD = 100 PSF

ACTIVE LEAF:

THREE POINT LOCK SYSTEM SERIES 2222 BY 'REGENT HARDWARE'
 KEY OPERATED FROM EXTERIOR AND THUMB TURN ON INTERIOR WITH CONCEALED FLUSH BOLTS AT TOP & BOTTOM OF LOCK STILE LOCATED AT 40" FROM BOTTOM OF LEAF

INACTIVE LEAF:

MANUALLY OPERATED TWO POINT LOCK SYSTEM BY 'REGENT HARDWARE' WITH CONCEALED FLUSH BOLTS AT TOP & BOTTOM OF LOCK STILE FASTENED WITH (2) #8-32 X 1/4" PH MACHINE SCREWS




STD. 3 POINT LOCK (LEVEL 'E' IMPACT)
 MAX. FRAME HEIGHT = 98 IN.
 MAX. LEAF WIDTH = 48 IN.
 MAX. DESIGN LOAD = 100 PSF

ACTIVE LEAF:

KEY OPERATED THREE POINT LOCK SYSTEM BY 'ADAMS RITE' WITH CONCEALED FLUSH BOLTS AT TOP & BOTTOM OF LOCK STILE AND A THUMB TURN ON THE INTERIOR, LOCATED AT 40" FROM BOTTOM OF PANEL FASTENED WITH (2) #12-24 X 1/2" FH MACHINE SCREWS

INACTIVE LEAF:


MANUALLY OPERATED TWO POINT LOCK SYSTEM BY 'ADAMS RITE' WITH CONCEALED FLUSH BOLTS AT TOP & BOTTOM OF LOCK STILE FASTENED WITH (2) #8-32 X 1/4" PH MACHINE SCREWS



PANIC EXIT DEVICE (LEVEL 'E' IMPACT)
 MAX. FRAME HEIGHT = 98 IN.
 MAX. LEAF WIDTH = 48 IN.
 MAX. DESIGN LOAD = 100 PSF

ACTIVE & INACTIVE LEAF:


CONCEALED VERTICAL ROD PANIC EXIT DEVICE PRECISION 2800 LOCATED AT 40" FROM SILL AT EACH LEAF. FASTENED WITH (2) #10-32 X 3/4" FH MACHINE SCREWS AT ONE END AND (2) #10-24 X 1/2" FH MACHINE SCREWS AT OTHER END



PANIC EXIT DEVICE (LEVEL 'E' IMPACT)
 MAX. FRAME HEIGHT = 98 IN.
 MAX. LEAF WIDTH = 48 IN.
 MAX. DESIGN LOAD = 100 PSF

ACTIVE & INACTIVE LEAF:


CONCEALED VERTICAL ROD PANIC EXIT DEVICE SERIES 8400/8600 BY 'SARGENT ASSA ABLOY' LOCATED AT 40" FASTENED WITH (2) #12 X 1" HH SELF DRILLING SCREW AT ONE END AND (2) #14 X 3/4" PH SELF DRILLING SCREWS AT OTHER END




PANIC EXIT DEVICE (LEVEL 'E' IMPACT)
 MAX. FRAME HEIGHT = 98 IN.
 MAX. LEAF WIDTH = 48 IN.
 MAX. DESIGN LOAD = 100 PSF

ACTIVE & INACTIVE LEAF:

'VON DUPRIN 98/99' CONCEALED VERTICAL ROD PANIC EXIT DEVICE LOCATED AT 40" FROM BOTTOM FASTENED TO ACTIVE LEAF WITH WITH (6) 10-24 X 1-1/8" PH MS



FL #20701






Sealed 2/22/2019


af c
AL-FAROOQ CORPORATION
 ENGINEERS & PRODUCT DEVELOPMENT
 9360 SUNSET DRIVE, SUITE 220
 MIAMI, FLORIDA 33173 (C.A.N. 3538)
 TEL. (305) 264-8100 FAX. (305) 262-6978
 COMP-ANL\W17-42ENV

SERIES ENV-350 OUTSWING ENTRANCE DOOR (L.M.I.)
ENVIRALUM INDUSTRIES INC.
 5100 N.W. 72 AVENUE BLDG. C
 MIAMI, FL. 33166
 TEL. (305) 752-4411 FAX. (305) 406-3877

revisions:	no	date	by	description
date:	04-11-17	scale:	3/8" = 1"	
dr. by:	TARIQ	chk. by:		
drawing no.	W17-42			
sheet	4.2 of 10			



THRESHOLD NOT ADA COMPLIANT
SEE SHEET 7.3 FOR ADA COMPLIANCE



FL #20701

Sealed 2/22/2019

af c
AL-FAROOQ CORPORATION
ENGINEERS & PRODUCT DEVELOPMENT
9360 SUNSET DRIVE, SUITE 220
MIAMI, FLORIDA 33173 (C.A.N. 3538)
TEL. (305) 264-8100 FAX. (305) 262-6978

SERIES ENV-350 OUTSWING ENTRANCE DOOR (L.M.I.)
ENVRALUM INDUSTRIES INC.
5100 N.W. 72 AVENUE BLDG. C
MIAMI, FL. 33166
TEL. (305) 752-4411 FAX. (305) 406-3877




revisions:

no	date	description

date: 04-11-17
scale: 3/8" = 1"
dr. by: TARIQ
chk. by:

drawing no.
W17-42
sheet 5 of 10

COMP-ANL\W17-42ENV



TYPICAL ANCHORS: SEE ELEV. FOR SPACING

TYPE 'A' - 5/16" DIA ULTRACON BY 'ELCO' (Fu=177 KSI, Fy=155 KSI)
 INTO WOOD STRUCTURES
 2" MIN. PENETRATION INTO WOOD (HEAD/SILL/JAMBS)
 THRU 1BY OR 2BY BUCKS INTO CONC. OR MASONRY
 1-3/4" MIN. EMBED INTO CONCRETE (HEAD/SILL/JAMBS)
 1-3/4" MIN. EMBED INTO FILLED BLOCKS (JAMBS)
 DIRECTLY INTO MASONRY
 1-3/4" MIN. EMBED INTO FILLED BLOCKS (JAMBS)

ANCHOR EDGE DISTANCES

INTO CONCRETE AND MASONRY = 2-1/2" MIN.
 INTO WOOD STRUCTURE = 1-1/4" MIN.

ANCHOR CL TO CL DISTANCE

INTO CONCRETE = 3" MIN.
 INTO FILLED BLOCKS = 4" MIN.

TYPE 'B' - 5/16" DIA ULTRACON BY 'ELCO' (Fu=177 KSI, Fy=155 KSI)
 DIRECTLY INTO CONCRETE
 1-3/4" MIN. EMBED INTO CONCRETE (HEAD/SILL/JAMBS)

TYPE 'BB' - 5/16" DIA ULTRACON BY 'ELCO' (Fu=177 KSI, Fy=155 KSI)
 DIRECTLY INTO GROUT FILLED BLOCKS
 1-3/4" MIN. EMBED INTO FILLED BLOCKS (JAMBS)

ANCHOR EDGE DISTANCES

INTO CONCRETE = 2-3/16" MIN.

ANCHOR CL TO CL DISTANCE

INTO CONCRETE = 3" MIN.
 INTO FILLED BLOCKS = 5" MIN.


TYPE 'C' - 5/16" DIA. TEKS OR SELF DRILLING SCREWS (GRADE 5 CRS)
 INTO MIAMI-DADE COUNTY APPROVED MULLIONS
 OR
 INTO METAL STRUCTURES
 (3) THREADS MIN. PENETRATION BEYOND METAL SUBSTRATE
 ALUMINUM: 1/8" THK. MIN. (6063-T5 MIN.)
 STEEL: 1/8" THK. MIN. (Fy = 36 KSI MIN.)
 (STEEL IN CONTACT WITH ALUMINUM TO BE PLATED OR PAINTED)

ANCHOR EDGE DISTANCES

INTO METAL STRUCTURE = 1/2" MIN.

WOOD AT HEAD, SILL OR JAMBS SG = 0.55 MIN.
 CONCRETE AT HEAD, SILL OR JAMBS f'c = 3000 PSI MIN.
 C-90 GROUT FILLED BLOCK AT JAMBS f'm = 2000 PSI MIN.

WOOD BUCKS AND METAL STRUCTURE NOT BY ENVIRALUM
 MUST SUSTAIN LOADS IMPOSED BY GLAZING SYSTEM
 AND TRANSFER THEM TO THE BUILDING STRUCTURE.







FL #20701

Sealed 2/22/2019

af c
AL-FAROOQ CORPORATION
 ENGINEERS & PRODUCT DEVELOPMENT
 9360 SUNSET DRIVE, SUITE 220
 MIAMI, FLORIDA 33173 (C.A.N. 3538)
 TEL. (305) 264-8100 FAX. (305) 262-6978
 COMP-ANL\W17-42ENV

SERIES ENV-350 OUTSWING ENTRANCE DOOR (L.M.I.)
ENVIRALUM INDUSTRIES INC.
 5100 N.W. 72 AVENUE BLDG. C
 MIAMI, FL. 33166
 TEL. (305) 752-4411 FAX. (305) 406-3877

revisions:	no	date	by	description
date:	04-11-17	scale:	3/8" = 1"	
dr. by:	TARIQ	chk. by:		
drawing no.	W17-42			
sheet	5.1 of 10			



DOOR DETAILS

FL #20701


Sealed 2/22/2019

afc
AL-FAROOQ CORPORATION
 ENGINEERS & PRODUCT DEVELOPMENT
 9360 SUNSET DRIVE, SUITE 220
 MIAMI, FLORIDA 33173
 TEL. (305) 264-8100 FAX. (305) 262-6978
 COMP-ANL\W17-42ENV

SERIES ENW-350 OUTSWING ENTRANCE DOOR (L.M.I.)
ENVIRALUM INDUSTRIES INC.
 5100 N.W. 72 AVENUE BLDG. C
 MIAMI, FL. 33166
 TEL. (305) 752-4411 FAX. (305) 406-3877


revisions:	no	date	by	description

date: 04-11-17
 scale: 3/8" = 1"
 dr. by: TARIQ
 chk. by:
 drawing no.
W17-42
 sheet 6 of 10




REINFORCING AS REQD.
SEE SHEETS 3 & 3.1
FOR CAPACITY

1/4" X 1/2" X 4 7/32"
ALUM BAR
ATTACHED TO VERTICAL FRAMES
WITH (2) #12 S.S. SMS
REQD. FOR LOADS
ABOVE 58 PSF ONLY



TRANSOM DETAILS



FL #20701

Sealed 2/22/2019

afc

AL-FAROOQ CORPORATION
ENGINEERS & PRODUCT DEVELOPMENT
9360 SUNSET DRIVE, SUITE 220
MIAMI, FLORIDA 33173 (C.A.N. 3538)
TEL. (305) 264-8100 FAX. (305) 262-6978
COMP-ANL\W17-42ENV

SERIES ENW-350 OUTSWING ENTRANCE DOOR (L.M.I.)


ENVIRALUM INDUSTRIES INC.
5100 N.W. 72 AVENUE BLDG. C
MIAMI, FL. 33166
TEL. (305) 752-4411 FAX. (305) 406-3877

revisions:	
no	date by description


date: 04-11-17
scale: 3/8" = 1"
dr. by: TARIQ
chk. by:

drawing no.
W17-42

sheet 7 of 10




ANCHOR TYPES	NO. OF ANCHORS AT MTG. STILE ENDS	
	1/4" SHIM	3/8" SHIM
A	6	8
B	6	8
C	5	6



TYPICAL ELEVATIONS
DOORS TO MEET WATER REQUIREMENTS

NOTE:
FOR DOORS WITH GLASS TYPE 'B' (LEVEL 'E' IMPACT)
LIMIT MAX. DOOR HEIGHTS TO 98 INCHES.

HINGES AT WATER RESISTANT DOORS
(4) REQD. FOR DOOR HEIGHTS UPTO 90 1/2"
(5) REQD. ABOVE 90 1/2" HEIGHTS



FL #20701

Sealed 2/22/2019

af c
AL-FAROOQ CORPORATION
ENGINEERS & PRODUCT DEVELOPMENT
9360 SUNSET DRIVE, SUITE 220
MIAMI, FLORIDA 33173 (C.A.N. 3538)
TEL. (305) 264-8100 FAX. (305) 262-6978
COMP-ANL\W17-42ENV





SERIES ENV-350 OUTSWING ENTRANCE DOOR (L.M.I.)
ENVIRALUM INDUSTRIES INC.
5100 N.W. 72 AVENUE BLDG. C
MIAMI, FL. 33166
TEL. (305) 752-4411 FAX. (305) 406-3877

revisions:	no	date	by	description
date:	04-11-17	scale:	3/8" = 1"	
dr. by:	TARIQ	chk. by:		
drawing no.	W17-42			
sheet	7.1 of 10			


DETAILS

DOORS TO MEET WATER REQUIREMENTS


ITEM NUMBERS 40, 41, 42 AND 43 ADDED TO STANDARD DOOR SECTIONS TO MEET WATER INFILTRATION RESISTANCE REQUIREMENT. SEE SHEETS 5 AND 6 FOR STD. DOOR DETAILS.




40 DRIP CAP



41 DOOR SWEEP (TOP)



42 DOOR SWEEP (BOTTOM)



43 WATER FLAP


WATER RESISTANT DOOR COMPONENTS

afc
AL-FAROOQ CORPORATION
 ENGINEERS & PRODUCT DEVELOPMENT
 9360 SUNSET DRIVE, SUITE 220
 MIAMI, FLORIDA 33173 (C.A.N. 3538)
 TEL. (305) 264-8100 FAX. (305) 262-6978
 COMP-ANL\W17-42ENV

SERIES ENW-350 OUTSWING ENTRANCE DOOR (L.M.I.)
ENVIRALUM INDUSTRIES INC.
 5100 N.W. 72 AVENUE BLDG. C
 MIAMI, FL. 33166
 TEL. (305) 752-4411 FAX. (305) 406-3877





no	date	by	description

date: 04-11-17
 scale: 3/8" = 1"
 dr. by: TARIQ
 chk. by:




FL #20701

drawing no.
W17-42
 sheet 7.2 of 10



ADA COMPLIANT THRESHOLD



FL #20701


Sealed 2/22/2019

afc
AL-FAROOQ CORPORATION
 ENGINEERS & PRODUCT DEVELOPMENT
 9360 SUNSET DRIVE, SUITE 220
 MIAMI, FLORIDA 33173 (C.A.N. 3538)
 TEL. (305) 264-8100 FAX. (305) 262-6978
 COMP-ANL\W17-42ENV


SERIES ENV-350 OUTSWING ENTRANCE DOOR (L.M.I.)
ENVIRALUM INDUSTRIES INC.
 5100 N.W. 72 AVENUE BLDG. C
 MIAMI, FL. 33166
 TEL. (305) 752-4411 FAX. (305) 406-3877

revisions:	
no	date by description


date: 04-11-17
 scale: 3/8" = 1"
 dr. by: TARIQ
 chk. by:
 drawing no.
W17-42
 sheet 7.3 of 10




6 FRAME HEAD




5 STD. JAMB 16 FLAT FILLER




11 THRESHOLD TYPE 1




11.1 THRESHOLD TYPE 2




11.2 THRESHOLD TYPE 3




1 TOP RAIL




2 BOTTOM RAIL




3 HINGE STILE




4 LOCK STILE




5A NARROW JAMB




2.1 ALT. BOTTOM RAIL




8 GLASS STOP (LAM. GLASS)




7 GLASS STOP (INSUL. LAM. GLASS)




15 STEEL CHANNEL REINF.




16 SHEAR BLOCK




14 TRANSOM SASH




12 DOOR STOP




13 STILE REINFORCEMENT




17 GUIDE CHANNEL FOR TOP & BOTTOM PIN




10 THRESHOLD/DOOR STOP COVER



10.1 ALT. THRESHOLD COVER




9 RAMP THRESHOLD TYPE 1




9.1 RAMP THRESHOLD TYPE 2

9.2 RAMP THRESHOLD TYPE 3



19 MID-RAIL



FL #20701

Sealed 2/22/2019

AL-FAROOQ CORPORATION
 ENGINEERS & PRODUCT DEVELOPMENT
 9360 SUNSET DRIVE, SUITE 220
 MIAMI, FLORIDA 33173
 TEL. (305) 264-8100 FAX. (305) 262-6978

SERIES ENV-350 OUTSWING ENTRANCE DOOR (L.M.I.)
ENVIRALUM INDUSTRIES INC.
 5100 N.W. 72 AVENUE BLDG. C
 MIAMI, FL. 33166
 TEL. (305) 752-4411 FAX. (305) 406-3877

revisions:	no	date	by	description

date: 04-11-17
 scale: 3/8" = 1"
 dr. by: TARIQ
 chk. by:

drawing no.
W17-42
 sheet 8 of 10


ITEM NO.	PART NUMBER	QUANTITY	DESCRIPTION	MATERIAL	MANF./SUPPLIER/REMARKS
1	ENV-351	1/ LEAF	TOP RAIL	6063-T6	ENVIRALUM
2	ENV-352	1/ LEAF	BOTTOM RAIL (8" HIGH)	6063-T6	ENVIRALUM
2.1	ENV-3521	1/ LEAF	ALT. BOTTOM RAIL (10" HIGH)	6063-T6	ENVIRALUM
3	ENV-353	1/ LEAF	HINGE STILE	6063-T6	ENVIRALUM
4	ENV-354	1/ LEAF	LOCK STILE	6063-T6	ENVIRALUM
5	ENV-355	2/ DOOR	STANDARD JAMB	6063-T6	ENVIRALUM
5A	-	2/ DOOR	NARROW JAMB	6063-T6	ENVIRALUM
6	ENV-356	1/ DOOR	FRAME HEAD	6063-T6	ENVIRALUM
7	ENV-357	4/ LITE	GLASS STOP (INSULATED GLASS)	6063-T6	ENVIRALUM
8	ENV-358	4/ LITE	GLASS STOP (LAMINATED GLASS)	6063-T6	ENVIRALUM
9	ENV-359	AS REQD.	RAMP THRESHOLD TYPE 1	6063-T6	ENVIRALUM
9.1	ENV-3520	AS REQD.	RAMP THRESHOLD TYPE 2	6063-T6	ENVIRALUM
9.2	ENV-3527	AS REQD.	RAMP THRESHOLD TYPE 3	6063-T6	ENVIRALUM
10	ENV-3510	AS REQD.	THRESHOLD/DOOR STOP COVER	6063-T6	ENVIRALUM
10.1	ENV-3518	AS REQD.	ALT. THRESHOLD COVER (HI-RISE)	6063-T6	ENVIRALUM
11	ENV-3511	1/ DOOR	THRESHOLD TYPE 1	6063-T6	ENVIRALUM
11.1	ENV-3519	1/ DOOR	THRESHOLD TYPE 2	6063-T6	ENVIRALUM
11.2	ENV-3526	1/ DOOR	THRESHOLD TYPE 3	6063-T6	ENVIRALUM
12	ENV-3512	3/ DOOR	DOOR STOP	6063-T6	ENVIRALUM
13	ENV-3513	AS REQD.	STILE REINFORCEMENT, REQD. FOR DOORS ABOVE 8 FT. HIGH	6063-T6	ENVIRALUM
14	ENV-3515	4/ TRANSOM	TRANSOM SASH	6063-T6	ENVIRALUM
15	ENV-ST2	AS REQD.	1" X 4-1/8" X 1" X 3/16" THK. CHANNEL	STEEL	ENVIRALUM
16	ENV-3516	1/ LEAF CORNER	SHEAR BLOCK	6063-T6	ENVIRALUM
17	ENV-GC01	2/ LEAF	GUIDE CHANNEL FOR TOP & BOTTOM PIN	6063-T6	ENVIRALUM
18	ENV-454	AS REQD.	FLAT SNAP, 3" LONG	6063-T6	ENVIRALUM
19	ENV-3514	AS REQD.	MID-RAIL (OPTIONAL)	6063-T5	ENVIRALUM
21	ENV-G04	AS REQD.	INTERIOR GASKET	EPDM	GLAZING RUBBER PRODUCTS
22	ENV-G06	AS REQD.	SPACER GASKET	EPDM	GLAZING RUBBER PRODUCTS
22A	ENV-G06	1/ QUARTER POINT	SPACER GASKET, 1" LONG	EPDM	GLAZING RUBBER PRODUCTS
23	ENV-SB01	1/ QUARTER POINT	3/8" X 1/2" X 2" SETTING BLOCKS, DUROMETER 80±5	EPDM	GLAZING RUBBER PRODUCTS
24	ENV-SB02	1/ QUARTER POINT	3/8" X 1-1/4" X 2" SETTING BLOCKS, DUROMETER 80±5	EPDM	GLAZING RUBBER PRODUCTS
25	DOW 791	AS REQD.	GLAZING COMPOUND	SILICONE	DOWSIL
26	GE SCS2000	AS REQD.	GLAZING COMPOUND	SILICONE	GE MOMENTIVE
27	#12 X 1-1/2	4/ CORNER	FRAME ASSEMBLY SCREWS	ST. STEEL	HWH SMS, AT 16" O.C.
28	#8 X 5/8"	AS REQD.	TRANSOM SASH SCREWS	ST. STEEL	AT 3" FROM ENDS & 12" O.C.
29	#8 X 5/8"	AS REQD.	DOOR STOP ASSEMBLY SCREWS, @ 3" FROM ENDS & 20" O.C.	ST. STEEL	HWH SMS
30	ENV-BP1	2/ HINGE	HINGE BACKING PLATE, 1-1/2" X 1/4" THK. X 8-3/8" LONG	ALUMINUM	-
31	-	3/ LEAF	4-1/2" X 4" BUTT HINGES	ST. STEEL	-
32	SL-21	1/ LEAF	CONT. GEAR HINGE	ALUMINUM	SELECT PRODUCTS LTD.
32A	PEMKO-FS	1/ LEAF	CONT. GEAR HINGE	ALUMINUM	PEMKO
33	1/4-20 X 1"	10/ LEAF	CORNER BLOCK ASSEMBLY	ST. STEEL	HEX HEAD BOLT W/ WASHER
34	ENV-G01	AS REQD.	FIXED INTERIOR GASKET	EPDM	GLAZING RUBBER PRODUCTS
37	ENV-WP1	AS REQD.	WOOL PILE W'STRIPPING	TRILOBAL YARN	ULTRAFAB
38	ENV-WP2	AS REQD.	WOOL PILE W'STRIPPING	TRILOBAL YARN	ULTRAFAB
39	ENV-BG1	AS REQD.	BULB W'STRIPPING, (.475 BULB W/ FLAP X .270 BK.)	EPDM	ULTRAFAB
40	ENV-3518	AS REQD.	DRIP CAP	ALUMINUM	PEMKO
40A	#8 X 5/8"	AS REQD.	DRIP CAP FASTENERS, AT 3" FROM ENDS & 6" O.C.	ST. STEEL	HWH SELF DRILLING SCREWS
41	ENV-3512	AS REQD.	DOOR SWEEP (TOP)	ALUMINUM	PEMKO
41A	#8 X 1/2"	AS REQD.	DOOR SWEEP FASTENERS, AT 3" FROM ENDS & 6" O.C.	ST. STEEL	FH SELF DRILLING SCREWS
42	ENV-3523	AS REQD.	DOOR SWEEP (BOTTOM)	ALUMINUM	PEMKO
42A	#8 X 3/4"	AS REQD.	DOOR SWEEP FASTENERS, AT 3" FROM ENDS & 6" O.C.	ST. STEEL	HH SELF DRILLING SCREWS
43	ENV-WF1	AS REQD.	WATER FLAP	EPDM	ULTRAFAB

SEALANTS:

ALL FRAME CORNERS, JOINTS, MULLION SEAMS AND PERIMETER OF GLAZING BEAD TO FRAME SEALED WITH SILICONE SEALANT.


HINGE OPTION #1:

4" X 4-1/2" X .130" THK. ST. STEEL KNUCKLE HINGE SERIES 4001 BY 'REGENT HARDWARE' OR SERIES FBB 191 BY 'STANLEY SECURITY SOLUTIONS' OR SERIES TA2314/TA2714 BY 'MCKINNEY ASSA ABLOY' 3 PER LEAF
TOP/BOTTOM HINGES AT 7" FROM EACH END
CENTER HINGE AT MIDSPAN
FASTENED TO
FRAME JAMB WITH (4) 12-24 X 1/2" FH MS
DOOR STILE WITH (4) 12-24 X 1/2" FH MS





HINGE OPTION #2:

CONTINUOUS GEAR ALUMINUM HINGE 'PEMKO-FS' OR 'SELECT SL-21' FASTENED TO
FRAME JAMB WITH #12 X 3/4" FH SCREWS AT 6" O.C.
DOOR STILE WITH 1/4-20 X 1-1/4" FH MS WITH SEX BOLT AT 6" O.C.



HINGE OPTION #3:

CONTINUOUS ALUMINUM ROTTON HINGE 'PEMKO-FM' OR 'SELECT SL 27' FASTENED TO FRAME JAMB AND TO JAMB STILE WITH (22) #12-24 X 1/2" FH MS SCREWS



FL #20701

Sealed 2/22/2019


af c
AL-FAROOQ CORPORATION
ENGINEERS & PRODUCT DEVELOPMENT
9360 SUNSET DRIVE, SUITE 220
MIAMI, FLORIDA 33173
TEL. (305) 264-8100 FAX. (305) 262-6978
COMP-ANL\W17-42ENV

SERIES ENV-350 OUTSWING ENTRANCE DOOR (L.M.I.)
ENVIRALUM INDUSTRIES INC.
5100 N.W. 72 AVENUE BLDG. C
MIAMI, FL. 33166
TEL. (305) 752-4411 FAX. (305) 406-3877

revisions:
no date by description

date: 04-11-17
scale: 3/8" = 1"
dr. by: TARIQ
chk. by:

drawing no.
W17-42
sheet 9 of 10



af c


AL-FAROOQ CORPORATION
 ENGINEERS & PRODUCT DEVELOPMENT
 9360 SUNSET DRIVE, SUITE 220
 MIAMI, FLORIDA 33173 (C.A.N. 3538)
 TEL. (305) 264-8100 FAX. (305) 262-6978
 COMP-ANL\W17-42ENV

SERIES ENV-350 OUTSWING ENTRANCE DOOR (L.M.I.)

ENVIRALUM INDUSTRIES INC.
 5100 N.W. 72 AVENUE BLDG. C
 MIAMI, FL. 33166
 TEL. (305) 752-4411 FAX. (305) 406-3877

revisions:	no	date	by	description

date: 04-11-17
 scale: 3/8" = 1"
 dr. by: TARIQ
 chk. by:



FL #20701

drawing no.
W17-42
 sheet 10 of 10

Sealed 2/22/2019