



8000 Vinyl Casement Picture Window 2-Wide
47 1/2" x 95 1/2" Individual Unit Frame Size
95 1/2" x 95 1/2" Overall Unit Frame Size
Nail Fin Installation / Non-Impact

TEST REPORT SUMMARY:

- MAXIMUM OVERALL COMBINATION FRAME SIZE:
95 1/2" (2426mm) x 95 1/2" (2426mm)
- OVERALL DESIGN PRESSURE: ± 40.10 psf
- STRUCTURAL TEST PRESSURE: ± 60.15 psf
- RATING: LC-PG40



CCL Listing #448-H-004.27 - .28		ELEMENT TEST REPORT #: ESP030570P-2419.1	
8000 Vinyl Series Casement Picture 2-Wide Nail Fin Installation / WDMA Instructions / Non-Impact			
SHEET: 1 OF 3		UPDATED: 5/10/2019	DRAWN BY: B.K.

FRAME ANCHOR INSTALLATION NOTES:

1. USE 2" X _ WOOD BUCK.
2. PLACE WOOD SHIMS EVERY 6-10" **AND** BEHIND EACH SCREW.
3. 1/4" MAXIMUM SHIM SPACE AT HEAD, SILL AND EACH JAMB.
4. APPLY A CONTINUOUS BEAD OF SEALANT BETWEEN THE NAIL FIN AND THE BUCK AT THE HEAD, SILL AND SIDE JAMBS TO SECURE NAILING FLANGE TO FRAMING MATERIAL.
5. INSTALL #8 X 1-1/4" PPH ZINC COATED SCREWS SPACED MAXIMUM 2-4" FROM EACH CORNER AND MAXIMUM 7" ON CENTER THEREAFTER, THROUGH THE INTEGRAL NAIL FIN INTO THE WOOD BUCK FRAMING MATERIAL, AT HEAD, SILL AND SIDE JAMBS.
 - MINIMUM FASTENER EMBEDMENT OF 1" INTO FRAMING MATERIAL.
 - 3/8" MINIMUM EDGE DISTANCE.
 - SILICONE SEAL OVER SCREW HEADS.
6. STRAP ANCHORS ARE SPACED 76MM (3) EACH SIDE OF MULL CENTER AT HEAD AND SILL ALONG WITH ONE AT THE SIDE JAMBS AT CENTER. THE ANCHOR STRAPS ARE FASTENED TO THE WINDOW FRAME WITH THREE #8 X 16MM (5/8) PFH SELF- TAPPING SCREWS AND TO THE BUCK WITH TWO #8 X 32MM (1-1/4) PPH SCREWS EACH ANCHOR STRAP.

GENERAL INSTALLATION NOTES:

- Check rough opening for proper size, plumb, level and square.
- Make all necessary adjustments to ensure rough opening is plumb, level & square.
- Sill must be flat, level and capable of supporting the weight of the unit.
- Opening must allow a maximum of 1/4" shim space at head, sill and jambs.
- Wood buck, framing, fasteners, sealant and all wall system materials are provided by others



Installation requirements may vary in particular locations and in other types of construction. Proper installation is essential, and Sierra Pacific Windows, recommends consultation with an AAMA Certified Installer, or other qualified, registered building professional before installation of any Sierra Pacific product. Proper installation of Sierra Pacific products is the responsibility of the installer. Sierra Pacific is not responsible for proper installation. Sierra Pacific is not responsible for the design of, conditions in, or performance of building construction beyond the perimeters of the Sierra Pacific units. Sierra Pacific is not responsible for proper integration of the Sierra Pacific units with the weather-repellent systems of the building.





8000 Vinyl Casement Picture Window 2-Wide
47 1/2" x 95 1/2" Individual Unit Frame Size
95 1/2" x 95 1/2" Overall Unit Frame Size
Nail Fin Installation / Non-Impact

TEST REPORT SUMMARY:

- MAXIMUM OVERALL COMBINATION FRAME SIZE:
95 1/2" (2426mm) x 95 1/2" (2426mm)
- OVERALL DESIGN PRESSURE: ± 40.10 psf
- STRUCTURAL TEST PRESSURE: ± 60.15 psf
- RATING: **LC-PG40**

CCL Listing #448-H-004.27 -.28	ELEMENT TEST REPORT #: ESP030570P-2419.1		
8000 Vinyl Series Casement Picture 2-Wide Nail Fin Installation / WDMA Instructions / Non-Impact			
SHEET: 2 OF 3		UPDATED: 5/10/2019	DRAWN BY: B.K.

THE STRAP ANCHORS ARE SPACED 76MM (3) EACH SIDE OF MULL CENTER AT HEAD AND SILL ALONG WITH ONE AT THE SIDE JAMBS AT CENTER. THE ANCHOR STRAPS ARE FASTENED TO THE WINDOW FRAME WITH THREE #8 X 16MM (5/8) PFH SELF- TAPPING SCREWS AND TO THE BUCK WITH TWO #8 X 32MM (1-1/4) PPH SCREWS EACH ANCHOR STRAP.



Installation requirements may vary in particular locations and in other types of construction. Proper installation is essential, and Sierra Pacific Windows, recommends consultation with an AAMA Certified Installer, or other qualified, registered building professional before installation of any Sierra Pacific product. Proper installation of Sierra Pacific products is the responsibility of the installer. Sierra Pacific is not responsible for proper installation. Sierra Pacific is not responsible for the design of, conditions in, or performance of building construction beyond the perimeters of the Sierra Pacific units. Sierra Pacific is not responsible for proper integration of the Sierra Pacific units with the weather-repellent systems of the building.



8000 Vinyl Casement Picture Window 2-Wide
47 1/2" x 95 1/2" Individual Unit Frame Size
95 1/2" x 95 1/2" Overall Unit Frame Size
Nail Fin Installation / Non-Impact

TEST REPORT SUMMARY:

- MAXIMUM OVERALL COMBINATION FRAME SIZE:
95 1/2" (2426mm) x 95 1/2" (2426mm)
- OVERALL DESIGN PRESSURE: ± 40.10 psf
- STRUCTURAL TEST PRESSURE: ± 60.15 psf
- RATING: LC-PG40

CCL Listing #448-H-004.27 - .28


ELEMENT TEST REPORT #: **ESP030570P-2419.1**

8000 Vinyl Series Casement Picture 2-Wide
Nail Fin Installation / WDMA Instructions / Non-Impact

SHEET: 3 OF 3

UPDATED: 5/10/2019

DRAWN BY: B.K.



Installation requirements may vary in particular locations and in other types of construction. Proper installation is essential, and Sierra Pacific Windows, recommends consultation with an AAMA Certified Installer, or other qualified, registered building professional before installation of any Sierra Pacific product. Proper installation of Sierra Pacific products is the responsibility of the installer. Sierra Pacific is not responsible for proper installation. Sierra Pacific is not responsible for the design of, conditions in, or performance of building construction beyond the perimeters of the Sierra Pacific units. Sierra Pacific is not responsible for proper integration of the Sierra Pacific units with the weather-repellent systems of the building.