FOUR SEASONS BUILDING PRODUCTS

PRO-FAB ROOF PANELS - PERFORMANCE EVALUATION REPORT
NON-IMPACT - HVHZ / NON-HVHZ

NON-SITE-SPECIFIC STRUCTURAL PERFORMANCE EVALUATION. A DESIGN PROFESSIONAL SHALL BE RESPONSIBLE FOR CERTIFYING THE APPLICATION OF THIS INFORMATION TO ANY SITE-SPECIFIC LOCATION.

NOTE REGARDING USE OF THIS DOCUMENT & USE OUTSIDE FLORIDA:
THIS IS A NON-SITE-SPECIFIC STRUCTURAL PERFORMANCE EVALUATION. THIS PRODUCT EVALUATION IS VALID FOR USE IN **FLORIDA ONLY**. USE OF THIS EVALUATION REQUIRES A REVIEW & CERTIFICATION BY A LOCAL DESIGN PROFESSIONAL WHO SHALL BE RESPONSIBLE FOR THE PROPER ADAPTATION OF THIS GENERAL PERFORMANCE EVALUATION TO ANY SITE-SPECIFIC PROJECT. CONTACT THIS OFFICE AT **ENGINEERINGEXPRESS.COM/QUOTE** FOR ASSISTANCE WITH YOUR PROJECT-SPECIFIC NEEDS & FOR ADAPTATION & CERTIFICATION OF THIS DOCUMENT OUTSIDE OF FLORIDA.

ENGINEER SIGNATURE & SEAL NOTICE:
*PRINTED COPIES OF THIS DOCUMENT ARE NOT CONSIDERED SIGNED & SEALED. SIGNATURE MUST BE VERIFIED ON ANY ELECTRONIC COPIES.
***FOR FLORIDA STATEWIDE PRODUCT APPROVALS (FSAs) REGISTERED & APPROVED WITH THE STATE OF FLORIDA:** ORIGINAL, SEALED COPIES OF APPROVED FLORIDA PRODUCT APPROVALS ARE NOT REQUIRED FOR PERMIT.
SEE **ECALC.IO/SEAL** TO LEARN MORE.

FRANK BENNARDO, PE
PE# 0046549 CA# 9885

FRANK L. BENNARDO LICENSE No 0046549 STATE OF FLORIDA PROFESSIONAL ENGINEER

Digitally signed by Frank Bennardo
Date: 2026.08.19 14:44:40 -04'00'


MAXIMUM ALLOWABLE CLEAR SPAN TABLE:

ASD Design Load	Deflection Limit (L/…)	3" Panels				4" Panels			6" Panels		
		0.024" Alum Skin 1-LB EPS	0.030" Alum Skin 1-LB EPS	26ga Steel Skin 1-LB EPS	0.024" (*) Alum Skin 1.5-LB EPS	0.024" Alum Skin 1-LB EPS	0.030" Alum Skin 1-LB EPS	26ga Steel Skin 1-LB EPS	0.024" Alum Skin 1-LB EPS	0.030" Alum Skin 1-LB EPS	26ga Steel Skin 1-LB EPS
10 PSF	80	17'-2"	19'-11"	20'-0"	17'-11"	20'-4"	22'-0"	23'-0"	23'-0"	23'-0"	23'-0"
	120	15'-0"	17'-5"	18'-7"	15'-8"	17'-9"	19'-2"	21'-11"	22'-6"	23'-0"	23'-0"
	180	13'-1"	15'-3"	16'-2"	13'-8"	15'-6"	16'-9"	19'-2"	19'-8"	20'-8"	23'-0"
	240	11'-11"	13'-10"	14'-9"	12'-5"	14'-1"	15'-3"	17'-5"	17'-10"	18'-10"	21'-11"
15 PSF	80	15'-0"	16'-9"	16'-6"	15'-8"	17'-6"	18'-9"	18'-9"	20'-10"	22'-6"	23'-0"
	120	13'-1"	15'-3"	16'-2"	13'-8"	15'-6"	16'-9"	18'-9"	19'-8"	20'-8"	23'-0"
	180	11'-5"	13'-3"	14'-2"	11'-11"	13'-7"	14'-8"	16'-9"	17'-2"	18'-1"	21'-1"
	240	10'-5"	12'-1"	12'-10"	10'-10"	12'-4"	13'-4"	15'-2"	15'-7"	16'-5"	19'-2"
20 PSF	80	13'-7"	14'-6"	14'-4"	14'-3"	15'-1"	16'-3"	16'-3"	18'-0"	19'-6"	20'-8"
	120	11'-11"	13'-10"	14'-4"	12'-5"	14'-1"	15'-3"	16'-3"	17'-10"	18'-10"	20'-8"
	180	10'-5"	12'-1"	12'-10"	10'-10"	12'-4"	13'-4"	15'-2"	15'-7"	16'-5"	19'-2"
	240	9'-5"	11'-0"	11'-8"	9'-10"	11'-2"	12'-1"	13'-10"	14'-2"	14'-11"	17'-5"
25 PSF	80	12'-2"	13'-0"	12'-10"	13'-3"	13'-6"	14'-7"	14'-6"	16'-2"	17'-5"	18'-5"
	120	11'-1"	12'-10"	12'-10"	11'-6"	13'-1"	14'-2"	14'-6"	16'-2"	17'-5"	18'-5"
	180	9'-8"	11'-2"	11'-11"	10'-1"	11'-5"	12'-4"	14'-1"	14'-6"	15'-3"	17'-9"
	240	8'-9"	10'-2"	10'-10"	9'-2"	10'-5"	11'-2"	12'-10"	13'-2"	13'-10"	16'-2"
30 PSF	80	11'-1"	11'-10"	11'-8"	12'-3"	12'-4"	13'-3"	13'-3"	14'-9"	15'-11"	16'-10"
	120	10'-5"	11'-10"	11'-8"	10'-10"	12'-4"	13'-3"	13'-3"	14'-9"	15'-11"	16'-10"
	180	9'-1"	10'-6"	11'-3"	9'-6"	10'-9"	11'-7"	13'-3"	13'-7"	14'-4"	16'-9"
	240	8'-3"	9'-7"	10'-2"	8'-7"	9'-9"	10'-7"	12'-1"	12'-4"	13'-0"	15'-2"
35 PSF	80	10'-3"	11'-0"	10'-10"	11'-4"	11'-5"	12'-3"	12'-3"	13'-8"	14'-9"	15'-7"
	120	9'-10"	11'-0"	10'-10"	10'-4"	11'-5"	12'-3"	12'-3"	13'-8"	14'-9"	15'-7"
	180	8'-7"	10'-0"	10'-8"	9'-0"	10'-3"	11'-0"	12'-3"	12'-11"	13'-7"	15'-7"
	240	7'-10"	9'-1"	9'-8"	8'-2"	9'-3"	10'-0"	11'-5"	11'-9"	12'-4"	14'-5"
40 PSF	80	9'-7"	10'-3"	10'-1"	10'-7"	10'-8"	11'-6"	11'-6"	12'-9"	13'-9"	14'-7"
	120	9'-5"	10'-3"	10'-1"	9'-10"	10'-8"	11'-6"	11'-6"	12'-9"	13'-9"	14'-7"
	180	8'-3"	9'-7"	10'-1"	8'-7"	9'-9"	10'-7"	11'-6"	12'-4"	13'-0"	14'-7"
	240	7'-6"	8'-8"	9'-3"	7'-10"	8'-10"	9'-7"	10'-11"	11'-3"	11'-10"	13'-9"
45 PSF	80	9'-1"	9'-8"	9'-6"	10'-0"	10'-1"	10'-10"	10'-10"	12'-0"	13'-0"	13'-9"
	120	9'-1"	9'-8"	9'-6"	9'-6"	10'-1"	10'-10"	10'-10"	12'-0"	13'-0"	13'-9"
	180	7'-11"	9'-2"	9'-6"	8'-3"	9'-5"	10'-2"	10'-10"	11'-11"	12'-6"	13'-9"
	240	7'-2"	8'-4"	8'-11"	7'-6"	8'-6"	9'-2"	10'-6"	10'-10"	11'-4"	13'-3"


ASD Design Load	Deflection Limit (L/…)	3" Panels				4" Panels			6" Panels		
		0.024" Alum Skin 1-LB EPS	0.030" Alum Skin 1-LB EPS	26ga Steel Skin 1-LB EPS	0.024" (*) Alum Skin 1.5-LB EPS	0.024" Alum Skin 1-LB EPS	0.030" Alum Skin 1-LB EPS	26ga Steel Skin 1-LB EPS	0.024" Alum Skin 1-LB EPS	0.030" Alum Skin 1-LB EPS	26ga Steel Skin 1-LB EPS
50 PSF	80	8'-7"	9'-2"	9'-0"	9'-5"	9'-7"	10'-3"	10'-3"	11'-5"	12'-4"	13'-0"
	120	8'-7"	9'-2"	9'-0"	9'-2"	9'-7"	10'-3"	10'-3"	11'-5"	12'-4"	13'-0"
	180	7'-8"	8'-11"	9'-0"	8'-0"	9'-1"	9'-9"	10'-3"	11'-5"	12'-1"	13'-0"
	240	6'-11"	8'-1"	8'-7"	7'-3"	8'-3"	8'-11"	10'-2"	10'-5"	11'-0"	12'-10"
55 PSF	80	8'-2"	8'-9"	8'-7"	9'-0"	9'-1"	9'-10"	9'-9"	10'-10"	11'-9"	12'-5"
	120	8'-2"	8'-9"	8'-7"	8'-10"	9'-1"	9'-10"	9'-9"	10'-10"	11'-9"	12'-5"
	180	7'-5"	8'-7"	8'-7"	7'-9"	8'-9"	9'-6"	9'-9"	10'-1"	11'-8"	12'-5"
	240	6'-9"	7'-10"	8'-4"	7'-0"	8'-0"	8'-7"	9'-9"	10'-1"	10'-8"	12'-5"
60 PSF	80	7'-10"	8'-4"	8'-3"	8'-8"	8'-9"	9'-4"	9'-4"	10'-5"	11'-3"	11'-11"
	120	7'-10"	8'-4"	8'-3"	8'-7"	8'-9"	9'-4"	9'-4"	10'-5"	11'-3"	11'-11"
	180	7'-2"	8'-4"	8'-3"	7'-6"	8'-6"	9'-2"	9'-4"	10'-5"	11'-3"	11'-11"
	240	6'-6"	7'-7"	8'-1"	6'-10"	7'-9"	8'-4"	9'-4"	9'-10"	10'-4"	11'-11"
65 PSF	80	7'-6"	8'-0"	7'-11"	8'-3"	8'-4"	9'-0"	9'-0"	10'-0"	10'-10"	11'-5"
	120	7'-6"	8'-0"	7'-11"	8'-3"	8'-4"	9'-0"	9'-0"	10'-0"	10'-10"	11'-5"
	180	7'-0"	8'-0"	7'-11"	7'-4"	8'-4"	9'-0"	9'-0"	10'-0"	10'-10"	11'-5"
	240	6'-4"	7'-5"	7'-10"	6'-8"	7'-7"	8'-2"	9'-0"	9'-7"	10'-1"	11'-5"
70 PSF	80	7'-3"	7'-9"	7'-8"	8'-0"	8'-1"	8'-8"	8'-8"	9'-7"	10'-5"	11'-0"
	120	7'-3"	7'-9"	7'-8"	8'-0"	8'-1"	8'-8"	8'-8"	9'-7"	10'-5"	11'-0"
	180	6'-10"	7'-9"	7'-8"	7'-2"	8'-1"	8'-8"	8'-8"	9'-7"	10'-5"	11'-0"
	240	6'-2"	7'-2"	7'-8"	6'-6"	7'-4"	7'-11"	8'-8"	9'-4"	9'-10"	11'-0"
75 PSF	80	7'-0"	7'-6"	7'-4"	7'-9"	7'-9"	8'-5"	8'-4"	9'-4"	10'-1"	10'-8"
	120	7'-0"	7'-6"	7'-4"	7'-9"	7'-9"	8'-5"	8'-4"	9'-4"	10'-1"	10'-8"
	180	6'-8"	7'-6"	7'-4"	7'-0"	7'-9"	8'-5"	8'-4"	9'-4"	10'-1"	10'-8"
	240	6'-1"	7'-0"	7'-4"	6'-4"	7'-2"	7'-9"	8'-4"	9'-1"	9'-7"	10'-8"
80 PSF	80	6'-9"	7'-3"	7'-2"	7'-6"	7'-6"	8'-1"	8'-1"	9'-0"	9'-9"	10'-4"
	120	6'-9"	7'-3"	7'-2"	7'-6"	7'-6"	8'-1"	8'-1"	9'-0"	9'-9"	10'-4"
	180	6'-6"	7'-3"	7'-2"	6'-10"	7'-6"	8'-1"	8'-1"	9'-0"	9'-9"	10'-4"
	240	5'-11"	6'-11"	7'-2"	6'-2"	7'-0"	7'-7"	8'-1"	8'-11"	9'-5"	10'-4"

TABLE USE INSTRUCTIONS:
1. OBTAIN SITE-SPECIFIC GRAVITY (DOWNWARD) AND UPLIFT (UPWARD) DESIGN PRESSURES, PREPARED BY A DESIGN PROFESSIONAL PER THE GOVERNING CODE FOR THE PROJECT LOCATION. THE LARGER OF THE GRAVITY OR UPLIFT LOAD SHALL BE YOUR CONTROLLING DESIGN VALUE.
2. FOR THE SELECTED PANEL AND OVERHANG CONDITION, READ THE ALLOWABLE SPAN FROM THE TABLE.
3. WHERE A PRESSURE FALLS BETWEEN ROWS, USE THE NEXT HIGHER ROW OR INTERPOLATE LINEARLY.
4. THE SMALLEST OF THE ALLOWABLE DESIGN SPANS GOVERNS THE MAXIMUM ALLOWABLE PANEL SPAN.
5. VERIFY THE PROJECT SPAN DOES NOT EXCEED THE GOVERNING TABLE VALUE.
6. FRONT (BEAM) AND BACK (HOST) CONNECTIONS ARE BY SEPARATE SITE-SPECIFIC DESIGN.
7. FOR PRESSURES AND SPANS BEYOND THE VALUES STATED HEREIN, CONTACT THIS OFFICE FOR SITE-SPECIFIC CONSULTATION.
8. FOR SITE-SPECIFIC ASD DESIGN PRESSURES, VISIT **ENGINEERINGEXPRESS.COM/WIND.**

TABLE NOTES:
1. SPANS ARE BASED ON THE PRODUCT TESTING AND EVALUATION REPORT PER THE GENERAL NOTES.
2. PRESSURES SHALL REFLECT THE CONTROLLING ASCE 7 LOAD COMBINATION (DEAD, LIVE, SNOW, WIND, ETC.), DETERMINED SEPARATELY.
3. THE SPANS LISTED HEREIN ARE APPLICABLE FOR NON-HABITABLE STRUCTURES ONLY.
4. TABLES CONSIDER ASD PRESSURES. FOR ULTIMATE PRESSURES, P(ULT) = P(ASD)*5/3.
5. A 0.7x REDUCTION (PER TABLE 1604.3 FOOTNOTE f) APPLIES TO DEFLECTION ONLY, UNLESS NOTED.



1/1 ROOF PANEL/SPAN DETAIL — N.T.S. — VERT SECTION



2/1 PANEL INTERLOCK — N.T.S. — VERT SECTION

MAXIMUM ALLOWABLE DESIGN PRESSURES: AS NOTED IN CLEAR SPAN TABLE

DESIGN NOTES
1. POSITIVE AND NEGATIVE DESIGN PRESSURES CALCULATED FOR USE WITH THIS SYSTEM SHALL BE DETERMINED BY OTHERS ON A JOB-SPECIFIC BASIS IN ACCORDANCE WITH THE STRUCTURAL REQUIREMENTS OF THE FLORIDA BUILDING CODE NINTH EDITION (2026).
2. SEPARATE 'SITE-SPECIFIC' SEALED ENGINEERING SHALL BE REQUIRED IN ORDER TO DEVIATE FROM LOADS, DEFLECTIONS, OR SPANS CONTAINED HEREIN. LINEAR INTERPOLATION OF THE ALLOWABLE SPAN TABLES LISTED HEREIN SHALL DETERMINE VALUES. CONTACT THIS ENGINEER FOR ALTERNATE SPAN CALCULATIONS AS NECESSARY.
3. EPS CORE COMPOSITE PANELS SHALL BE CONSTRUCTED USING TYPE 3105-H254 ALUMINUM FACINGS, 1.0 PCF EPS. THE EPS FOAM SHALL BE ADHERED TO THE ALUMINUM FACINGS WITH MOR-AD M-652 MOISTURE CURE URETHANE ADHESIVE (BY ROHM & HAAS Co.). FABRICATION SHALL BE IN ACCORDANCE WITH APPROVED FABRICATION METHODS BY METALS BUILDING PRODUCTS AT THEIR GROVELAND FACILITY FOR ALL PANELS EXCEPT THE 3" / 0.024" ALUM SKIN / 1.5-lb FOAM PANELS, WHICH SHALL BE MANUFACTURED BY METALS BUILDING PRODUCTS AT THEIR GROVELAND FACILITY.
4. IF APPLICABLE, COMPOSITE ROOF PANELS SHALL COMPLY WITH CHAPTER 7 SECTION 720, CHAPTER 8 SECTION 803, CLASS A INTERIOR FINISH, AND CHAPTER 26 SECTION 2603 OF THE FBC.
5. EPS PANEL PERFORMANCE CHARACTERISTICS FOR SELF IGNITION, FLAME SPREAD AND SMOKE DENSITY HAVE BEEN QUALIFIED THROUGH APPLICABLE ASTM TEST STANDARDS. SEE EVALUATION REPORT FOR MORE INFORMATION.
6. PANEL DEAD LOADS HAVE BEEN FACTORED INTO CALCULATIONS FOR GRAVITY LOADS AS WELL AS CALCULATIONS FOR PANEL PROPERTIES.

GENERAL NOTES
1. THIS SPECIFICATION HAS BEEN DESIGNED AND SHALL BE FABRICATED IN ACCORDANCE WITH THE REQUIREMENTS OF THE APPLICABLE BUILDING CODE. CONTRACTOR SHALL INVESTIGATE AND CONFORM TO ALL LOCAL BUILDING CODE AMENDMENTS WHICH MAY APPLY. DESIGN CRITERIA BEYOND AS STATED HEREIN MAY REQUIRE ADDITIONAL SITE-SPECIFIC SEALED ENGINEERING.
2. THE ARCHITECT/ENGINEER OF RECORD FOR THE PROJECT SUPERSTRUCTURE WITH WHICH THIS DESIGN IS USED SHALL BE RESPONSIBLE FOR THE INTEGRITY OF ALL SUPPORTING SURFACES TO THIS DESIGN WHICH SHALL BE COORDINATED BY THE PERMITTING CONTRACTOR.
3. THE CONTRACTOR SHALL CAREFULLY CONSIDER POSSIBLE IMPOSING LOADS ON ROOF, INCLUDING BUT NOT LIMITED TO ANY CONCENTRATED LOADS WHICH MAY JUSTIFY GREATER DESIGN CRITERIA. THIS ADDITIONAL ROOF LOAD CRITERIA SHALL BE PROPERLY ANALYZED BY A LICENSED ENGINEER OR REGISTERED ARCHITECT.
4. ALL PANEL ATTACHMENTS SHALL BE CERTIFIED PER SEPARATE ENGINEERING ON A SITE SPECIFIC BASIS.REFER TO FASTENER MANUFACTURER'S PUBLISHED DATA SHEETS AND RECOMMENDATIONS FOR FASTENER INSTALLATION INSTRUCTIONS.
5. FOR PERMANENT OUTDOOR INSTALLATIONS, ALL EXPOSED ANCHORS, FASTENERS, CONNECTORS, AND METAL PLATES SHALL BE CORROSION RESISTANT. CORROSION RESISTANCE MAY BE PROVIDED BY INHERENT MATERIAL COMPOSITION OR, WHERE PERMITTED BY CODE, BY AN APPROVED PROTECTIVE COATING OR GALVANIZATION. WHERE APPLICABLE NEAR A SALTWATER COASTLINE, SUCH COMPONENTS SHALL COMPLY WITH FBC SECTION 1711, INCLUDING APPLICABLE REQUIREMENTS FOR EXPOSED, PROTECTED, OR ENCLOSED CONDITIONS. MATERIALS, COATINGS, AND FINISHES SHALL BE COMPATIBLE WITH CONNECTED MATERIALS, AND PROTECTIVE COATINGS SHALL BE CONTINUOUS OVER EXPOSED SURFACES. FASTENERS USED WITH ALUMINUM MEMBERS SHALL ALSO COMPLY WITH SECTION J.3.7.2 OF THE ALUMINUM DESIGN MANUAL, "SPECIFICATION FOR ALUMINUM STRUCTURES." SUBSTITUTION OF COMPONENTS FROM ALTERNATE MANUFACTURERS, OR WITH DIFFERENT MATERIALS, COATINGS, OR FINISHES, SHALL NOT BE ASSUMED EQUIVALENT AND MAY REQUIRE ADDITIONAL ENGINEERING REVIEW OR SITE-SPECIFIC ANALYSIS.
6. CONTRACTOR IS RESPONSIBLE TO INSULATE OR PROTECT ALL MEMBERS FROM DISSIMILAR MATERIALS TO PREVENT ELECTROLYSIS.THE CONTRACTOR IS RESPONSIBLE TO INSULATE ALL MEMBERS FROM DISSIMILAR MATERIALS TO PREVENT ELECTROLYSIS.
7. ENGINEER SEAL AFFIXED HERE TO VALIDATES STRUCTURAL DESIGN AS SHOWN ONLY. USE OF THIS SPECIFICATION BY CONTRACTOR, et. al. INDEMNIFIES & SAVES HARMLESS THIS ENGINEER FOR ALL COST & DAMAGES INCLUDING LEGAL FEES & APPELLATE FEES RESULTING FROM MATERIAL FABRICATION, SYSTEM ERECTION, & CONSTRUCTION PRACTICES BEYOND THAT WHICH IS CALLED FOR BY LOCAL, STATE, & FEDERAL CODES & FROM DEVIATIONS OF THIS PLAN.
8. PRODUCTS SHALL BE LABELED IN ACCORDANCE WWITH THE FLORIDA BUILDIG COMMISSION AND THE FLORIDA DEPARTMENT OF BUSINESS AND PROFESSIONAL REGULATION SPECIFICATION.
9. ALTERATIONS, ADDITIONS, OR OTHER MARKINGS TO THIS DOCUMENT ARE NOT PERMITTED AND INVALIDATE THIS CERTIFICATION.
10. EXCEPT AS EXPRESSLY PROVIDED HEREIN, NO ADDITIONAL CERTIFICATIONS OR AFFIRMATIONS ARE INTENDED.

VISIT ECALC.IO/FOURSEASONS
FOR SITE SPECIFIC DEVIATIONS & MORE INFORMATION ABOUT THIS DOCUMENT OR SCAN THIS QR CODE
VISIT ENGINEERINGEXPRESS.COM/FOURSEASONS FOR ADDITIONAL PLANS, REPORTS & RESOURCES

FL# 2291.1

ENGINEERING EXPRESS®
POSTAL ADDRESS:
2234 NORTH FEDERAL HWY #7664,
BOCA RATON, FL 33431
ENGINEERINGEXPRESS.COM

FOUR SEASONS BUILDING PRODUCTS
7815 AMERICAN WAY, GROVELAND, FL 34736
(352) 787 - 7766

PRO-FAB ROOF PANELS
FLORIDA BUILDING CODE NINTH EDITION (2026)
FLORIDA STATEWIDE APPROVAL (FSA FL#2291.1)

REMARKS	DRWN	CHKD	DATE
2020 FBC (20-30696)	CCB	RWN	9/08/20
2023 FBC (23-60172)	MLD	CCB	08/03/23
2026 FBC UPDATE	NRD	RMS	08/10/26

COPYRIGHT ENGINEERING EXPRESS®

26-100275

SCALE: NTS UNLESS NOTED

1 OF 1

8/17/2026 10:44 AM COLBYBENNARDOPE w:\shared\projects\26-\26-100275 2026 product fbc update fl2291.1\work\2026 fbc\2 - drawings & cad\26-100275c - fl2291.1 - dwg.dwg