


NOTE: TYPICAL M600 FIXED WINDOW - STRAP ANCHOR INSTALLATION




Maximum				
FW	FH	DLO-W	DLO-H	Pressure
60"	60"	56 1/4"	56 1/4"	± 80 PSF

1" Insulating Glass
Two lights 1/4" Annealed Glass
with 1/2" Spacer

NOTES:

1. Installations depicted satisfy the requirements of the Florida Building Code, Building 8th; Edition (2023) for design wind pressures and overall sizes noted.
2. Wood bucks, wood framing and steel stud framing are by others and shall be designed by the architect or engineer of record to resist the loads imparted to them.
3. Wood bucks and wood framing are assumed S-P-F (G=0.55) or denser. Buck width shall be greater than the window frame width. Tapered or partial width buck strips are not allowed.
4. Metal stud frames are assumed to be a minimum 18 gauge 33 KSI steel.
5. Concrete masonry (CMU) shall conform to ASTM C90
6. Concrete shall be minimum f'c = 3,000 psi
7. Wood screws shall meet requirements of ANSI/ASME B18.6.1.
8. TEKS screws shall be ASTM A510 Grade 1018 or equivalent.
9. Hilti Kwik-Con II+ anchors as specified in NOA 21-0628.20.
10. Maximum shim thickness 1/4".
11. Products are not impact resistant and require an approved protection device if used in windborne debris regions.
12. Not for use in High Velocity Hurricane Zone (HVHZ).
13. Glazing Conforms to ASTM E1300-16 (See Engineering)



Digitally Signed by: Tanya Dolby
2024.04.05 13:41:47 -04'00'

Tanya A. Dolby, P.E.
FL P.E. No. 93536
Intertek – ATI
130 Derry Ct. York, PA 17406
(717) 764-7700
Project: Q9365.01

Project Name:

M600 FIXED

GENERAL NOTES

QUAKER WINDOW PRODUCTS
WILL NOT BE RESPONSIBLE
FOR FIELD MEASUREMENT,
QUANTITIES, & INSTALLATION
DESIGN. CONTRACTOR MUST
VERIFY ALL DIMENSIONS.

PHONE (573)-744-5211
FAX (573)-744-5586
COMMERCIAL
www.quakerwindows.com

Scale: NONE
Sheet #: 1 of 5



504 Highway 63 South
Freeburg, MO 65035
drafting@quakerwindows.com

Drawn By: BUD
Date: 02-19-2024


QUAKER
commercial windows and doors

INSTALLATION INSTRUCTIONS


NOTE: TYPICAL M600 FIXED WINDOW - NAIL FIN INSTALLATION



VERTICAL SECTION DETAIL
WOOD FRAMING INSTALLATION



HORIZONTAL SECTION DETAIL
WOOD FRAMING INSTALLATION




Digitally Signed by: Tanya Dolby
2024.04.05 13:42:09 -04'00'
Tanya A. Dolby, P.E.
FL P.E. No. 93536
Intertek – ATI
130 Derry Ct. York, PA 17406
(717) 764-7700
Project: Q9365.01


Project Name: M600 FIXED NAIL FIN		INSTALLATION INSTRUCTIONS	
Description: GENERAL NOTES		QUAKER WINDOW PRODUCTS WILL NOT BE RESPONSIBLE FOR FIELD MEASUREMENT, QUANTITIES, & INSTALLATION DESIGN. CONTRACTOR MUST VERIFY ALL DIMENSIONS.	
PHONE (573)-744-5211 FAX (573)-744-5586 COMMERCIAL FAX (573)-744-5822 www.quakerwindows.com	Scale: NONE	Sheet #: 2 of 5	
QUAKER commercial windows and doors	Drawn By: BUD	Date: 02-19-2024	504 Highway 63 South Freeburg, MO 65035 drafting@quakerwindows.com

NOTE: TYPICAL M600 FIXED WINDOW - NAIL FIN INSTALLATION


- Notes:
- 1. See detail 4 on sheet 2 for attachment of window to wood buck.
 - 2. Shimming and anchorage to shown substraights - BY OTHERS




STEEL FRAMING INSTALLATION



CONCRETE INSTALLATION



CMU INSTALLATION



Tanya A. Dolby


Digitally Signed by: Tanya Dolby

2024.04.05 13:42:37 -04'00'

Tanya A. Dolby, P.E.
FL P.E. No. 93536
Intertek – ATI
130 Derry Ct. York, PA 17406
(717) 764-7700
Project: Q9365.01


Project Name:		M600 FIXED NAIL FIN		INSTALLATION INSTRUCTIONS	
Description:		FIN INSTALLATIONS			
QUAKER WINDOW PRODUCTS WILL NOT BE RESPONSIBLE FOR FIELD MEASUREMENT, QUANTITIES, & INSTALLATION DESIGN. CONTRACTOR MUST VERIFY ALL DIMENSIONS.					
PHONE (573)-744-5211 FAX (573)-744-5586 COMMERCIAL FAX (573)-744-5822 www.quakerwindows.com		Scale:		Sheet #: 3 of 5	
504 Highway 63 South Freeburg, MO 65035 drafting@quakerwindows.com		NONE			
Drawn By: BUD		Date:		02-19-2024	

NOTE: TYPICAL M600 FIXED WINDOW - STRAP ANCHOR INSTALLATION




EXTERIOR

INTERIOR




VERTICAL SECTION DETAIL

WOOD FRAMING INSTALLATION



EXTERIOR


HORIZONTAL SECTION DETAIL
WOOD FRAMING INSTALLATION




Digitally Signed by: Tanya Dolby
2024.04.05 13:43:11 -04'00'
Tanya A. Dolby, P.E.
FL P.E. No. 93536
Intertek – ATI
130 Derry Ct. York, PA 17406
(717) 764-7700
Project: Q9365.01

Project Name:		M600 FIXED STRAP ANCHOR INSTALLATION INSTRUCTIONS	
Description:		GENERAL NOTES	
QUAKER WINDOW PRODUCTS WILL NOT BE RESPONSIBLE FOR FIELD MEASUREMENT, QUANTITIES, & INSTALLATION DESIGN. CONTRACTOR MUST VERIFY ALL DIMENSIONS.			
PHONE (573)-744-5211 FAX (573)-744-5586 COMMERCIAL FAX (573)-744-5822 www.quakerwindows.com	Scale: NONE	Sheet #: 4 of 5	
Drawn By: BUD	504 Highway 63 South Freeburg, MO 65035 drafting@quakerwindows.com	Date: 02-19-2024	


NOTE: TYPICAL M600 FIXED WINDOW - STRAP ANCHOR INSTALLATION




STEEL FRAMING INSTALLATION



CONCRETE INSTALLATION



CMU INSTALLATION



Tanya A. Dolby

Digitally Signed by: Tanya Dolby

2024.04.05 13:43:38 -04'00'

Tanya A. Dolby, P.E.
FL P.E. No. 93536
Intertek – ATI
130 Derry Ct. York, PA 17406
(717) 764-7700
Project: Q9365.01

Project Name:		M600 FIXED STRAP ANCHOR INSTALLATION INSTRUCTIONS		
Description:	FIN INSTALLATIONS		Revision #:	By:
	QUAKER WINDOW PRODUCTS WILL NOT BE RESPONSIBLE FOR FIELD MEASUREMENT, QUANTITIES, & INSTALLATION DESIGN. CONTRACTOR MUST VERIFY ALL DIMENSIONS.		Date:	
	PHONE (573)-744-5211 FAX (573)-744-5586 COMMERCIAL FAX (573)-744-5822 www.quakerwindows.com		Scale:	NONE
	504 Highway 63 South Freeburg, MO 65035 drafting@quakerwindows.com		Sheet #:	5 of 5
Drawn By:	BUD	Date:	02-19-2024	