

TYPICAL ELEVATIONS

APPROVAL APPLIES TO SINGLE LITE UNIT OR MULTIPLE LITES UNIT INSTALLATIONS

THIS SYSTEM IS RATED FOR LARGE & SMALL MISSILE IMPACT. SHUTTERS ARE NOT REQUIRED.

SERIES 'SLIMPACT X' GLASS WALL SYSTEM

THIS PRODUCT HAS BEEN DESIGNED AND TESTED TO COMPLY WITH THE REQUIREMENTS OF THE 2017 (6TH EDITION) FLORIDA BUILDING CODE INCLUDING HIGH VELOCITY HURRICANE ZONE (HVHZ).

1BY OR 2BY WOOD BUCKS & BUCK FASTENERS BY OTHERS, MUST BE DESIGNED AND INSTALLED ADEQUATELY TO TRANSFER APPLIED PRODUCT LOADS TO THE BUILDING STRUCTURE.

ANCHORS SHALL BE CORROSION RESISTANT, SPACED AS SHOWN ON DETAILS AND INSTALLED PER MANUF'S INSTRUCTIONS. SPECIFIED EMBEDMENT TO BASE MATERIAL SHALL BE BEYOND WALL DRESSING OR STUCCO.

A LOAD DURATION INCREASE IS USED IN DESIGN OF ANCHORS INTO WOOD ONLY. ALL SHIMS TO BE HIGH IMPACT, NON-METALLIC AND NON-COMPRESSIBLE.

MATERIALS INCLUDING BUT NOT LIMITED TO STEEL/METAL SCREWS, THAT COME INTO CONTACT WITH OTHER DISSIMILAR MATERIALS SHALL MEET THE REQUIREMENTS OF THE 2017 FLORIDA BLDG. CODE & ADOPTED STANDARDS.

THIS PRODUCT APPROVAL IS GENERIC AND DOES NOT PROVIDE INFORMATION FOR A SITE SPECIFIC PROJECT, i.e. LIFE SAFETY OF THIS PRODUCT, ADEQUACY OF STRUCTURE RECEIVING THIS PRODUCT AND SEALING AROUND OPENING FOR WATER INFILTRATION RESISTANCE ETC. CONDITIONS NOT SHOWN IN THIS DRAWING ARE TO BE ANALYZED SEPARATELY, AND TO BE REVIEWED BY BUILDING OFFICIAL.

MANUFACTURER'S LABEL SHALL BE LOCATED ON A READILY VISIBLE LOCATION IN ACCORDANCE WITH SECTION 1709.9.3 OF FLORIDA BUILDING CODE. LABELING TO COMPLY WITH SECTION 1709.9.2.


ANCHOR TYPE	ANCHOR SPACING INCHES		
	HEAD	SILL	JAMBS
A	4"	4"	6-3/4"
B	8	8	8
C	-	-	6-3/4
D	8	8	8

FOR SINGLE LITE UNITS:
SEE CHART ON SHEET 2.

FOR MULTIPLE LITES UNIT:
MAX. FRAME HEIGHT = 124 IN.
MAX. GLASS HEIGHT = 121-1/2 IN.
MAX. D.L.O. HEIGHT = 120-1/8 IN.
MAX. GLASS/D.L.O. WIDTH = 84 IN.

MAX. DESIGN LOAD = + 70 PSF
- 70 PSF

A- CONTRACTOR TO BE RESPONSIBLE FOR THE SELECTION, PURCHASE AND INSTALLATION OF THIS PRODUCT BASED ON THIS PRODUCT EVALUATION PROVIDED HE/SHE DOES NOT DEVIATE FROM THE CONDITIONS DETAILED ON THIS DOCUMENT.
B- THIS PRODUCT EVALUATION DOCUMENT WILL BE CONSIDERED INVALID IF ALTERED BY ANY MEANS.
C- SITE SPECIFIC PROJECTS SHALL BE PREPARED BY A FLORIDA REGISTERED ENGINEER OR ARCHITECT WHICH WILL BECOME THE ENGINEER OF RECORD (E.O.R.) FOR THE PROJECT AND WHO WILL BE RESPONSIBLE FOR THE PROPER USE OF THE P.E.D. ENGINEER OF RECORD, ACTING AS A DELEGATED ENGINEER TO THE P.E.D. ENGINEER SHALL SUBMIT TO THIS LATTER THE SITE SPECIFIC DRAWINGS FOR REVIEW.
D- THIS P.E.D. SHALL BEAR THE DATE AND ORIGINAL SEAL AND SIGNATURE OF THE PROFESSIONAL ENGINEER OF RECORD THAT PREPARED IT.



af c

AL-FAROOQ CORPORATION
ENGINEERS & PRODUCT DEVELOPMENT
9360 SUNSET DRIVE, SUITE 220
MIAMI, FLORIDA 33173 (C.A.N. 3538)
TEL. (305) 264-8100 FAX. (305) 262-6978




SERIES 'SLIMPACT X' SSG GLASS WALL SYSTEM (L.M.I.)

Faour Glass Technologies

5119 West Knox Street
Tampa, FL. 33634
Tel. (813) 884-3297 Fax. (-)

date: 11-08-17		revisions:	
drawing no. W17-104		no	by description
sheet 1 of 5	scale: 3/8"=1'-0"	A	SERIES NAME REV.
		B	CHART ADDED
chk. by:	dr. by: TARIQ		

DESIGN LOAD CAPACITY - PSF			
D.L.O. DIMS.		1-1/4" OVERALL LAM. GLASS	
WIDTH	HEIGHT	EXT.(+)	INT.(-)
42"	42"	70.0	70.0
60"		70.0	70.0
72"		70.0	70.0
84"		70.0	70.0
96"		70.0	70.0
120"		70.0	70.0
132"		70.0	70.0
168"		70.0	70.0
240"		70.0	70.0
42"	60"	70.0	70.0
60"		70.0	70.0
72"		70.0	70.0
84"		70.0	70.0
96"		70.0	70.0
120"		70.0	70.0
132"		70.0	70.0
168"		70.0	70.0
42"	72"	70.0	70.0
60"		70.0	70.0
72"		70.0	70.0
84"		70.0	70.0
96"		70.0	70.0
120"		70.0	70.0
132"		70.0	70.0
42"	84"	70.0	70.0
60"		70.0	70.0
72"		70.0	70.0
84"		70.0	70.0
96"		70.0	70.0
120"		70.0	70.0
42"	96"	70.0	70.0
60"		70.0	70.0
72"		70.0	70.0
84"		70.0	70.0
96"		61.3	61.3
42"	120"	70.0	70.0
60"		70.0	70.0
72"		70.0	70.0
84"		70.0	70.0



FL #25673


AL-FAROOQ CORPORATION
 ENGINEERS & PRODUCT DEVELOPMENT
 9360 SUNSET DRIVE, SUITE 220
 MIAMI, FLORIDA 33173 (C.A.N. 3538)
 TEL (305) 264-8100 FAX (305) 262-6978
 COMP-ANL\W17-104FGT

SERIES 'SLIMPACT X' SSG GLASS WALL SYSTEM (L.M.I.)

Faour Glass Technologies
 5119 West Knox Street
 Tampa, FL. 33634
 Tel. (813) 884-3297 Fax. (-)

revisions:		date:	11-08-17	scale:	3/8" = 1"	dr. by:	TARIQ	chk. by:	
no	date	by	description	SERIES NAME	REV.				
A	04.11.18								

drawing no.
W17-104
sheet 2 of 5



FL #25673

Sealed 12/17/18

AL-FAROOQ CORPORATION
ENGINEERS & PRODUCT DEVELOPMENT
9360 SUNSET DRIVE, SUITE 220
MIAMI, FLORIDA 33173
TEL. (305) 264-8100 FAX. (305) 262-6978
COMP-ANL\W17-104FGT

afC

SERIES 'SLIMPACT X' SSG GLASS WALL SYSTEM (L.M.I.)

Faour Glass Technologies
5119 West Knox Street
Tampa, FL. 33634
Tel. (813) 884-3297 Fax. (-)

revisions:


no	date	by	description
1	11-08-17		

date: 11-08-17
scale: 3/8" = 1"
dr. by: TARIQ
chk. by:

drawing no.
W17-104


sheet 4 of 5

FL #25673




ITEM #	PART #	REQD.	DESCRIPTION	MATERIAL	MANF./SUPPLIER/REMARKS
1	-	AS REQD.	TOP CHANNEL	6063-T4	-
2	-	AS REQD.	BOTTOM CHANNEL	6063-T4	-
3	-	2/ LITE	SETTING BLOCKS AT 1/4 POINTS	EPDM	DUROMETER 80±5 SHORE A
4	-	AS REQD.	3/8" DIA. BACKER ROD	FOAM	-
5	DOWSIL 995	AS REQD.	GLAZING COMPOUND	SILICONE	-
6	-	AS REQD.	JAMB BAR (OPTIONAL)	6063-T4	-
7	-	AS REQD.	SIDE CHANNEL	6063-T4	-

SEALANT:
ALL FRAME JOINTS SQUARE-CUT AND BUTTED,
SEALED WITH DOWSIL 123 SILICONE SEAL TAPE.



SEE SEPARATE APPROVAL FOR DESIGN LOAD
CAPACITY OF DOOR AND DOOR ANCHORS.
LOWER VALUES FROM DOOR APPROVAL
OR GLASS WALL SYSTEM CAPACITY WILL
APPLY TO ENTIRE SYSTEM.



FL #25673

AL-FAROOQ CORPORATION
ENGINEERS & PRODUCT DEVELOPMENT
9360 SUNSET DRIVE, SUITE 220
MIAMI, FLORIDA 33173 (C.A.N. 3538)
TEL. (305) 264-8100 FAX. (305) 262-6978
COMP-ANL\W17-104FGT

SERIES 'SLIMPACT X' SSG GLASS WALL SYSTEM (L.M.I.)
Faour Glass Technologies
5119 West Knox Street
Tampa, FL. 33634
Tel. (813) 884-3297 Fax. (-)

revisions:		date		by description	
no	date	no	date	no	date
1	11-08-17	1	11-08-17	1	11-08-17
2		2		2	
3		3		3	
4		4		4	
5		5		5	
6		6		6	
7		7		7	
8		8		8	
9		9		9	
10		10		10	
11		11		11	
12		12		12	
13		13		13	
14		14		14	
15		15		15	
16		16		16	
17		17		17	
18		18		18	
19		19		19	
20		20		20	
21		21		21	
22		22		22	
23		23		23	
24		24		24	
25		25		25	
26		26		26	
27		27		27	
28		28		28	
29		29		29	
30		30		30	
31		31		31	
32		32		32	
33		33		33	
34		34		34	
35		35		35	
36		36		36	
37		37		37	
38		38		38	
39		39		39	
40		40		40	
41		41		41	
42		42		42	
43		43		43	
44		44		44	
45		45		45	
46		46		46	
47		47		47	
48		48		48	
49		49		49	
50		50		50	
51		51		51	
52		52		52	
53		53		53	
54		54		54	
55		55		55	
56		56		56	
57		57		57	
58		58		58	
59		59		59	
60		60		60	
61		61		61	
62		62		62	
63		63		63	
64		64		64	
65		65		65	
66		66		66	
67		67		67	
68		68		68	
69		69		69	
70		70		70	
71		71		71	
72		72		72	
73		73		73	
74		74		74	
75		75		75	
76		76		76	
77		77		77	
78		78		78	
79		79		79	
80		80		80	
81		81		81	
82		82		82	
83		83		83	
84		84		84	
85		85		85	
86		86		86	
87		87		87	
88		88		88	
89		89		89	
90		90		90	
91		91		91	
92		92		92	
93		93		93	
94		94		94	
95		95		95	
96		96		96	
97		97		97	
98		98		98	
99		99		99	
100		100		100	

drawing no.
W17-104
sheet 5 of 5