

Evaluation Report "HC-16" Metal Wall/Soffit Assembly

Manufacturer:
Berridge Manufacturing Company

**1720 Maury Road
Houston, TX 77026
(800) 231-8127**

for

Florida Product Approval

FL 29683.2 R3

Florida Building Code 9th Edition (2026)

Method: 1 - D

Category: Structural Components

Sub - Category: Structural Wall

Product: HC-16 Wall/Soffit Panel

Material: Aluminum

Prepared by:


James L. Buckner, P.E., S.E.C.B.
Florida Professional Engineer # 31242
Florida Evaluation ANE ID: 1916
Project Manager: Diana Galloway
Report No. 26-809-HC16-A3,4S-ER
(Revises 23-542-HC16-A3,4S-ER, FL29683.2 R2)
Date: 08/17/2026

Contents:

Evaluation Report

Pages 1 – 6

This item has been digitally signed and sealed by James L. Buckner, P.E., on this date below. Printed copies of this document are not considered signed and sealed, and the signature must be verified on any electronic copies.



James L. Buckner, P.E.
FL31242

2026.08.17 15:16:33 -04'00'

Manufacturer:	Berridge Manufacturing Company 1720 Maury Road Houston, TX 77026 (800) 231-8127 www.berridge.com
Product Name:	"HC-16"
Product Category:	Structural Components
Product Sub-Category	Structural Wall
Compliance Method:	State Product Approval Rule 61G20-3.005 (1) (d)
Product/System Description:	"HC-16" Wall/Soffit Panel Corrugated Concealed Fastener Aluminum lapped Wall/Soffit panel fastened into structural Steel Supports.
Product Assembly as Evaluated:	Refer to Page 4 of this report for product assembly components/materials & standards: 1. Wall/Soffit Panel 2. Fasteners
Support:	Type: Steel Supports (Design of steel support and its attachment to support framing is outside the scope of this evaluation.) Description: Material: Steel Thickness: 16 gauge (min.) Yield Strength: 40 ksi minimum Girt/Stud Size: 2" min. flange bearing
Performance:	Wind Resistance: • Design Pressure: Refer to Table A (Refer to "Table A" attachment details herein)

Performance Standards: The following test protocol was performed to demonstrate compliance with the intent of the code:

- TAS 125-03 – *Standard Requirements for Metal Roofing Systems*

Code Compliance: The product(s) described herein have demonstrated compliance with the performance standards listed above as referenced in the Florida Building Code 9th edition (2026).

Evaluation Report Scope: This product evaluation is limited to compliance with the structural requirements of the Florida Building Code, as related to the scope section to Florida Product Approval Rule 61G20-3.001.

Limitations and Conditions of Use:

- Diaphragm and axial load capacity is outside the scope of this evaluation.
- Wall/Soffit panels shall comply with labeling requirements per FBC Section 1709.10.

Scope of "Limitations and Conditions of Use" for this evaluation:

This evaluation report for "Optional Statewide Approval" contains technical documentation, specifications and installation method(s) which include "Limitations and Conditions of Use" throughout the report in accordance with Rule 61G20-3.005. Per Rule 61G20-3.004, the Florida Building Commission is the authority to approve products under "Optional Statewide Approval".

- This report is a building code product evaluation per FLPE rule (FAC) 61G15-36 to comply with Florida product approval rule (FAC) 61G20-3. This evaluation report is part of the Florida Building Commission approval for the listed code related criteria. This report by James Buckner, P.E. and CBUCK Engineering is not a design certification of code compliance construction submittal documentation, per FBC section 107, for any individual structure, site specific or permit design.
- All metal components and fasteners shall be corrosion resistant in accordance with applicable sections of FBC. Installations located within 3000 feet of a saltwater coastline shall comply with Section 1711 in accordance with authorities having jurisdiction.
- Design of support system is outside the scope of this report. Support shall be designed by others and shall comply with the FBC Chapters 22 for steel and Chapter 16 for structural loading.
- This evaluation report does not evaluate the use of this product for use in the High Velocity Hurricane Zone code section. (Dade & Broward Counties)

Option for application outside "Limitations and Conditions of Use"

Rule 61G20-3.005(1)(e) allows engineering analysis for "project specific approval by the local authorities having jurisdiction in accordance with the alternate methods and materials authorized in the Code". Any modification of the product as evaluated in this report and approved by the Florida Building Commission is outside the scope of this evaluation and will be the responsibility of others.

Quality Assurance: The manufacturer has demonstrated compliance of Wall/Soffit panel products in accordance with the Florida Building Code and Rule 61G20-3.0005 (3) for manufacturing under a quality assurance program audited by an approved quality assurance entity through **UL, LLC** (FBC Organization #: QUA 9625).

**Components/Materials
(by Manufacturer):**

Wall/Soffit Panel:

Berridge "HC-16"
 Material: Aluminum
 Thickness: 0.032" min. or 0.040" min.
 Panel Width: 16" Coverage
 Rib Height: 7/8"
 Material Standard: ASTM B209
 Alloy Type: 3105-H14
 Corrosion Resistance: In compliance with FBC Section 1506.6 and 1507.4.4

Fastener:

FASTENER 1:

Wall/Soffit Panel to Support
 Type: Hex-Head Sheet Metal Screw with 5/8" WSW
 Size: #12 – 14 x 1-1/4"
 Corrosion Resistance: Per FBC Section 1405.17 & 1403.12
 Standard: Approved per FBC Section 1405.17

Installation:

Installation Method:

(Refer to "TABLE A" below and drawings at the end of this report.)

- # Fasteners per Attachment: **Refer to Table A Below**
 (along the support span, in the concealed fastener panel interlock)
- Minimum fastener penetration thru support, 3/4".
 (through flange of steel supports)




TABLE "A" ALLOWABLE LOADS					
	METHOD 1:	METHOD 2:	METHOD 3:	METHOD 4:	METHOD 5:
DESIGN PRESSURE (PSF)	- 62.45	- 67.7	- 33.8	- 93.7	- 57.25
# Fasteners per Attachment:	2	3	3	3	3
Panel Thickness:	0.032" min.	0.032" min.	0.032" min.	0.040" min.	0.040" min.
Max.Wall/Soffit Span	24" (2' - 0")	24" (2' - 0")	48" (4' - 0")	24" (2' - 0")	48" (4' - 0")
Span Condition:	3 or more	3 or more	3 or more	3 or more	3 or more
	NOTES: - Negative Pressure Outward - Allowable design pressure(s) for allowable stress design (ASD) with a margin of safety of 2 to 1. - No pressure equalization factors have been applied. - Fastener Attachment to Steel Supports May Be Designed By A Qualified Design Professional As Required By The Florida Building Code For Site Specific Projects.				

Install the "HC-16" Wall/Soffit panel assembly in compliance with the installation method listed in this report and applicable code sections of FBC 9th Edition (2026). The installation method described herein is in accordance with the scope of this evaluation report. Refer to manufacturer's installation instructions as a supplemental guide for attachment.


Referenced Data:

1. TAS 125-03 Uplift Test (per ASTM E 1592-01)
By Force Engineering & Testing Inc., Inc. (FBC Organization #TST ID:5328)
Report # 49-0047T-19E-I, Report Date: 4/27/19
2. Engineering Analysis
By CBUCK Engineering
3. Quality Assurance
UL, LLC (FBC Organization #: QUA 9625)
4. Certification of Independence
By James L. Buckner, P.E. @ CBUCK Engineering
(FBC Organization #ANE 1916)


Installation Method Berridge Manufacturing Company HC-16 Aluminum Wall/Soffit Panel Attached to 16 Ga. Steel Supports



Profile Views



Typical Assembly Cross Section View



Typical Assembly Concealed Fastener Panel Interlock
(Fasteners attached at 1-1/4" along the support span, in the concealed fastener panel interlock)