

Force Engineering & Testing
19530 Ramblewood Drive
Humble, Texas 77338
Office: (281) 540-6603 Test Lab: (832) 720-4251
www.forceengineeringtesting.com

Product Evaluation Report
McELROY METAL, INC.

Maxima 216 Roof Panel 24 Ga. 16" Coverage over Plywood

Florida Product Approval # 30920.4 R3

Florida Building Code 2026
Per Rule 61G20-3
Method: 1 -D

Category: Roofing
Subcategory: Metal Roofing
Compliance Method: 61G20-3.005(1)(d)
NON HVHZ

Product Manufacturer:


McElroy Metal, Inc.
1500 Hamilton Road
Bossier City, LA 71111

Engineer Evaluator:

Johnathan Green, P.E. #88223
Florida Evaluation ANE ID: 12901

Contents:

Evaluation Report: Pages 1 - 3
Details: Page 4



THIS DOCUMENT HAS
BEEN DIGITALLY SIGNED
AND SEALED BY
JOHNATHAN GREEN ON
THE DATE ADJACENT TO
THE SEAL.

PRINTED COPIES OF THIS
DOCUMENT ARE NOT
CONSIDERED SIGNED
AND SEALED AND THE
SIGNATURE MUST BE
VERIFIED ON ANY
ELECTRONIC COPIES.



Compliance Statement:	The product as described in this report has demonstrated compliance with the Florida Building Code 2026, Sections 1504.3.2.
Product Description:	Maxima 216 24 Ga. Steel, 16" Coverage, standing seam roof panel over APA Rated Plywood decking. Non-Structural Application.
Panel Material/Standards:	Material: 24 Ga. Steel, conforming to Florida Building Code 2026 Section 1507.4.3. Yield Strength: Min. 50.0 ksi Corrosion Resistance: Panel Material shall comply with Florida Building Code 2026, Section 1507.4.3.
Panel Dimension(s):	Thickness: 0.024" min. Coverage: 16" nominal coverage Rib: 2" tall standing seam rib Panel Seam: Mechanically seamed 90-degree seam
Panel Clips:	Product Name: MC 120310 Low Floating Clip Description: 22 Ga. Steel top, 16 Ga. steel base Corrosion Resistance: Per Florida Building Code 2026 Section 1506.7 and Section 1711 for installations within 3000 ft. of a saltwater coastline.
Panel Clip Fastener:	(2) #14-10 x 1 1/2" HWH Type A per clip 1/4" minimum penetration through plywood Corrosion Resistance: Per Florida Building Code 2026 Section 1506.6, 1507.4.4 and Section 1711 for installations within 3000 ft. of a saltwater coastline.
Substrate Description:	Min. 15/32" thick, APA Rated plywood over supports at maximum 24" O.C. Design of plywood and plywood supports are outside the scope of this evaluation. Substrate must be designed in accordance w/ Florida Building Code 2026. Min. 19/32" thick, APA Rated plywood over supports at maximum 24" O.C. Design of plywood and plywood supports are outside the scope of this evaluation. Substrate must be designed in accordance w/ Florida Building Code 2026.


Allowable Design Uplift Pressures:

Table A				
Maximum Allowable Design Uplift Pressure:	56.0 psf	116.0 psf	63.5 psf	116.0 psf
Substrate Thickness:	15/32" Plywood	15/32" Plywood	19/32" Plywood	19/32" Plywood
Panel Clip Spacing:	4'-0" O.C.	1'-0" O.C.	4'-0" O.C.	1'-0" O.C.


*Design Pressure includes a Safety Factor = 2.0.




Code Compliance:	The product described herein has demonstrated compliance with The Florida Building Code 2026, Section 1504.3.2.
Evaluation Report Scope:	The product evaluation is limited to compliance with the structural wind load requirements of the Florida Building Code 2026, as relates to Rule 61G20-3.
Performance Standards:	The product described herein has demonstrated compliance with: ▪ UL 580-06 - Test for Uplift Resistance of Roof Assemblies ▪ UL 1897-2015 - Uplift Test for Roof Covering Systems
Reference Data:	1. UL 580-06 / 1897-2012 Uplift Test Force Engineering & Testing, Inc. (FBC Organization # TST-5328) Report No. 90-0158T-19 2. Certificate of Independence By Johnathan Green, P.E. (No. 88223) @ Force Engineering & Testing (FBC Organization # ANE ID: 12901)
Test Standard Equivalency:	The UL 1897-12 test standard is equivalent to the UL 1897-2015 test standard.
Quality Assurance Entity:	The manufacturer has established compliance of roof panel products in accordance with the Florida Building Code and Rule 61G20-3.005 (3) for manufacturing under a quality assurance program audited by an approved quality assurance entity.
Minimum Slope Range:	Minimum Slope shall comply with Florida Building Code 2026, including Section 1507.4.2 and in accordance with Manufacturers recommendations. For slopes less than 3:12, lap sealant must be used in the panel side laps.
Installation:	Install per manufacturer's recommended details.
Limitation:	Metal hip and ridge covers are outside the scope of this evaluation report and must be in compliance with FBC 2026 Section 1504.3.1.1 through other product approval.
Underlayment:	Min. 40 mil thick peel and stick self adhered underlayment, Grace Ice and Water Shield HT or equivalent conforming to Florida Building Code, Section 1507.1.1 and manufacturer's installation guidelines.
Roof Panel Fire Classification:	Fire classification is not part of this acceptance.
Shear Diaphragm:	Shear diaphragm values are outside the scope of this report.
Design Procedure:	Based on the dimensions of the structure, appropriate wind loads are determined using Chapter 16 of the Florida Building Code 2026 for roof cladding wind loads. These component wind loads for roof cladding are compared to the allowable pressure listed above. The design professional shall select the appropriate erection details to reference in his drawings for proper fastener attachment to his structure and analyze the panel fasteners for pullout and pullover. Support framing must be in compliance with Florida Building Code 2026 Chapter 22 for steel, Chapter 23 for wood and Chapter 16 for structural loading.



Force Engineering & Testing
19530 Ramblewood Drive
Humble, Texas 77338
Office: (281) 540-6603 Test Lab: (832) 720-4251
www.forceengineeringtesting.com




STRIATED PROFILE
(Standard)



BEAD (PENCIL RIB) PROFILE
(Option)

***NOTE:**
12" wide panel has a single Pencil Rib



FLAT PAN PROFILE
(Option)

