


MULLED UNIT 1" LVL STRUCTURAL BRACKET INSTALLATION



STRUCTURAL BRACKET INSTALLATION METHOD:

- UNIT MUST NOT BE IN DIRECT CONTACT WITH EITHER CONCRETE OR TREATED BUCK MATERIAL. IF SHIM SPACE IS LESS THAN 1/8" WRAPPING THE UNIT ON ALL 4 SIDES WITH WINDOW FLASHING TAPE IS REQUIRED AS A BARRIER BETWEEN THE UNIT AND CONCRETE OR TREATED LUMBER.
- SCREWS MUST HAVE FULL EMBEDMENT.

CATEGORY:
DOUBLE HUNG

UNIT TYPE:
UWDHIZ3, UWDHPIZ3, UWDHTRIZ3

- NOTES:**
- THIS PRINT IS FOR STRUCTURAL PERFORMANCE ONLY. FOR FLASHING & SEALING REQUIREMENTS, REFER TO THE INSTALLATION INSTRUCTIONS.
 - SHIMS:
 - A SHIM MUST BE PLACED 4-6" FROM EACH CORNER.
 - ALL OTHERS MUST BE PLACED A MAX OF 15 INCHES APART.
 - IF CHEMICALLY TREATED LUMBER IS USED FOR BUCK MATERIAL, FASTENERS INTO THE BUCK MUST BE A MINIMUM OF 0.90 OZ/FT² ZINC HOT DIPPED GALVANIZED OR STAINLESS STEEL TYPE 304 OR 316.

PRODUCTS
UL WD DBLHNG IZ3
UL WD DBLHNG P IZ3
UL WD DBLHNG TR IZ3


MULL ORIENTATION	SPAN	TRIB	DP RATING
VERTICAL	77"	37 3/8"	+55/-65

ITEM NO	REF NO	DESCRIPTION
6	-----	1" LVL
5	-----	SHIM
4	-----	BUCK BY OTHER
3	-----	#8 X 5/8" SCREW
2	-----	STRUCTURAL BRACKET
1	-----	#8 X 1 1/2" SCREW

UNSPECIFIED TOLERANCES

DECIMALS: XX ± .03 XXX ± .012	ANGLE DEG: ± .5
LINEAL: + .125 - .000	FAB LINEAL: ± NA

MATERIAL:
NA



MARVIN



RESEARCH & DEVELOPMENT

COLLECTION: ULTIMATE				
DWG TYPE: INSTALLATION				
DESCRIPTION: INSTALLATION				
CHK:	SIZE: B	CLASS: MISC	DWG NO: 00126939	
APP:	SCALE: NA	DATE: 05/28/15	DWG BY: BORNEMAN, SKIP	SHEET: 1 OF 1

NOTICE - CONFIDENTIAL INFORMATION

The information in this document is privileged and strictly confidential. The information contained herein shall be used only by Marvin Windows and Doors employees and by those agents or suppliers granted official written permission. If the reader of this document is not the intended recipient, or the employee or agent of the intended recipient, please delete this document from all data storage devices, and destroy all hard copies. Any unauthorized dissemination, distribution, copying or other use of the information contained in this document is strictly prohibited.