


- NOTES:
1. STANDARD GLAZING OPTION – .125" MINIMUM DSB GLAZING MEETS UNIFORM STATIC DESIGN PRESSURES SHOWN ON THIS DRAWING. GLAZING SHALL HAVE A MAXIMUM HEIGHT OF 6.70" AND A MAXIMUM LENGTH OF 24.00". GLAZING IS NOT IMPACT RESISTANT AND DOES NOT MEET THE REQUIREMENTS FOR WIND-BORNE DEBRIS REGIONS.
 2. ALUMINUM FULL VIEW OPTION – ALUMINUM FULL VIEW SECTION MAY REPLACE ANY SECTION EXCEPT TOP AND BOTTOM PANELS. ALUMINUM FULL VIEW SECTION SHALL HAVE RAILS AND STILES OF EXTRUDED ALUMINUM ALLOY 6063-T6 WITH A 2-1/4" INTEGRAL FIN AND .125" MINIMUM DSB GLAZING INSTALLED WITH ALUMINUM RETAINERS IN ORDER TO MEET UNIFORM STATIC DESIGN PRESSURES SHOWN ON THIS DRAWING. GLAZING IS NOT IMPACT RESISTANT AND DOES NOT MEET THE REQUIREMENTS FOR WIND-BORNE DEBRIS REGIONS.
 3. MINIMUM OF 1" OVERLAP ON BOTH JAMBS REQUIRED TO MEET NEGATIVE DESIGN PRESSURES.
 4. SLIDE LOCK OR OPERATOR REQUIRED.
 5. SECTION STEEL TO HAVE THE FOLLOWING MINIMUM THICKNESS:
C20 – 20 GA
C24 – 24 GA
C2400 – 25 GA
 6. THE DESIGN OF THE SUPPORTING STRUCTURAL ELEMENTS SHALL BE THE RESPONSIBILITY OF THE PROFESSIONAL OF RECORD FOR THE BUILDING OR STRUCTURE AND IN ACCORDANCE WITH CURRENT BUILDING CODES FOR THE LOADS LISTED ON THIS DRAWING.
 7. TRACK CLIPS SHALL BE LOCATED WITH CENTERLINE OF BOTTOM CLIP SPACED 10" MAX FROM BOTTOM OF TRACK AND REMAINING TRACK CLIPS SPACED AT 24" O.C. MAX. SPACING BETWEEN TOP TRACK CLIP AND SPLICE PLATE SHALL BE 30" O.C. MAX.
 8. WHEN MOUNTING TO WOOD, DOOR JAMB TO BE MINIMUM 2x6 STRUCTURAL GRADE LUMBER. REFER TO JAMB CONNECTION SUPPLEMENT FOR ATTACHMENT TO SUPPORTING STRUCTURE.

- 13 GA HORIZ ANGLE
- 15 GA MIN HORIZ TRACK
- 13 GA CONTINUOUS WALL ANGLE
- 15 GA MIN VERT TRACK
- 5/16"x1-5/8" LAG SCREW AT EACH HOLE LOCATION FOR WOOD SUBSTRATE. SEE SHEET 3 FOR MOUNTING TO OTHER SUBSTRATES.
- 1/4-20x9/16" TRACK BOLTS AND 1/4-20 HEX NUT AT EACH TRACK CLIP LOCATION (SEE DETAIL A SHEET 3)
- 11 GA TRACK CLIPS (WELDED, BOLTED, OR RIVETED TO WALL ANGLE) SEE NOTE 7 AND DETAIL F SHEET 3
- SLIDE LOCK ONE END (NOT REQUIRED WITH OPERATOR – SEE NOTE 4)

NOTE: (4) SECTION SOLID DOOR SHOWN. SEE SHEET 2 FOR U-BAR LOCATIONS ON DOORS WITH OTHER SECTION QUANTITIES AND SEE NOTES 1 & 2 THIS SHEET FOR GLAZING OPTIONS.


SUPERIMPOSED DESIGN PRESSURE LOADS ON SUPPORTING STRUCTURE		
MAX DOOR WIDTH	DOOR HEIGHT	MAX UNIFORM LOAD EACH JAMB (PLF)
12'-2"	ALL	+127.1/-143.6



J. CHRISTIAN VOELKEL, PE
312 N. NEW WARRINGTON ROAD, UNIT 1A
PENSACOLA, FL
FL PE 82229
TX PE 133174

PROFESSIONAL ENGINEER'S SEAL PROVIDED ONLY FOR VERIFICATION OF WINDLOAD CONSTRUCTION DETAILS.

Digitally signed by
John Christian
Voelkel
Date: 2021.02.11
22:30:51 -06'00'




REVISIONS	
REV	INITIAL DRAWING TLC 11/12/20

THE DOORS ARE DESIGNED AND MANUFACTURED TO COMPLY WITH THE 2018 IRC AND THE 2018 IBC.


 Wayne Dalton GARAGE DOORS A DIVISION OF OVERHEAD DOOR CORP 3395 ADDISON DRIVE PENSACOLA, FLORIDA 32514 (850) 474-9890	STATIC PRESSURE RATINGS		APPROVED SIZES		SCALE: N.T.S.		SIZE: A		
	DESIGN (PSF): +20.90/-23.60		MAX WIDTH: 12'-2"			DATE		NAME	
	TEST (PSF): +31.35/-35.40		MAX HEIGHT: 24'-1"		DRAWN	11/12/20		TLC	
	IMPACT/CYCLIC RATED (YES/NO): NO		MAX SECTION HEIGHT: 24"		CHECKED	1/6/2021		JQ	
	MODELS C20/C24/C2400					SHEET 1 OF 3			
	WINDLOAD SPECIFICATION OPTION CODE 2024					DRAWING PART NO. 365573		REV. —	

1/4-20x9/16" TRACK BOLT
AND 1/4-20 HEX NUT
THROUGH THE SLOT IN THE
TRACK AND TRACK CLIP



DETAIL A


12 GA COMMERCIAL 'A' FRAME
BRACKET ASSEMBLY WITH 13 GA
ROLLER CARRIER ATTACHED
WITH (4) 1/4-14x7/8" SELF
DRILLING CRIMPTITE SCREWS



DETAIL B


ADD (2) 1/4-14x7/8" SELF
DRILLING CRIMPTITE SCREWS
(INSIDE OF EACH INSIDE END HINGE)

2" STEEL ROLLER WITH
5-1/8" STEM AND 7/16" PUSHNUT AT EACH ROLLER
LOCATION. 1/4" MAX
BETWEEN PUSHNUT AND
BRACKET OR HINGE




DETAIL C

13 GA WIDE BODY END
HINGES EACH ATTACHED
WITH (4) 1/4-14x7/8" SELF
DRILLING CRIMPTITE SCREWS




SOLID SECTION

14 GA WIDE BODY
INTERMEDIATE HINGE
ATTACHED WITH (4)
1/4-14x7/8" SELF
DRILLING CRIMPTITE
SCREWS



DETAIL E

12 GA BOTTOM BRACKET
ATTACHED WITH (3)
1/4-14x7/8" SELF DRILLING
CRIMPTITE SCREWS (2 THROUGH
STRUT AND BRACKET)




AFV SECTION

(2) 1/4-14x7/8" SELF DRILLING
CRIMPTITE SCREWS
HALF HINGE
(2) 1/4 x 1/2"
CARRIAGE BOLTS AND
1/4" FLANGE NUTS

DETAIL D

ATTACH U-BARS WITH
(2) 1/4-14x7/8" SELF
DRILLING CRIMPTITE SCREWS
AT ALL STILE LOCATIONS, TYP.



(4) SECTION DOORS WITH
(4) 3" 20 GA 80 KSI U-BARS
LOCATED AS SHOWN

(6) SECTION DOORS WITH
(6) 3" 20 GA 80 KSI U-BARS
LOCATED AS SHOWN

(7) SECTION DOORS WITH
(7) 3" 20 GA 80 KSI U-BARS
LOCATED AS SHOWN


(8) SECTION DOORS WITH
(8) 3" 20 GA 80 KSI U-BARS
LOCATED AS SHOWN

(9) SECTION DOORS WITH
(9) 3" 20 GA 80 KSI U-BARS
LOCATED AS SHOWN

(10) SECTION DOORS WITH
(10) 3" 20 GA 80 KSI U-BARS
LOCATED AS SHOWN

(11) SECTION DOORS WITH
(11) 3" 20 GA 80 KSI U-BARS
LOCATED AS SHOWN

(12) SECTION DOORS WITH
(12) 3" 20 GA 80 KSI U-BARS
LOCATED AS SHOWN




J. CHRISTIAN VOELKEL, PE
312 N. NEW WARRINGTON ROAD, UNIT 1A
PENSACOLA, FL
FL PE 82229
TX PE 133174

PROFESSIONAL ENGINEER'S SEAL PROVIDED ONLY FOR
VERIFICATION OF WINDLOAD CONSTRUCTION DETAILS.






A DIVISION OF OVERHEAD DOOR CORP
3395 ADDISON DRIVE
PENSACOLA, FLORIDA 32514
(850) 474-9890





STATIC PRESSURE RATINGS		APPROVED SIZES		SCALE: N.T.S.		SIZE: A	
DESIGN (PSF):	+20.90/−23.60	MAX WIDTH:	12′−2″		DATE	NAME	
TEST (PSF):	+31.35/−35.40	MAX HEIGHT:	24′−1″	DRAWN	11/20/20	TLC	
IMPACT/CYCLIC RATED (YES/NO): NO		MAX SECTION HEIGHT: 24″		CHECKED	1/6/2021	JQ	
MODELS C20/C24/C2400				SHEET 2 OF 3			
WINDLOAD SPECIFICATION OPTION CODE 2024				DRAWING PART NO.		REV.	
				365573		—	



ALUMINUM FULL VIEW FRAME



EXTERIOR FRAME



PROFESSIONAL ENGINEER'S SEAL PROVIDED ONLY FOR VERIFICATION OF WINDLOAD CONSTRUCTION DETAILS.

Wayne Dalton GARAGE DOORS A DIVISION OF OVERHEAD DOOR CORP 3395 ADDISON DRIVE PENSACOLA, FLORIDA 32514 (850) 474-9890	STATIC PRESSURE RATINGS		APPROVED SIZES		SCALE: N.T.S.		SIZE: A		
	DESIGN (PSF): +20.90/-23.60		MAX WIDTH: 12'-2"		DATE		NAME		
	TEST (PSF): +31.35/-35.40		MAX HEIGHT: 24'-1"		DRAWN		TLC		
	IMPACT/CYCLIC RATED (YES/NO): NO		MAX SECTION HEIGHT: 24"		CHECKED		JQ		
	MODELS C20/C24/C2400					SHEET 3 OF 3			
	WINDLOAD SPECIFICATION OPTION CODE 2024					DRAWING PART NO.		REV.	
					365573		—		