

OPTIMUM STEEL WINDOWS AND DOORS

RTS-430i STAINLESS STEEL FRENCH CASEMENT WINDOW (WZ3)(IMPACT)

INSTALLATION NOTES:

- ONE (1) INSTALLATION ANCHOR FOR EACH ANCHOR LOCATION SHOWN.
- THE NUMBER OF INSTALLATION ANCHORS DEPICTED IS THE MINIMUM NUMBER OF ANCHORS TO BE USED FOR PRODUCT INSTALLATION.
- INSTALL INDIVIDUAL INSTALLATION ANCHORS WITHIN A TOLERANCE OF ±1/2 INCH OF THE DEPICTED LOCATION IN THE ANCHOR LAYOUT DETAIL (I.E., WITHOUT CONSIDERATION OF TOLERANCES). TOLERANCES ARE NOT CUMULATIVE FROM ONE INSTALLATION ANCHOR TO THE NEXT.
- SHIM AS REQUIRED AT EACH INSTALLATION ANCHOR WITH LOAD BEARING SHIM(S). MAXIMUM ALLOWABLE SHIM STACK TO BE 1/4 INCH. SHIM WHERE SPACE OF 1/16 INCH OR GREATER OCCURS. SHIM(S) SHALL BE CONSTRUCTED OF HIGH DENSITY PLASTIC OR BETTER.
- FOR INSTALLATION DIRECTLY INTO CONCRETE/MASONRY, USE 1/4 INCH DIAMETER ITW TAPCON OF SUFFICIENT LENGTH TO ACHIEVE 1 1/4 INCH MINIMUM EMBEDMENT, AND 2-1/2 INCHES EDGE DISTANCE.
- FOR INSTALLATION DIRECTLY INTO WOOD FRAME, USE #14 WOOD SCREWS OF SUFFICIENT LENGTH TO ACHIEVE 1 1/2 INCH MINIMUM EMBEDMENT, AND 3/4 INCH EDGE DISTANCE.
- FOR INSTALLATION INTO STEEL STUD OR ALUMINUM USE 1/4" SELF-DRILLING OR SELF-TAPPING PH OR HWH SCREWS OF SUFFICIENT LENGTH TO ACHIEVE A MINIMUM OF 3 THREADS PENETRATION BEYOND METAL WALL, AND 3/4 INCH EDGE DISTANCE.
- MINIMUM EMBEDMENT AND EDGE DISTANCE EXCLUDE WALL FINISHES, INCLUDING BUT NOT LIMITED TO STUCCO, FOAM, BRICK VENEER, AND SIDING.
- INSTALLATION ANCHORS AND ASSOCIATED HARDWARE MUST BE MADE OF CORROSION RESISTANT MATERIAL OR HAVE A CORROSION RESISTANT COATING.
- FOR HOLLOW BLOCK AND GROUT FILLED BLOCK, DO NOT INSTALL INSTALLATION ANCHORS INTO MORTAR JOINTS. EDGE DISTANCE IS MEASURED FROM FREE EDGE OF BLOCK OR EDGE OF MORTAR JOINT INTO FACE SHELL OF BLOCK.
- INSTALLATION ANCHORS SHALL BE INSTALLED IN ACCORDANCE WITH ANCHOR MANUFACTURER'S INSTALLATION INSTRUCTIONS, AND ANCHORS SHALL NOT BE USED IN SUBSTRATES WITH STRENGTHS LESS THAN THE MINIMUM STRENGTH SPECIFIED BY THE ANCHOR MANUFACTURER.
- INSTALLATION ANCHOR CAPACITIES FOR PRODUCTS HEREIN ARE BASED ON SUBSTRATE MATERIALS WITH THE FOLLOWING PROPERTIES:
 - WOOD - MINIMUM SPECIFIC GRAVITY OF 0.55.
 - CONCRETE -MINIMUM COMPRESSIVE STRENGTH OF 3000 PSI.
 - GROUT-FILLED CMU- UNIT STRENGTH CONFORMS TO ASTM C-90 WITH MINIMUM COMPRESSIVE STRENGTH OF 2000 PSI AND GROUT CONFORMS TO ASTM C 476, MINIMUM GROUT COMPRESSIVE STRENGTH OF 2000 PSI.
 - STEEL - MINIMUM YIELD STRENGTH OF 33 KSI. MINIMUM WALL THICKNESS OF 35.9 MIL (0.0478" OR 18 GAUGE).
 - ALUMINUM - MINIMUM GRADE OF 6063-T6. 1/8" MINIMUM WALL THICKNESS.

GENERAL NOTES:

- THE PRODUCT SHOWN HEREIN IS DESIGNED AND MANUFACTURED TO COMPLY WITH THE CURRENT FLORIDA BUILDING CODE (FBC), **EXCLUDING** HVHZ AND HAS BEEN EVALUATED ACCORDING TO THE FOLLOWING:
 - ASTM E283-19
 - ASTM E330-14(21)
 - ASTM E331-00(16)
 - TAS 201-94
 - TAS 202-94
 - TAS 203-94
- ADEQUACY OF THE EXISTING STRUCTURAL CONCRETE/MASONRY, STEEL, AND 2X FRAMING AS A MAIN WIND FORCE RESISTING SYSTEM CAPABLE OF WITHSTANDING AND TRANSFERRING APPLIED PRODUCT LOADS TO THE FOUNDATION IS THE RESPONSIBILITY OF THE ENGINEER OR ARCHITECT OF RECORD FOR THE PROJECT OF INSTALLATION.
- 1X AND 2X BUCKS (WHEN USED) SHALL BE DESIGNED AND ANCHORED TO PROPERLY TRANSFER ALL LOADS TO THE STRUCTURE. BUCK DESIGN AND INSTALLATION IS THE RESPONSIBILITY OF THE ENGINEER OR ARCHITECT OF RECORD FOR THE PROJECT OF INSTALLATION.
- THE INSTALLATION DETAILS DESCRIBED HEREIN ARE GENERIC AND MAY NOT REFLECT ACTUAL CONDITIONS FOR A SPECIFIC SITE. IF SITE CONDITIONS CAUSE INSTALLATION TO DEVIATE FROM THE REQUIREMENTS DETAILED HEREIN, A LICENSED ENGINEER OR ARCHITECT SHALL PREPARE SITE SPECIFIC DOCUMENTS FOR USE WITH THIS DOCUMENT IN NON-HVHZ AREAS. IN HVHZ AREAS, ONE TIME PRODUCT APPROVAL TO BE OBTAINED FROM MIAMI-DADE RER.
- APPROVED IMPACT PROTECTIVE SYSTEM **IS NOT REQUIRED** ON THIS PRODUCT IN AREAS REQUIRING IMPACT RESISTANCE IN WIND ZONE 3 OR LESS.
- APPROVED IMPACT PROTECTIVE SYSTEM **IS REQUIRED** ON THIS PRODUCT IN AREAS REQUIRING IMPACT RESISTANCE IN WIND ZONE 4.
- WINDOW FRAME MATERIAL: 304 STAINLESS STEEL
- DISSIMILAR METALS INCLUDING FASTENERS THAT MAY COME INTO CONTACT WITH ALUMINUM UNIT FRAMING SHALL BE PROTECTED IN ACCORDANCE WITH THE FBC.
- GLASS MEETS THE REQUIREMENTS OF ASTM E 1300 GLASS CHARTS. SEE SHEET 2 FOR GLAZING DETAILS.

NOTE:

INTERIOR AND EXTERIOR GLAZED OPTIONS QUALIFIED FOR ALL CONFIGURATIONS SHOWN ON THIS APPROVAL.

TABLE OF CONTENTS	
SHEET	SHEET DESCRIPTION
1	GENERAL NOTES AND INSTALLATION NOTES
2	GLAZING DETAILS
3	DESIGN PRESSURE TABLES
4	ELEVATIONS
5	ANCHOR LAYOUTS
6	VERTICAL SECTIONS - 2X WOOD BUCK
7	VERTICAL SECTIONS - CONCRETE/MASONRY
8	VERTICAL SECTIONS - METAL STUD
9	HORIZONTAL SECTIONS - 2X WOOD & CENTER STILES
10	HORIZONTAL SECTIONS - CONCRETE/MASONRY
11	HORIZONTAL SECTIONS - METAL STUD
12	VERTICAL SECTIONS
13	HORIZONTAL SECTIONS

DESIGN PRESSURE RATING				
FRAME SIZE	CONFIGURATION	MAX. D.L.O. SIZE	DESIGN PRESSURE	MISSILE IMPACT RATING
36" X 96"	"X"	31 ¹¹ / ₁₆ " X 90 ⁷ / ₁₆ "	+/- 65 PSF	LARGE & SMALL MISSILE IMPACT
72" X 96"	"X - X"			

NOTES:

- DESIGN PRESSURES ARE LIMITED TO THE LESSER OF COMPARATIVE ANALYSIS PER FBC SECTION 1709.5.1 AND GLASS CAPACITIES PER ASTM E1300 (3 SEC. GUST).
- SQUARE FOOTAGE AREA HAS BEEN LIMITED TO EQUAL OR LESS THAN THE TESTED AREA FOR SINGLE AND MULLED CONFIGURATIONS.
- ALLOWABLE DESIGN PRESSURE WILL BE LESSER OF DESIGN PRESSURE TABLES ON SHEET 3.
- SEE SHEET 4 FOR ALLOWABLE SHAPE CONFIGURATIONS.



OPTIMUM STEEL WINDOWS AND DOORS
28 CANAL STREET
ELLENVILLE, NY 12428
PH: (845) 647-1900 FX: (845) 647-1494

TITLE: RTS-430i STAINLESS STEEL
FRENCH CASEMENT WINDOW
(WZ3)(IMPACT)
GENERAL NOTES AND
INSTALLATION NOTES


PREPARED BY:
BUILDING DROPS, INC.
1900 NE MIAMI CT, SUITE 2-15
MIAMI, FL 33132
PH: (954) 399-8478
FAX: (954) 744-4738
WEB: www.buildingdrops.com



REMARKS	BY	DATE
MISC. REVISION	MS	01/26

THE INSTALLATION DETAILS DESCRIBED HEREIN ARE GENERIC AND MAY NOT REFLECT ACTUAL CONDITIONS FOR A SPECIFIC SITE. IF SITE CONDITIONS CAUSE INSTALLATION TO DEVIATE FROM THE REQUIREMENTS DETAILED HEREIN, A LICENSED ENGINEER OR ARCHITECT SHALL PREPARE SITE SPECIFIC DOCUMENTS FOR USE WITH THIS DOCUMENT.

Digitally signed by Hermes F. Norero, P.E.
Reason: I am approving this document
Date: 2026.02.12 13:47:50 -0500



FL38442

DATE: 02.12.25

DWG. BY:
DB

CHK. BY:
HFN

SCALE: NTS

DWG. #: OPW018

SHEET: OF 13

1



OPTIMUM STEEL WINDOWS AND DOORS
28 CANAL STREET
ELLENVILLE, NY 12428
PH: (845) 647-1900 FX: (845) 647-1494

TITLE: RTS-430I STAINLESS STEEL
FRENCH CASEMENT WINDOW
(WZ3)(IMPACT)

GLAZING DETAILS

PREPARED BY:

BUILDING DROPS, INC.

1900 NE MIAMI CT, SUITE 2-15

MIAMI, FL 33132

PH: (954) 399-8478

FAX: (954) 744-4738

WEB: www.buildingdrops.com



REMARKS	BY	DATE
MISC. REVISION	MS	01/26

THE INSTALLATION DETAILS DESCRIBED HEREIN ARE GENERIC AND MAY NOT REFLECT ACTUAL CONDITIONS FOR A SPECIFIC SITE. IF SITE CONDITIONS CAUSE INSTALLATION TO DEVIATE FROM THE REQUIREMENTS DETAILED HEREIN, A LICENSED ENGINEER OR ARCHITECT SHALL PREPARE SITE SPECIFIC DOCUMENTS FOR USE WITH THIS DOCUMENT.




FL38442

DATE:	02.12.25
DWG. BY:	DB
CHK. BY:	HFN
SCALE:	NTS
DWG. #:	OPW018
SHEET:	OF 13


2

1 1/2" O.A. IG CONSISTING OF:
1/4" TEMPERED
13/16" ALUMINUM SPACER
3/16" CLEAR HS
0.090" SENTRYGLAS INTERLAYER
BY KURARAY AMERICA
3/16" CLEAR HS




GLAZING DETAIL 1

1 1/2" O.A. IG CONSISTING OF:
3/16" CLEAR HS
0.090" SENTRYGLAS INTERLAYER
BY KURARAY AMERICA
3/16" CLEAR HS
13/16" ALUMINUM SPACER
1/4" TEMPERED




GLAZING DETAIL 2

1 5/16" O.A. IG CONSISTING OF:
1/4" TEMPERED
9/16" ALUMINUM SPACER
3/16" CLEAR HS
0.090" SENTRYGLAS INTERLAYER
BY KURARAY AMERICA
3/16" CLEAR HS




GLAZING DETAIL 3

7/16" O.A. LAMINATED GLASS
CONSISTING OF:
3/16" HEAT STRENGTHENED GLASS
0.090" SENTRYGLAS INTERLAYER
BY KURARAY AMERICA
3/16" HEAT STRENGTHENED GLASS




GLAZING DETAIL 4

7/16" O.A. LAMINATED GLASS
CONSISTING OF:
3/16" HEAT STRENGTHENED GLASS
0.090" SENTRYGLAS INTERLAYER
BY KURARAY AMERICA
3/16" HEAT STRENGTHENED GLASS




GLAZING DETAIL 5

7/16" O.A. LAMINATED GLASS
CONSISTING OF:
3/16" HEAT STRENGTHENED GLASS
0.090" SENTRYGLAS INTERLAYER
BY KURARAY AMERICA
3/16" HEAT STRENGTHENED GLASS




GLAZING DETAIL 6

1 1/2" O.A. IG CONSISTING OF:
3/16" CLEAR HS
0.090" SENTRYGLAS INTERLAYER
BY KURARAY AMERICA
3/16" CLEAR HS
13/16" ALUMINUM SPACER
1/4" TEMPERED




GLAZING DETAIL 7

1 1/2" O.A. IG CONSISTING OF:
1/4" TEMPERED
13/16" ALUMINUM SPACER
3/16" CLEAR HS
0.090" SENTRYGLAS INTERLAYER
BY KURARAY AMERICA
3/16" CLEAR HS




GLAZING DETAIL 8

SIMULATED MUNTIN:




OTHER QUALIFIED GLAZING BEADS:

INSULATED GLAZING BEAD OPTIONS



MONOLITHIC GLAZING BEAD OPTIONS



NOTES:

- GLASS TYPE AND THICKNESS COMPLIES WITH ASTM E1300 REQUIREMENTS AS WELL AS APPLICABLE SAFETY GLAZING REQUIREMENTS PER THE FBC. THICKNESS, TEMPER, AND SAFETY GLAZING REQUIREMENTS SHALL BE REVIEWED ON A SITE SPECIFIC BASIS.
- SETTING BLOCK DUROMETER HARDNESS OF 70-90 (SHORE A) AS REFERENCED IN FBC CHAPTER 24.
- SETTING BLOCKS TO BE LOCATED AT 1/4 SPAN LENGTH FOR GLASS WIDER THAN 36" AS PER FBC CHAPTER 24.
- D.L.O. AND DESIGN PRESSURES ARE LIMITED TO THE MAX VALUES SHOWN HEREIN.

GLASS LOAD CAPACITY (PSF)			
NOMINAL DIMS.		GLASS TYPES '1, 2, 3, 4, 5, 6'	
D.L.O. WIDTH 'in.'	D.L.O. HEIGHT 'in.'	EXT. (+)	INT. (-)
13.69	30.44	65.0	65.0
19.69		65.0	65.0
25.69		65.0	65.0
31.69		65.0	65.0
13.69		65.0	65.0
19.69	36.44	65.0	65.0
25.69		65.0	65.0
31.69		65.0	65.0
37.69		56.5	56.5
13.69		65.0	65.0
19.69	42.44	65.0	65.0
25.69		65.0	65.0
31.69		65.0	65.0
37.69		54.7	54.7
43.69		48.5	48.5
13.69	48.44	65.0	65.0
19.69		65.0	65.0
25.69		65.0	65.0
31.69		65.0	65.0
37.69		54.7	54.7
43.69	54.44	47.1	47.1
49.69		42.5	42.5
13.69		65.0	65.0
19.69		65.0	65.0
25.69		65.0	65.0
13.69	60.44	65.0	65.0
19.69		65.0	65.0
25.69		65.0	65.0
31.69		65.0	65.0
37.69		54.7	54.7
43.69	66.44	47.1	47.1
13.69		65.0	65.0
19.69		65.0	65.0
25.69		65.0	65.0
31.69		65.0	65.0
13.69	72.44	54.7	54.7
19.69		65.0	65.0
25.69		65.0	65.0
31.69		65.0	65.0
37.69		54.7	54.7
13.69	78.44	65.0	65.0
19.69		65.0	65.0
25.69		65.0	65.0
31.69		65.0	65.0
37.69		65.0	65.0

GLASS CAPACITY TABLE

GLASS LOAD CAPACITY (PSF)			
NOMINAL DIMS.		GLASS TYPES '1, 2, 3, 4, 5, 6'	
D.L.O. WIDTH 'in.'	D.L.O. HEIGHT 'in.'	EXT. (+)	INT. (-)
13.69	84.44	65.0	65.0
19.69		65.0	65.0
25.69		65.0	65.0
31.69		65.0	65.0
13.69		65.0	65.0
19.69	90.44	65.0	65.0
25.69		65.0	65.0
31.69		65.0	65.0
13.69		65.0	65.0
19.69		65.0	65.0
25.69	96.44	65.0	65.0
31.69		65.0	65.0
37.69		65.0	65.0
13.69		65.0	65.0
19.69		65.0	65.0
25.69	102.44	65.0	65.0
31.69		65.0	65.0
37.69		65.0	65.0
43.69		65.0	65.0
49.69		65.0	65.0
13.69	108.44	65.0	65.0
19.69		65.0	65.0
25.69		65.0	65.0
31.69		65.0	65.0
37.69		65.0	65.0
43.69	114.44	65.0	65.0
49.69		65.0	65.0
13.69		65.0	65.0
19.69		65.0	65.0
25.69		65.0	65.0
13.69	120.44	65.0	65.0
19.69		65.0	65.0
25.69		65.0	65.0
31.69		65.0	65.0
37.69		65.0	65.0
43.69	126.44	65.0	65.0
49.69		65.0	65.0
13.69		65.0	65.0
19.69		65.0	65.0
25.69		65.0	65.0
13.69	132.44	65.0	65.0
19.69		65.0	65.0
25.69		65.0	65.0
31.69		65.0	65.0
37.69		65.0	65.0
43.69	138.44	65.0	65.0
49.69		65.0	65.0
13.69		65.0	65.0
19.69		65.0	65.0
25.69		65.0	65.0
13.69	144.44	65.0	65.0
19.69		65.0	65.0
25.69		65.0	65.0
31.69		65.0	65.0
37.69		65.0	65.0
43.69	150.44	65.0	65.0
49.69		65.0	65.0
13.69		65.0	65.0
19.69		65.0	65.0
25.69		65.0	65.0

DESIGN PRESSURE (PSF)			
NOMINAL DIMS.		"X" CONFIGURATION	
FRAME WIDTH 'in.'	FRAME HEIGHT 'in.'	EXT. (+)	INT. (-)
18.00	36.00	65.0	65.0
24.00		65.0	65.0
30.00		65.0	65.0
36.00		65.0	65.0
18.00		65.0	65.0
24.00	42.00	65.0	65.0
30.00		65.0	65.0
36.00		65.0	65.0
42.00		55.7	55.7
18.00		65.0	65.0
24.00	48.00	65.0	65.0
30.00		65.0	65.0
36.00		65.0	65.0
42.00		55.7	55.7
48.00		48.8	48.8
18.00	54.00	65.0	65.0
24.00		65.0	65.0
30.00		65.0	65.0
36.00		65.0	65.0
42.00		55.7	55.7
48.00	60.00	48.8	48.8
54.00		43.3	43.3
18.00		65.0	65.0
24.00		65.0	65.0
30.00		65.0	65.0
36.00	66.00	65.0	65.0
42.00		55.7	55.7
48.00		48.8	48.8
18.00		65.0	65.0
24.00		65.0	65.0
30.00	72.00	65.0	65.0
36.00		65.0	65.0
42.00		55.7	55.7
48.00		48.8	48.8
18.00		65.0	65.0
24.00	78.00	65.0	65.0
30.00		65.0	65.0
36.00		65.0	65.0
42.00		55.7	55.7
48.00		48.8	48.8

DESIGN PRESSURE TABLE

"X"


DESIGN PRESSURE (PSF)			
NOMINAL DIMS.		"X" CONFIGURATION	
FRAME WIDTH 'in.'	FRAME HEIGHT 'in.'	EXT. (+)	INT. (-)
18.00	84.00	65.0	65.0
24.00		65.0	65.0
30.00		65.0	65.0
36.00		65.0	65.0
18.00		65.0	65.0
24.00	90.00	65.0	65.0
30.00		65.0	65.0
36.00		65.0	65.0
42.00		65.0	65.0
18.00		65.0	65.0
24.00	96.00	65.0	65.0
30.00		65.0	65.0
36.00		65.0	65.0
42.00		65.0	65.0
48.00		65.0	65.0
18.00	102.00	65.0	65.0
24.00		65.0	65.0
30.00		65.0	65.0
36.00		65.0	65.0
42.00		65.0	65.0
48.00	108.00	65.0	65.0
54.00		65.0	65.0
18.00		65.0	65.0
24.00		65.0	65.0
30.00		65.0	65.0
36.00	114.00	65.0	65.0
42.00		65.0	65.0
48.00		65.0	65.0
54.00		65.0	65.0
18.00		65.0	65.0
24.00	120.00	65.0	65.0
30.00		65.0	65.0
36.00		65.0	65.0
42.00		65.0	65.0
48.00		65.0	65.0
18.00	126.00	65.0	65.0
24.00		65.0	65.0
30.00		65.0	65.0
36.00		65.0	65.0
42.00		65.0	65.0
48.00	132.00	65.0	65.0
54.00		65.0	65.0
18.00		65.0	65.0
24.00		65.0	65.0
30.00		65.0	65.0
36.00	138.00	65.0	65.0
42.00		65.0	65.0
48.00		65.0	65.0
54.00		65.0	65.0
18.00		65.0	65.0
24.00	144.00	65.0	65.0
30.00		65.0	65.0
36.00		65.0	65.0
42.00		65.0	65.0
48.00		65.0	65.0
18.00	150.00	65.0	65.0
24.00		65.0	65.0
30.00		65.0	65.0
36.00		65.0	65.0
42.00		65.0	65.0

DESIGN PRESSURE TABLE


"X - X"

DESIGN PRESSURE (PSF)			
NOMINAL DIMS.		"X-X" CONFIGURATION	
TRIB. WIDTH (W) 'in.'	FRAME HEIGHT 'in.'	EXT. (+)	INT. (-)
18.00	36.00	65.0	65.0
24.00		65.0	65.0
30.00		65.0	65.0
36.00		65.0	65.0
18.00		65.0	65.0
24.00	42.00	65.0	65.0
30.00		65.0	65.0
36.00		65.0	65.0
42.00		65.0	65.0
18.00		65.0	65.0
24.00	48.00	65.0	65.0
30.00		65.0	65.0
36.00		65.0	65.0
42.00		65.0	65.0
48.00		65.0	65.0
18.00	54.00	65.0	65.0
24.00		65.0	65.0
30.00		65.0	65.0
36.00		65.0	65.0
42.00		65.0	65.0
48.00	60.00	65.0	65.0
54.00		65.0	65.0
18.00		65.0	65.0
24.00		65.0	65.0
30.00		65.0	65.0
36.00	66.00	65.0	65.0
42.00		65.0	65.0
48.00		65.0	65.0
54.00		65.0	65.0
18.00		65.0	65.0
24.00	72.00	65.0	65.0
30.00		65.0	65.0
36.00		65.0	65.0
42.00		65.0	65.0
48.00		65.0	65.0
18.00	78.00	65.0	65.0
24.00		65.0	65.0
30.00		65.0	65.0
36.00		65.0	65.0
42.00		65.0	65.0



DESIGN PRESSURE (PSF)			
NOMINAL DIMS.		"X-X" CONFIGURATION	
TRIB. WIDTH (W) 'in.'	FRAME HEIGHT 'in.'	EXT. (+)	INT. (-)
18.00	84.00	65.0	65.0
24.00		65.0	65.0
30.00		65.0	65.0
36.00		65.0	65.0
18.00	90.00	65.0	65.0
24.00		65.0	65.0
30.00		65.0	65.0
36.00		65.0	65.0
18.00	96.00	65.0	65.0
24.00		65.0	65.0
30.00		65.0	65.0
36.00		65.0	65.0
18.00	102.00	65.0	65.0
24.00		65.0	65.0
30.00		63.6	63.6
36.00		65.0	65.0
18.00	108.00	65.0	65.0
24.00		65.0	65.0
30.00		53.4	53.4
36.00		65.0	65.0
18.00	114.00	56.0	56.0
24.00		45.2	45.2
30.00		63.4	63.4
36.00		47.9	47.9
18.00	126.00	54.8	54.8
24.00		41.3	41.3
30.00		47.6	47.6
36.00		35.9	35.9
18.00	132.00	41.6	41.6
24.00		31.4	31.4
30.00		36.6	36.6
36.00		27.6	27.6
18.00	150.00	32.4	32.4



DOUBLE OUTSWING CASEMENT WINDOW
EXTERIOR ELEVATION VIEW




SINGLE CASEMENT WINDOW
EXTERIOR ELEVATION VIEW




ALLOWABLE CONFIGURATIONS "X - X"

NOTE: SIZES LIMITED TO MAX.
WIDTH AND HEIGHT IN DP TABLES
ON SHEET 3.



ALLOWABLE CONFIGURATIONS "X"

NOTE: SIZES LIMITED TO MAX.
WIDTH AND HEIGHT IN DP TABLES
ON SHEET 3.



OPTIMUM STEEL WINDOWS AND DOORS
28 CANAL STREET
ELLENVILLE, NY 12428
PH: (845) 647-1900 FX: (845) 647-1494

TITLE: RTS-430i STAINLESS STEEL
FRENCH CASEMENT WINDOW
(WZ3)(IMPACT)

ELEVATIONS

PREPARED BY: BUILDING DROPS, INC.
1900 NE MIAMI CT, SUITE 2-15
MIAMI, FL 33132
PH: (954) 399-8478
FAX: (954) 744-4738
WEB: www.buildingdrops.com



REMARKS	BY	DATE
MISC. REVISION	MS	01/26

THE INSTALLATION DETAILS DESCRIBED HEREIN ARE GENERIC AND MAY NOT REFLECT ACTUAL CONDITIONS FOR A SPECIFIC SITE. IF SITE CONDITIONS CAUSE INSTALLATION TO DEVIATE FROM THE REQUIREMENTS DETAILED HEREIN, A LICENSED ENGINEER OR ARCHITECT SHALL PREPARE SITE SPECIFIC DOCUMENTS FOR USE WITH THIS DOCUMENT.



FL38442

DATE:	02.12.25
DWG. BY:	DB
CHK. BY:	HFN
SCALE:	NTS
DWG. #:	OPW018
SHEET:	OF 13



OPTIMUM STEEL WINDOWS AND DOORS
28 CANAL STREET
ELLENVILLE, NY 12428
PH: (845) 647-1900 FX: (845) 647-1494

TITLE: RTS-430i STAINLESS STEEL
FRENCH CASEMENT WINDOW
(WZ3)(IMPACT)
ANCHOR LAYOUTS

PREPARED BY:
BUILDING DROPS, INC.
1900 NE MIAMI CT, SUITE 2-15
MIAMI, FL 33132
PH: (954) 399-8478
FAX: (954) 744-4738
WEB: www.buildingdrops.com




REMARKS	BY	DATE
MISC. REVISION	MS	01/26

THE INSTALLATION DETAILS DESCRIBED HEREIN ARE GENERIC AND MAY NOT REFLECT ACTUAL CONDITIONS FOR A SPECIFIC SITE. IF SITE CONDITIONS CAUSE INSTALLATION TO DEVIATE FROM THE REQUIREMENTS DETAILED HEREIN, A LICENSED ENGINEER OR ARCHITECT SHALL PREPARE SITE SPECIFIC DOCUMENTS FOR USE WITH THIS DOCUMENT.





FL38442


DATE:	02.12.25
DWG. BY:	DB
CHK. BY:	HFN
SCALE:	NTS
DWG. #:	OPW018
SHEET:	OF 13



DOUBLE OUTSWING CASEMENT WINDOW
ANCHOR LAYOUT



SINGLE CASEMENT WINDOW
ANCHOR LAYOUT





OPTIMUM STEEL WINDOWS AND DOORS
28 CANAL STREET
ELLENVILLE, NY 12428
PH: (845) 647-1900 FX: (845) 647-1494


TITLE: RTS-430I STAINLESS STEEL
FRENCH CASEMENT WINDOW
(WZ3)(IMPACT)
VERTICAL SECTIONS - 2X
WOOD BUCK

PREPARED BY:
BUILDING DROPS, INC.
1900 NE MIAMI CT, SUITE 2-15
MIAMI, FL 33132
PH: (954) 399-8478
FAX: (954) 744-4738
WEB: www.buildingdrops.com



REMARKS	BY	DATE
MISC. REVISION	MS	01/26


THE INSTALLATION DETAILS DESCRIBED HEREIN ARE GENERIC
AND MAY NOT REFLECT ACTUAL CONDITIONS FOR A SPECIFIC
SITE. IF SITE CONDITIONS CAUSE INSTALLATION TO DEVIATE
FROM THE REQUIREMENTS DETAILED HEREIN, A LICENSED
ENGINEER OR ARCHITECT SHALL PREPARE SITE SPECIFIC
DOCUMENTS FOR USE WITH THIS DOCUMENT.




FL38442

DATE:	02.12.25
DWG. BY:	DB
CHK. BY:	HFN
SCALE:	NTS
DWG. #:	OPW018
SHEET:	OF 13


6




A
6 VERTICAL SECTION
HEAD - 2X WOOD BUCK
STRAP INSTALLATION
LONG LEG FRAME




B
6 VERTICAL SECTION
HEAD - 2X WOOD BUCK
THROUGH FRAME INSTALLATION
LONG LEG FRAME




C
6 VERTICAL SECTION
HEAD - 2X WOOD BUCK
FLANGE INSTALLATION
UNEQUAL LEG FRAME




D
6 VERTICAL SECTION
SILL - 2X WOOD BUCK
STRAP INSTALLATION
LONG LEG FRAME




E
6 VERTICAL SECTION
SILL - 2X WOOD BUCK
THROUGH FRAME INSTALLATION
LONG LEG FRAME




F
6 VERTICAL SECTION
SILL - 2X WOOD BUCK
FLANGE INSTALLATION
UNEQUAL LEG FRAME




A
7 **VERTICAL SECTION**
HEAD - CONCRETE/MASONRY
STRAP INSTALLATION
LONG LEG FRAME




D
7 **VERTICAL SECTION**
SILL - CONCRETE/MASONRY
STRAP INSTALLATION
LONG LEG FRAME




B
7 **VERTICAL SECTION**
HEAD - CONCRETE/MASONRY
THROUGH FRAME INSTALLATION
LONG LEG FRAME



E
7 **VERTICAL SECTION**
SILL - CONCRETE/MASONRY
THROUGH FRAME INSTALLATION
LONG LEG FRAME



C
7 **VERTICAL SECTION**
HEAD - CONCRETE/MASONRY
FLANGE/STRAP INSTALLATION
UNEQUAL LEG FRAME



F
7 **VERTICAL SECTION**
SILL - CONCRETE/MASONRY
FLANGE/STRAP INSTALLATION
UNEQUAL LEG FRAME



OPTIMUM STEEL WINDOWS AND DOORS
28 CANAL STREET
ELLENVILLE, NY 12428
PH: (845) 647-1900 FX: (845) 647-1494


TITLE: RTS-430I STAINLESS STEEL
FRENCH CASEMENT WINDOW
(WZ3)(IMPACT)
VERTICAL SECTIONS-
CONCRETE/MASONRY

PREPARED BY:
BUILDING DROPS, INC.
1900 NE MIAMI CT, SUITE 2-15
MIAMI, FL 33132
PH: (954) 399-8478
FAX: (954) 744-4738
WEB: www.buildingdrops.com



REMARKS	BY	DATE
MISC. REVISION	MS	01/26

THE INSTALLATION DETAILS DESCRIBED HEREIN ARE GENERIC AND MAY NOT REFLECT ACTUAL CONDITIONS FOR A SPECIFIC SITE. IF SITE CONDITIONS CAUSE INSTALLATION TO DEVIATE FROM THE REQUIREMENTS DETAILED HEREIN, A LICENSED ENGINEER OR ARCHITECT SHALL PREPARE SITE SPECIFIC DOCUMENTS FOR USE WITH THIS DOCUMENT.



FL38442

DATE: 02.12.25


DWG. BY: DB
CHK. BY: HFN

SCALE: NTS


DWG. #: OPW018

SHEET: OF 13


7




A
8 **VERTICAL SECTION**
HEAD - METAL STUD
STRAP INSTALLATION
LONG LEG FRAME




B
8 **VERTICAL SECTION**
HEAD - METAL STUD
THROUGH FRAME INSTALLATION
LONG LEG FRAME




C
8 **VERTICAL SECTION**
HEAD - METAL STUD
FLANGE INSTALLATION
UNEQUAL LEG FRAME



D
8 **VERTICAL SECTION**
SILL - METAL STUD
STRAP INSTALLATION
LONG LEG FRAME



E
8 **VERTICAL SECTION**
SILL - METAL STUD
THROUGH FRAME INSTALLATION
LONG LEG FRAME



F
8 **VERTICAL SECTION**
SILL - METAL STUD
FLANGE INSTALLATION
UNEQUAL LEG FRAME



OPTIMUM STEEL WINDOWS AND DOORS
28 CANAL STREET
ELLENVILLE, NY 12428
PH: (845) 647-1900 FX: (845) 647-1494


TITLE: RTS-430I STAINLESS STEEL
FRENCH CASEMENT WINDOW
(WZ3)(IMPACT)
VERTICAL SECTIONS -
METAL STUD

PREPARED BY:
BUILDING DROPS, INC.
1900 NE MIAMI CT, SUITE 2-15
MIAMI, FL 33132
PH: (954) 399-8478
FAX: (954) 744-4738
WEB: www.buildingdrops.com



REMARKS	BY	DATE
MISC. REVISION	MS	01/26


THE INSTALLATION DETAILS DESCRIBED HEREIN ARE GENERIC AND MAY NOT REFLECT ACTUAL CONDITIONS FOR A SPECIFIC SITE. IF SITE CONDITIONS CAUSE INSTALLATION TO DEVIATE FROM THE REQUIREMENTS DETAILED HEREIN, A LICENSED ENGINEER OR ARCHITECT SHALL PREPARE SITE SPECIFIC DOCUMENTS FOR USE WITH THIS DOCUMENT.




FL38442

DATE:	02.12.25
DWG. BY:	DB
CHK. BY:	HFN
SCALE:	NTS
DWG. #:	OPW018
SHEET:	OF 13


8




A
9 **HORIZONTAL SECTION**
JAMB- 2X WOOD BUCK
STRAP INSTALLATION
LONG LEG FRAME




B
9 **HORIZONTAL SECTION**
JAMB- 2X WOOD BUCK
THROUGH FRAME INSTALLATION
LONG LEG FRAME



C
9 **HORIZONTAL SECTION**
JAMB- 2X WOOD BUCK
FLANGE INSTALLATION
UNEQUAL LEG FRAME



D
9 **HORIZONTAL SECTION**
CENTER STILES
INTERIOR GLAZED



E
9 **HORIZONTAL SECTION**
CENTER STILES
EXTERIOR GLAZED



OPTIMUM STEEL WINDOWS AND DOORS
28 CANAL STREET
ELLENVILLE, NY 12428
PH: (845) 647-1900 FX: (845) 647-1494

TITLE: RTS-430I STAINLESS STEEL
FRENCH CASEMENT WINDOW
(WZ3)(IMPACT)
HORIZONTAL SECTIONS - 2X WOOD
BUCK & CENTER STILES

PREPARED BY:
BUILDING DROPS, INC.
1900 NE MIAMI CT, SUITE 2-15
MIAMI, FL 33132
PH: (954) 399-8478
FAX: (954) 744-4738
WEB: www.buildingdrops.com




REMARKS	BY	DATE
MISC. REVISION	MS	01/26

THE INSTALLATION DETAILS DESCRIBED HEREIN ARE GENERIC
AND MAY NOT REFLECT ACTUAL CONDITIONS FOR A SPECIFIC
SITE. IF SITE CONDITIONS CAUSE INSTALLATION TO DEVIATE
FROM THE REQUIREMENTS DETAILED HEREIN, A LICENSED
ENGINEER OR ARCHITECT SHALL PREPARE SITE SPECIFIC
DOCUMENTS FOR USE WITH THIS DOCUMENT.




FL38442


DATE:	02.12.25
DWG. BY:	DB
CHK. BY:	HFN
SCALE:	NTS
DWG. #:	OPW018
SHEET:	OF 13



A HORIZONTAL SECTION
10 JAMB- CONCRETE/MASONRY STRAP INSTALLATION LONG LEG FRAME



B HORIZONTAL SECTION
10 JAMB- CONCRETE/MASONRY THROUGH FRAME INSTALLATION LONG LEG FRAME



C HORIZONTAL SECTION
10 JAMB- CONCRETE/MASONRY FLANGE/STRAP INSTALLATION UNEQUAL LEG FRAME




OPTIMUM STEEL WINDOWS AND DOORS
 28 CANAL STREET
 ELLENVILLE, NY 12428
 PH: (845) 647-1900 FX: (845) 647-1494

TITLE: RTS-430i STAINLESS STEEL FRENCH CASEMENT WINDOW (WZ3)(IMPACT)
 HORIZONTAL SECTIONS - CONCRETE/MASONRY
 PREPARED BY: BUILDING DROPS, INC.
 1900 NE MIAMI CT, SUITE 2-15
 MIAMI, FL 33132
 PH: (954) 399-8478
 FAX: (954) 744-4738
 WEB: www.buildingdrops.com

REMARKS	BY	DATE
MISC. REVISION	MS	01/26


THE INSTALLATION DETAILS DESCRIBED HEREIN ARE GENERIC AND MAY NOT REFLECT ACTUAL CONDITIONS FOR A SPECIFIC SITE. IF SITE CONDITIONS CAUSE INSTALLATION TO DEVIATE FROM THE REQUIREMENTS DETAILED HEREIN, A LICENSED ENGINEER OR ARCHITECT SHALL PREPARE SITE SPECIFIC DOCUMENTS FOR USE WITH THIS DOCUMENT.




FL38442

DATE: 02.12.25
 DWG. BY: DB
 CHK. BY: HFN
 SCALE: NTS
 DWG. #: OPW018
 SHEET: OF 13


10



A HORIZONTAL SECTION
11
JAMB- METAL STUD
STRAP INSTALLATION
LONG LEG FRAME



B HORIZONTAL SECTION
11
JAMB- METAL STUD
THROUGH FRAME INSTALLATION
LONG LEG FRAME



C HORIZONTAL SECTION
11
JAMB- METAL STUD
FLANGE INSTALLATION
UNEQUAL LEG FRAME



OPTIMUM STEEL WINDOWS AND DOORS
28 CANAL STREET
ELLENVILLE, NY 12428
PH: (845) 647-1900 FX: (845) 647-1494

TITLE: RTS-430I STAINLESS STEEL
FRENCH CASEMENT WINDOW
(WZ3)/(IMPACT)
HORIZONTAL SECTIONS -
METAL STUD

PREPARED BY:
BUILDING DROPS, INC.
1900 NE MIAMI CT, SUITE 2-15
MIAMI, FL 33132
PH: (954) 399-8478
FAX: (954) 744-4738
WEB: www.buildingdrops.com



REMARKS	BY	DATE
MISC. REVISION	MS	01/26


THE INSTALLATION DETAILS DESCRIBED HEREIN ARE GENERIC AND MAY NOT REFLECT ACTUAL CONDITIONS FOR A SPECIFIC SITE. IF SITE CONDITIONS CAUSE INSTALLATION TO DEVIATE FROM THE REQUIREMENTS DETAILED HEREIN, A LICENSED ENGINEER OR ARCHITECT SHALL PREPARE SITE SPECIFIC DOCUMENTS FOR USE WITH THIS DOCUMENT.



FL38442

DATE:	02.12.25
DWG. BY:	DB
CHK. BY:	HFN
SCALE:	NTS
DWG. #:	OPW018
SHEET:	OF 13


11




EXTERIOR INTERIOR

A
12 **VERTICAL SECTION**
HEAD - 2X WOOD BUCK
THROUGH FRAME INSTALLATION
SHORT LEG FRAME

EXTERIOR INTERIOR




D
12 **VERTICAL SECTION**
SILL - 2X WOOD BUCK
THROUGH FRAME INSTALLATION
SHORT LEG FRAME




EXTERIOR INTERIOR

B
12 **VERTICAL SECTION**
HEAD - CONCRETE/MASONRY
THROUGH FRAME INSTALLATION
SHORT LEG FRAME

EXTERIOR INTERIOR




E
12 **VERTICAL SECTION**
SILL - CONCRETE/MASONRY
THROUGH FRAME INSTALLATION
SHORT LEG FRAME



EXTERIOR INTERIOR

C
12 **VERTICAL SECTION**
HEAD - METAL STUD
THROUGH FRAME INSTALLATION
SHORT LEG FRAME

EXTERIOR INTERIOR



F
12 **VERTICAL SECTION**
SILL - METAL STUD
THROUGH FRAME INSTALLATION
SHORT LEG FRAME



OPTIMUM STEEL WINDOWS AND DOORS
28 CANAL STREET
ELLENVILLE, NY 12428
PH: (845) 647-1900 FX: (845) 647-1494

TITLE: RTS-430I STAINLESS STEEL
FRENCH CASEMENT WINDOW
(WZ3)(IMPACT)

VERTICAL SECTIONS

PREPARED BY:

BUILDING DROPS, INC.

1900 NE MIAMI CT, SUITE 2-15
MIAMI, FL 33132
PH: (954) 399-8478
FAX: (954) 744-4738
WEB: www.buildingdrops.com



REMARKS	BY	DATE
MISC. REVISION	MS	01/26


THE INSTALLATION DETAILS DESCRIBED HEREIN ARE GENERIC AND MAY NOT REFLECT ACTUAL CONDITIONS FOR A SPECIFIC SITE. IF SITE CONDITIONS CAUSE INSTALLATION TO DEVIATE FROM THE REQUIREMENTS DETAILED HEREIN, A LICENSED ENGINEER OR ARCHITECT SHALL PREPARE SITE SPECIFIC DOCUMENTS FOR USE WITH THIS DOCUMENT.




FL38442

DATE:	02.12.25
DWG. BY:	DB
CHK. BY:	HFN
SCALE:	NTS
DWG. #:	OPW018
SHEET:	OF 13


12



A HORIZONTAL SECTION
13 JAMB- 2X WOOD BUCK
 THROUGH FRAME INSTALLATION
 SHORT LEG FRAME



C HORIZONTAL SECTION
13 JAMB- METAL STUD
 THROUGH FRAME INSTALLATION
 SHORT LEG FRAME



B HORIZONTAL SECTION
13 JAMB- CONCRETE/MASONRY
 THROUGH FRAME INSTALLATION
 SHORT LEG FRAME



OPTIMUM STEEL WINDOWS AND DOORS
 28 CANAL STREET
 ELLENVILLE, NY 12428
 PH: (845) 647-1900 FX: (845) 647-1494

TITLE: RTS-430I STAINLESS STEEL
 FRENCH CASEMENT WINDOW
 (WZ3)(IMPACT)

HORIZONTAL SECTIONS


PREPARED BY: BUILDING DROPS, INC.

1900 NE MIAMI CT, SUITE 2-15
 MIAMI, FL 33132
 PH: (954) 399-8478
 FAX: (954) 744-4738
 WEB: www.buildingdrops.com



REMARKS	BY	DATE
MISC. REVISION	MS	01/26

THE INSTALLATION DETAILS DESCRIBED HEREIN ARE GENERIC AND MAY NOT REFLECT ACTUAL CONDITIONS FOR A SPECIFIC SITE. IF SITE CONDITIONS CAUSE INSTALLATION TO DEVIATE FROM THE REQUIREMENTS DETAILED HEREIN, A LICENSED ENGINEER OR ARCHITECT SHALL PREPARE SITE SPECIFIC DOCUMENTS FOR USE WITH THIS DOCUMENT.



FL38442

DATE: 02.12.25

DWG. BY: DB

CHK. BY: HFN

SCALE: NTS

DWG. #: OPW018

SHEET: OF 13

13