


GLASS TYPE 'A'

7/16" NOM. LAMI. GLASS

SERIES 950
ALUMINUM OUTSWING ENTRANCE DOOR

SINGLE (X) AND DOUBLE (XX) LEAF DOORS SEE SHEET 2.
SINGLE AND DOUBLE LEAF DOORS WITH SIDELITES SEE SHEET 3 & 4.
SINGLE (O) STAND ALONE SIDELITE SEE SHEETS 3 & 4.

LOWER VALUES FROM SIDELITE CAPACITY CHART OR DOOR CAPACITY WILL APPLY TO ENTIRE SYSTEM.

DOOR APPROVED FOR INSTALLATIONS WHERE WATER INFILTRATION RESISTANCE IS REQUIRED.

THIS PRODUCT HAS BEEN DESIGNED AND TESTED TO COMPLY WITH THE REQUIREMENTS OF THE FLORIDA BUILDING CODE INCLUDING HIGH VELOCITY HURRICANE ZONE (HVHZ).

1BY OR 2BY WOOD BUCKS & BUCK FASTENERS BY OTHERS, MUST BE DESIGNED AND INSTALLED ADEQUATELY TO TRANSFER APPLIED PRODUCT LOADS TO THE BUILDING STRUCTURE

ANCHORS SHALL BE CORROSION RESISTANT, SPACED AS SHOWN ON DETAILS AND INSTALLED PER MANUF'S INSTRUCTIONS. SPECIFIED EMBEDMENT TO BASE MATERIAL SHALL BE BEYOND WALL DRESSING OR STUCCO.

A LOAD DURATION INCREASE IS USED IN DESIGN OF ANCHORS INTO WOOD ONLY.


ALL SHIMS TO BE HIGH IMPACT, NON–METALLIC AND NON–COMPRESSIBLE.

MATERIALS INCLUDING BUT NOT LIMITED TO STEEL/METAL SCREWS, THAT COME INTO CONTACT WITH OTHER DISSIMILAR MATERIALS SHALL MEET THE REQUIREMENTS OF THE FLORIDA BLDG. CODE & ADOPTED STANDARDS.

THIS PRODUCT APPROVAL IS GENERIC AND DOES NOT PROVIDE INFORMATION FOR A SITE SPECIFIC PROJECT, i.e. LIFE SAFETY OF THIS PRODUCT, ADEQUACY OF STRUCTURE RECEIVING THIS PRODUCT AND SEALING AROUND OPENING FOR WATER INFILTRATION RESISTANCE ETC.
CONDITIONS NOT SHOWN IN THIS DRAWING ARE TO BE ANALYZED SEPARATELY, AND TO BE REVIEWED BY BUILDING OFFICIAL

DESIGN LOAD SHOWN ARE BASED ON 'ALLOWABLE STRESS DESIGN (ASD)'.

GLAZING OPTIONS



GLASS TYPE 'A1'

1" NOM. INSUL. LAM. GLASS

THESE DOORS ARE RATED FOR LARGE & SMALL MISSILE IMPACT. SHUTTERS ARE NOT REQUIRED.

FL#39630.9

JAVAD AHMAD PE, inc
7875 NW 12th St., Suite 102 Doral, FL 33126
Ph: (305) 424-8001
support@ja-pe.com
CONSULTING • STRUCTURAL DESIGN • FACADES • BUILDING ENVELOPE • SYSTEM DESIGN • PRODUCT APPROVALS

drawing no. JA-1844-24 | drawn by: MA
date: 12/30/2024 | check by: BS

REVISION


No.	DATE	BY	DESCRIPTION

SERIES 950: ALUMINUM OUTSWING ENTRANCE DOOR (LM.I)
LARGE MISSILE IMPACT RATED


ECO window systems
ECO WINDOW SYSTEMS, LLC.
8502 N.W. 80th ST. MEDLEY, FL 33166
TEL. (305) 885-5299 FAX. (305) 885-5902

JAVAD AHMAD LICENSE No 70592 STATE OF FLORIDA PROFESSIONAL ENGINEER

SEALED: 12/30/2024



(X)



(XX)

MAXIMUM DESIGN LOAD RATING =	+ 60.0 PSF
(FOR SIZES SHOWN ABOVE OR SMALLER)	– 70.0 PSF

NOTE:
EGRESS REQUIREMENTS TO BE REVIEWED BY BUILDING OFFICIAL

GLASS D.L.O. DIMS.
D.L.O. HEIGHT = FRAME HEIGHT – 10.750"
D.L.O. WIDTH (X DOORS) = FRAME WIDTH – 11.375"
D.L.O. WIDTH (XX DOORS) = (FRAME WIDTH – 19.375")/2

NOTE:
GLASS CAPACITIES ON THIS SHEET ARE BASED ON ASTM E1300–16 (3 SEC. GUSTS)

FL#39630.9

JAVAD AHMAD PE, inc
7875 NW 12th St., Suite 102 Doral, FL 33126
Ph: (305) 424-8001
support@ja-pe.com

CONSULTING • STRUCTURAL DESIGN • FACADES • BUILDING ENVELOPE • SYSTEM DESIGN • PRODUCT APPROVALS

drawing no. JA-1844-24 | drawn by: MA
date: 12/30/2024 | check by: BS

REVISION


No.	DATE	BY	DESCRIPTION

SERIES 950: ALUMINUM OUTSWING ENTRANCE DOOR (L.M.I)
LARGE MISSILE IMPACT RATED

eco window systems
ECO WINDOW SYSTEMS, LLC.
8502 N.W. 80th ST. MEDLEY, FL 33166
TEL. (305) 885-5299 FAX. (305) 885-5902

JAVAD AHMAD LICENSE No 70592 STATE OF FLORIDA PROFESSIONAL ENGINEER
SEALED: 12/30/2024


02 | 02 of 10



TYPICAL ELEVATION

(O)

STAND ALONE SIDELITE
(SEE SHEET 4 FOR CAPACITY)



TYPICAL ELEVATION

(OXXO)

PAIRED SIDELITE GLASS D.L.O. DIMS.
D.L.O. HEIGHT (SIDELITE) = FRAME HEIGHT – 11.000"
D.L.O. WIDTH (SIDELITE) = FRAME WIDTH – 3.312"

STAND ALONE SIDELITE GLASS D.L.O. DIMS.
D.L.O. HEIGHT (SIDELITE) = FRAME HEIGHT – 11.000"
D.L.O. WIDTH (SIDELITE) = FRAME WIDTH – 4.438"

NOTE:
FOR DOORS CAPACITIES SEE SHEET 2.
FOR SINGLE SIDELITE CAPACITY SEE SHEET 4.
FOR SIDELITE REINF. MULLION CAPACITY SEE SHEET 4.
LOWER VALUES FROM DOOR, SIDELITE OR REINF. MULLION CHART
WILL APPLY TO ENTIRE SYSTEM.

FL#39630.9

JAVAD AHMAD PE, inc
7875 NW 12th St., Suite 102 Doral,
FL 33126
Ph: (305) 424-8001
support@ja-pe.com

CONSULTING • STRUCTURAL DESIGN • FACADES • BUILDING ENVELOPE • SYSTEM DESIGN • PRODUCT APPROVALS

drawing no. JA-1844-24 | drawn by: MA
date: 12/30/2024 | check by: BS

REVISION

No.	DATE	BY	DESCRIPTION

SERIES 950: ALUMINUM OUTSWING ENTRANCE DOOR
(L.M.I)
LARGE MISSILE IMPACT RATED

ECO WINDOW SYSTEMS, LLC.
8502 N.W. 80th ST. MEDLEY, FL 33166
TEL. (305) 885-5299 FAX. (305) 885-5902

JAVAD AHMAD LICENSE No 70592 STATE OF FLORIDA PROFESSIONAL ENGINEER

SEALED: 12/30/2024

Design Load Capacity - PSF


Stand Alone Single Sidelites


Without Reinforcement		Sidelite Frame Height (in.)							
		80"		84"		96"		108"	
Sidelite Frame Width (in.)	24"	+60.0	-70.0	+60.0	-70.0	+60.0	-70.0	+60.0	-70.0
	28"	+60.0	-70.0	+60.0	-70.0	+60.0	-70.0	+60.0	-69.8
	31-11/16"	+60.0	-70.0	+60.0	-70.0	+60.0	-70.0	+60.0	-65.8
	32"	+60.0	-70.0	+60.0	-70.0	+60.0	-70.0		
	35-9/16"	+53.3	-62.2	+53.3	-62.2	+53.3	-62.2		
	36"	+53.3	-62.2	+53.3	-62.2				

Design Load Capacity - PSF

Sidelites with Single or Double Leaf Doors
(SEE NOTE BELOW)

Mullion w/ Reinforcement		Sidelite Frame Height (in.)							
		80"		84"		96"		108"	
Sidelite Frame Width (in.)	24"	+60.0	-70.0	+60.0	-70.0	+60.0	-70.0	+60.0	-70.0
	28"	+60.0	-70.0	+60.0	-70.0	+60.0	-70.0	+60.0	-69.8
	31-11/16"	+60.0	-70.0	+60.0	-70.0	+60.0	-70.0	+60.0	-65.8
	32"	+60.0	-70.0	+60.0	-70.0	+60.0	-70.0		
	35-9/16"	+53.3	-62.2	+53.3	-62.2	+53.3	-62.2		
	36"	+53.3	-62.2	+53.3	-62.2				





NOTE:
GLASS CAPACITIES ON THIS SHEET ARE
BASED ON ASTM E1300–16 (3 SEC. GUSTS)

FOR SINGLE OR DOUBLE DOORS CAPACITY SEE SHEET 2.
FOR SIDELITE MULLION CAPACITY SEE CHART ABOVE.
LOWER VALUES FROM DOOR CAPACITY CHARTS OR DOOR/SIDELITE MULLION CHART WILL APPLY TO ENTIRE SYSTEM.

FOR STAND ALONE SINGLE SIDELITE CAPACITY SEE CHART ABOVE.

FOR SIZES NOT SHOWN, ROUND UP TO THE NEXT AVAILABLE WIDTH OR HEIGHT DIMENSION SHOWN ON THE TABLE.

FL#39630.9

JAVAD AHMAD PE, inc
7875 NW 12th St., Suite 102 Doral, FL 33126
Ph: (305) 424-8001
support@ja-pe.com

CONSULTING • STRUCTURAL DESIGN • FACADES • BUILDING ENVELOPE • SYSTEM DESIGN • PRODUCT APPROVALS

drawing no. JA-1844-24 | drawn by: MA
date: 12/30/2024 | check by: BS


REVISION


No.	DATE	BY	DESCRIPTION


SERIES 950: ALUMINUM OUTSWING ENTRANCE DOOR (L.M.I)
LARGE MISSILE IMPACT RATED


ECO window systems
ECO WINDOW SYSTEMS, LLC.
8502 N.W. 80th ST. MEDLEY, FL 33166
TEL. (305) 885-5299 FAX. (305) 885-5902

JAVAD AHMAD LICENSE No 70592 STATE OF FLORIDA PROFESSIONAL ENGINEER
SEALED: 12/30/2024









1BY OR 2BY WOOD BUCKS AND METAL STRUCTURE NOT BY 'ECO WDW.' MUST SUSTAIN LOADS IMPOSED BY GLAZING SYSTEM AND TRANSFER THEM TO THE BUILDING STRUCTURE.


NOTE:
ANCHORS MUST GO THRU ANCHOR PADS AS SHOWN ON FRAME MEMBERS

TYPICAL ANCHORS: SEE ELEV. FOR SPACING

Anchor Type	Frame Member	Substrate	Min. Edge Distance	Min. Embedment or Metal Thickness
1/4" DeWalt UltraCon +	Head/Jambs	Southern Pine (SG = 0.55)	1"	1-1/2"
	Head/Jambs	Thru 1BY Buck into Concrete (min. 3 ksi)	2-1/2"	1-1/4"
	Jambs	Thru 1BY Buck into Filled Block (ASTM C90, min. 2 ksi)	2-1/2"	1-1/2"
	All	Concrete (min. 3ksi)	2-1/2"	1-1/4"
	Jambs	Filled Block (ASTM C90, min. 2 ksi)	2-1/2"	1-1/2"
#14 SMS or Self Drilling Screws (Gr. 2)	All	F.B.C Approved Mullions	3/4"	(3) Threads min. beyond metal thickness
	Head/Jambs	Aluminum 1/8" Thk. Min. (6063-T5)	3/4"	(3) Threads min. beyond metal thickness
	Head/Jambs	Steel 1/8" Thk. Min. (min. 36 ksi)	3/4"	(3) Threads min. beyond metal thickness

1. STEEL IN CONTACT WITH ALUMINUM TO BE PLATED OR PAINTED

2. ALL ANCHOR HEAD TYPES ARE ACCEPTABLE



DOOR DETAILS

FL#39630.9

JAVAD AHMAD PE, inc
7875 NW 12th St., Suite 102 Doral, FL 33126
Ph: (305) 424-8001
support@ja-pe.com

CONSULTING • STRUCTURAL DESIGN • FACADES • BUILDING ENVELOPE • SYSTEM DESIGN • PRODUCT APPROVALS

drawing no. JA-1844-24 | drawn by: MA
date: 12/30/2024 | check by: BS

REVISION


No.	DATE	BY	DESCRIPTION


SERIES 950: ALUMINUM OUTSWING ENTRANCE DOOR (L.M.I)
LARGE MISSILE IMPACT RATED


eco window systems
ECO WINDOW SYSTEMS, LLC.
8502 N.W. 80th ST. MEDLEY, FL 33166
TEL. (305) 885-5299 FAX. (305) 885-5902


JAVAD AHMAD LICENSE No 70592 STATE OF FLORIDA PROFESSIONAL ENGINEER

SEALED: 12/30/2024









DOOR DETAILS

FL#39630.9

JAVAD AHMAD PE, inc
7875 NW 12th St., Suite 102 Doral, FL 33126
Ph: (305) 424-8001
support@ja-pe.com
CONSULTING • STRUCTURAL DESIGN • FACADES • BUILDING ENVELOPE • SYSTEM DESIGN • PRODUCT APPROVALS

drawing no.	JA-1844-24	drawn by:	MA
date:	12/30/2024	check by:	BS

REVISION			
No.	DATE	BY	DESCRIPTION


SERIES 950: ALUMINUM OUTSWING ENTRANCE DOOR (L.M.I)
LARGE MISSILE IMPACT RATED


ECO WINDOW SYSTEMS, LLC.
8502 N.W. 80th ST. MEDLEY, FL 33166
TEL. (305) 885-5299 FAX. (305) 885-5902


JAVAD AHMAD LICENSE No 70592 STATE OF FLORIDA PROFESSIONAL ENGINEER

SEALED: 12/30/2024

NOTE:
ANCHORS MUST GO THRU ANCHOR PADS
AS SHOWN ON FRAME MEMBERS







SIDELITE DETAILS

FL#39630.9

JAVAD AHMAD PE, inc
7875 NW 12th St., Suite 102 Doral, FL 33126
Ph: (305) 424-8001
support@ja-pe.com
CONSULTING • STRUCTURAL DESIGN • FACADES • BUILDING ENVELOPE • SYSTEM DESIGN • PRODUCT APPROVALS

drawing no.	JA-1844-24	drawn by:	MA
date:	12/30/2024	check by:	BS

REVISION

No.	DATE	BY	DESCRIPTION

SERIES 950: ALUMINUM OUTSWING ENTRANCE DOOR (L.M.I)
LARGE MISSILE IMPACT RATED

ECO window systems
ECO WINDOW SYSTEMS, LLC.
8502 N.W. 80th ST. MEDLEY, FL 33166
TEL. (305) 885-5299 FAX. (305) 885-5902

JAVAD AHMAD LICENSE No 70592 STATE OF FLORIDA PROFESSIONAL ENGINEER
SEALED: 12/30/2024

ITEM #	PART #	REQD.	DESCRIPTION	MATERIAL	MANF./SUPPLIER/REMARKS
1	E627	AS REQD.	DOOR FRAME HEAD/SILL	6063 – T6	–
2	E602	AS REQD.	FRAME COVER (SIDELITE)	6063 – T6	–
2A	E629	AS REQD.	FRAME COVER (DOOR)	6063 – T6	–
3	E628	AS REQD.	DOOR FRAME JAMB	6063 – T6	–
4	E604	AS REQD.	SIDELITE TOP & BOTTOM FRAME	6063 – T6	–
5	E605	AS REQD.	SIDELITE FRAME JAMB	6063 – T6	–
6	E606	AS REQD.	SIDELITE SLIP ON JAMB	6063 – T6	–
7	E907	AS REQD.	LEAF TOP & BOTTOM RAIL	6063 – T6	–
8	E915	AS REQD.	LEAF W'STRIP ADAPTER	6063 – T6	–
9	E908	AS REQD.	LEAF STILE	6063 – T6	–
10	E910	AS REQD.	ASTRAGAL ADAPTER	6063 – T6	–
11	#10 X 3/4"	AS REQD.	ADAPTER FASTENER, AT 6" FROM ENDS AND 9" O.C. MAX	ST. STEEL	FH SELF DRILLING SCREWS
12	E909	AS REQD.	LEAF ALIGNMENT BRACKET	6063 – T6	–
13	E613	AS REQD.	LEAF CLAMP	6063 – T6	4–1/4" LONG
13A	E613	AS REQD.	HINGE BACK–UP PLATE	6063 – T6	10–1/2" LONG
14	E913	AS REQD.	GLAZING BEAD (LAM. GLASS)	6063 – T6	–
14A	E912	AS REQD.	GLAZING BEAD (INSUL. LAM. GLASS)	6063 – T6	–
16	E616	AS REQD.	SNAP COVER	6063 – T6	–
18	–	1	SIDELITE MULLION REINFORCING	6063 – T6	–
19	FD–107	3/ LEAF	BUTT HINGE	ALUMINUM	SULLIVAN & ASSOC.
22	#10 X 1–1/2"	AS REQD.	FRAME ASSEMBLY SCREWS	ST. STEEL	HWH SMS
23	#10 X 3/4"	–	HINGE INSTALLATION FASTENERS	ST. STEEL	FH SMS
24	–	2/ LEAF	3/8" DIA. THREADED ROD	STEEL	–
25	W11323	AS REQD.	PILE W'STRIPPING	WOOL	ULTRAFAB
26	E20618–KN–3020	AS REQD.	BULB W'STRIPPING	SANTOPRENE	EPDM
27	E206	AS REQD.	GLAZING BEAD BULB	SANTOPRENE	ULTRAFAB
28	–	AS REQD.	GLASS SPACER	SILICONE	FRANK LOWE RUBBER CO.
33	#10 X 3/4"	2/ ADAPTER	ADAPTER FASTENER, AT 5" FROM ENDS	ST. STEEL	FH SELF DRILLING
34	–	2/ LITE	SETTING BLOCK, 1/4" X 1/2" X 4"LONG	EPDM	AT 6" FROM EACH END, DUROMETER 80±5

LOCKS:

ACTIVE LEAF:
4 POINT LOCK ASSEMBLY DL01–6007 BY 'INTERLOCK USA INC.'
(2) LOCKING POINTS ENGAGING AT INACTIVE LEAD AT STRIKE PLATE 1/2" DIA. THROW BOLT (1) AT TOP ENGAGING FRAME HEAD AND (1) AT BOTTOM ENGAGING FRAME SILL
THROW BOLTS ATTACHED TO LOCK BY 3/8" CONNECTING RODS
LOCK HANDLE LOCATED AT 42–1/2" FROM BOTTOM

INACTIVE LEAF:
2 POINT LOCK ASSEMBLY BY 'INTERLOCK USA INC.'
1/2" DIA. THROW BOLTS AT TOP AND BOTTOM ENGAGING FRAME HEAD AND FRAME SILL
THROW BOLTS ATTACHED TO LOCK BY 3/8" CONNECTING RODS
LOCK LOCATED AT 42–1/2" FROM BOTTOM

DOOR HANDLES:

SURFACE MOUNTED MEALLIC HANDLES AT 42–1/2" FROM BOTTOM
FASTENED TO ACTIVE AND INACTIVE LEAF LOCK STILE WITH
(2) 1/4–20 X 1–13/16" CONE HEAD MS
(4) 1/4–20 X 5/16" SET SCREWS

HINGES:

3–1/2" X 7–5/8" X .122" THK. EXTRUDED ALUM. HINGE
PART #FD–107 BY SULLIVAN & ASSOC.
3 HINGES PER LEAF
BOTTOM HINGE AT 10–1/4" FROM BOTTOM
TOP HINGE AT 11–3/4" FROM TOP
CENTER HINGE AT MIDSPAN (38" O.C. MAX.)
HINGES FASTENED WITH #10 X 1" FH SMS
(5) SCREWS AT HINGE STILE
(6) SCREWS AT FRAME JAMB

SEALANT:

ALL FRAME/PANEL JOINTS AND SEAMS SEALED WITH SCHNEE MOREHEAD JM5504 SEALANT

FL#39630.9

JAVAD AHMAD PE, inc
7875 NW 12th St., Suite 102 Doral, FL 33126
Ph: (305) 424-8001
support@ja-pe.com
CONSULTING • STRUCTURAL DESIGN • FACADES • BUILDING ENVELOPE • SYSTEM DESIGN • PRODUCT APPROVALS

drawn by: MA
check by: BS
JA-1844-24
12/30/2024
drawing no.
date:

REVISION


No.	DESCRIPTION	BY	DATE

SERIES 950: ALUMINUM OUTSWING ENTRANCE DOOR (L.M.I.)
LARGE MISSILE IMPACT RATED


eco window systems
ECO WINDOW SYSTEMS, LLC.
8502 N.W. 80th ST. MEDLEY, FL 33166
TEL. (305) 885-5299 FAX. (305) 885-5902

JAVAD AHMAD LICENSE No 70592 STATE OF FLORIDA PROFESSIONAL ENGINEER


SEALED: 12/30/2024




1 DOOR FRAME HEAD/SILL




4 SIDELITE TOP & BOTTOM FRAME




16 SNAP COVER




3 DOOR FRAME JAMB




7 LEAF TOP/BOTTOM RAIL




9 LEAF STILE




2 FRAME COVER (SIDELITE)




10 ASTRAGAL W'STRIP ADAPTER




5 SIDELITE FRAME JAMB




14 GLAZING BEAD LAM. GLASS




14A GLAZING BEAD INSUL. LAM. GLASS




8 LEAF W'STRIP ADAPTER



12 LEAF ALIGNMENT BRACKET




2A FRAME COVER (DOOR)



13 LEAF CLAMP

13A HINGE BACK–UP PLATE

6 SIDELITE SLIP ON JAMB



18 SIDELITE MULLION REINFORCING

FL#39630.9

JAVAD AHMAD PE, inc
7875 NW 12th St., Suite 102 Doral, FL 33126
Ph: (305) 424-8001
support@ja-pe.com

CONSULTING • STRUCTURAL DESIGN • FACADES • BUILDING ENVELOPE • SYSTEM DESIGN • PRODUCT APPROVALS

drawing no. JA-1844-24 | drawn by: MA
date: 12/30/2024 | check by: BS

REVISION


No.	DATE	BY	DESCRIPTION

SERIES 950: ALUMINUM OUTSWING ENTRANCE DOOR (L.M.I.)
LARGE MISSILE IMPACT RATED


window systems
ECO WINDOW SYSTEMS, LLC.
8502 N.W. 80th ST. MEDLEY, FL 33166
TEL. (305) 885-5299 FAX. (305) 885-5902

JAVAD AHMAD LICENSE No 70592 STATE OF FLORIDA PROFESSIONAL ENGINEER


SEALED: 12/30/2024




DOOR FRAME CORNER



SIDELITE FRAME CORNER



SIDELITE MULLION SLIP ON JAMB CORNER



LEAF CORNER

FL#39630.9

JAVAD AHMAD PE, inc
7875 NW 12th St., Suite 102 Doral, FL 33126
Ph: (305) 424-8001
support@ja-pe.com

CONSULTING • STRUCTURAL DESIGN • FACADES • BUILDING ENVELOPE • SYSTEM DESIGN • PRODUCT APPROVALS

drawing no.	JA-1844-24	drawn by:	MA
date:	12/30/2024	check by:	BS

REVISION

No.	DATE	BY	DESCRIPTION

SERIES 950: ALUMINUM OUTSWING ENTRANCE DOOR (LM.I)
LARGE MISSILE IMPACT RATED

ECO window systems
ECO WINDOW SYSTEMS, LLC.
8502 N.W. 80th ST. MEDLEY, FL 33166
TEL. (305) 885-5299 FAX. (305) 885-5902

JAVAD AHMAD LICENSE No 70592 STATE OF FLORIDA PROFESSIONAL ENGINEER

SEALED: 12/30/2024