





UNIT	MAX PANEL WIDTH	MAX FRAME SIZE	PG
UOFDG2	41 1/16	167 X 97 1/2	+25/-25
UOD2.25	41 1/16	167 X 121 1/2	+25/-25



- JAMB SCREW INSTALLATION METHOD:
- UNIT MUST NOT BE IN DIRECT CONTACT WITH EITHER CONCRETE OR TREATED BUCK MATERIAL. IF SHIM SPACE IS LESS THAN 1/8" WRAPPING THE JAMBS AND HEAD JAMBS WITH WINDOW FLASHING TAPE IS REQUIRED AS A BARRIER BETWEEN THE UNIT AND CONCRETE OR TREATED LUMBER.
 - SECURE THE JAMBS WITH #10 X 3" SCREWS 6" FROM EACH CORNER AND 15" OC
 - SECURE THE HEAD JAMB WITH STRUCTURAL BRACKETS 6" FROM EACH CORNER AND 15" OC
 - MINIMUM OF 2 PER SIDE.
 - SHIM AT EACH SCREW LOCATION
 - APPLY #8 X 1-1/2" SCREW THROUGH SILL 15" OC
 - NAIL FIN SHOWN BUT IS OPTIONAL

FOR OPERATING UNITS ONLY

- APPLY TWO #10 X 3" SCREWS PER HEADER STRIKE
- APPLY ONE #10 X 3" SCREW INTO EACH HEADER STATIONARY PLATE

- NOTES:
1. THIS PRINT IS FOR STRUCTURAL PERFORMANCE ONLY. FOR FLASHING & SEALING REQUIREMENTS, REFER TO THE INSTALLATION INSTRUCTIONS.
- SHIMS:
- A SHIM MUST BE PLACED 4-6" FROM EACH CORNER.
 - ALL OTHERS MUST BE PLACED A MAX OF 15 INCHES APART.
3. IF CHEMICALLY TREATED LUMBER IS USED FOR BUCK MATERIAL, FASTENERS INTO THE BUCK MUST BE A MINIMUM OF 0.90 OZ/FT^2 ZINC HOT DIPPED GALVANIZED OR STAINLESS STEEL TYPE 304 OR 316.
- USED THROUGH FRAME HARDWARE

CATEGORY:
SWINGING FRENCH DOO, SWINGING DOOR,

UNIT TYPE:
UOD2.25, UOFD G,

			UNSPECIFIED TOLERANCES		MARVIN  RESEARCH & DEVELOPMENT				
8	-----	STRUCTURAL BRACKET	DECIMALS:	ANGLE DEG:	COLLECTION: ULTIMATE				
7	-----	#10 X 3" SCREW	XX ± .03	± .5	DWG TYPE: INSTALLATION DESCRIPTION: UOD2.25, UOFD2.25 G2, AND UOFD G2 ACC SILL OXXO INSTALLATION				
6	-----	#8 X 1 1/2" SCREW	XXX± .012						
5	-----	#8 X 7/8" SCREW	LINEAL:	FAB LINEAL:	MATERIAL:				
4	-----	2X WOOD BUCK BY OTHERS	+ .125	± NA					
3	-----	SHIM	- .000						
2	-----	#10 X 2 1/2" WOOD SCREW	NA		CHK:	SIZE:	CLASS:	DWG NO:	00141371
1	-----	#8 X 3" WOOD SCREW			APP:	SCALE:	DATE:	DWG BY:	
ITEM NO	REF NO	DESCRIPTION			NA	NA	3/18/2024	MARVINtimbert	1 OF 1