




*GLASS COMPLIES WITH
ASTM E1300*

GLAZING DETAIL

LABEL	DESCRIPTION	CONFIGURATION	MAX PANEL WIDTH	MAX FRAME SIZE	PG
UODFG2		X	41 $\frac{1}{16}$	43 $\frac{7}{16}$ X 97.5	+30/-30
UOD2.25		X	41 $\frac{1}{16}$	43 $\frac{7}{16}$ X 121.5	+30/-30



CATEGORY:

SWINGING FRENCH DOO, SWINGING DOOR,

UNIT TYPE:


UOD2.25, UOFD2.25 G2, UOFDG2,

JAMB SCREW INSTALLATION METHOD:

- UNIT MUST NOT BE IN DIRECT CONTACT WITH EITHER CONCRETE OR TREATED BUCK MATERIAL. IF SHIM SPACE IS LESS THAN 1/8" WRAPPING THE JAMBS AND HEAD JAMBS WITH WINDOW FLASHING TAPE IS REQUIRED AS A BARRIER BETWEEN THE UNIT AND CONCRETE OR TREATED LUMBER.
- SECURE THE JAMBS AND HEAD JAMB WITH #10 X 3" SCREWS 6' FROM EACH CORNER AND 15" OC
- MINIMUM OF 2 PER SIDE.
- SHIM AT EACH SCREW LOCATION
- APPLY #8 X 1-1/2" SCREW THROUGH SILL 15" OC
- NAIL FIN SHOWN BUT IS OPTIONAL

FOR OPERATING UNITS ONLY

- APPLY TWO #10 X 3" SCREWS PER HEADER STRIKE
- APPLY ONE #10 X 2-1/2" SCREW PER HINGE
- APPLY THREE #10 X 3" SCREW PER JAMB STRIKE



NOTES:

1. THIS PRINT IS FOR STRUCTURAL PERFORMANCE ONLY. FOR FLASHING & SEALING REQUIREMENTS, REFER TO THE INSTALLATION INSTRUCTIONS.

SHIMS:

- A SHIM MUST BE PLACED 4-6' FROM EACH CORNER.
- ALL OTHERS MUST BE PLACED A MAX OF 15 INCHES APART.

3. IF CHEMICALLY TREATED LUMBER IS USED FOR BUCK MATERIAL, FASTENERS INTO THE BUCK MUST BE A MINIMUM OF 0.90 OZ/FT^2 ZINC HOT DIPPED GALVANIZED OR STAINLESS STEEL TYPE 304 OR 316.

USED THROUGH FRAME HARDWARE

7	-----	#10 X 3" SCREW
6	-----	#8 X 1 1/2" SCREW
5	-----	#8 X 5/8" SCREW
4	-----	2X WOOD BUCK BY OTHERS
3	-----	SHIM
2	-----	#10 X 2 1/2" WOOD SCREW
1	-----	#8 X 3" WOOD SCREW

ITEM NO	REF NO	DESCRIPTION
---------	--------	-------------

UNSPECIFIED TOLERANCES

DECIMALS:	ANGLE DEG:
XX ± .03	± .5
XXX ± .012	
LINEAL:	FAB LINEAL:
+ .125	± NA
- .000	

MATERIAL:

NA

MARVIN

RESEARCH & DEVELOPMENT

COLLECTION: ULTIMATE

DWG TYPE: INSTALLATION

DESCRIPTION: UOD2.25, UOFD2.25 G2, AND UOFDG2 ACC SILL X,0 INSTALLATION

CHK:

SIZE:

B

CLASS:

MISC

DWG NO: 00141171

APP:

SCALE:

NA

DATE:

12/22/10

DWG BY: MARVIN\timbent

SHEET:

1 OF 1

NOTICE - CONFIDENTIAL INFORMATION

The information in this document is privileged and strictly confidential. The information contained herein shall be used only by Marvin Windows and Doors employees and by those agents or suppliers granted official written permission. If the reader of this document is not the intended recipient, or the employee or agent of the intended recipient, please delete this document from all data storage devices, and destroy all hard copies. Any unauthorized dissemination, distribution, copying or other use of the information contained in this document is strictly prohibited.