

STRUCTURAL SOLUTIONS, P.A.*

Structural Engineering ■ Investigations ■ Consulting

October 12, 2026


Mr. Robert Richardson
Amarr Garage Doors
165 Carriage Court
Winston-Salem, NC 27105

Re: Saltwater Environment Corrosion Resistance Requirements
Project No. 26-001

Mr. Richardson:

When Amarr garage doors are to be installed in areas within 3000 ft. of a saltwater coastline, all fasteners and connectors specified in the approval's installation instruction that connect the product to the structure will be potentially exposed to salt air and shall meet the saltwater environment corrosion resistance requirements of the Florida Building Code 9th Edition (2026) Section 1711, or the Florida Residential Code 9th Edition (2026) Section R332, as applicable.

Sincerely,



Thomas L
Shelmerdine

Digitally signed by Thomas L Shelmerdine
DN: c=US, o=Unaffiliated, dnQualifier=A01410C0000019B469BB84300125111, cn=Thomas L Shelmerdine
Date: 2026.10.12 14:42:50 -04'00'

STRUCTURAL SOLUTIONS, P.A.*

Thomas L. Shelmerdine, PE
Florida PE #48579
President