



EVALUATION REPORT

FLORIDA BUILDING CODE, 8TH EDITION (2023)

Manufacturer: INLAND COATINGS
26259 US-6
Adel, IA 50003
(800) 456-8467
www.inlandcoatings.com

Issued December 13, 2023

Manufacturing Plants: Adel, IA

Quality Assurance: PRI Construction Materials Technologies (QUA9110)

SCOPE

Category: Roofing
Subcategory: Cements -Adhesives-Coatings
Code Edition: Florida Building Code, 8th Edition (2023)
Code Sections: 1507.10.2, 1507.14.3, 1507.15.2
Properties: Physical Properties

REFERENCES

<u>Entity</u>	<u>Report No.</u>	<u>Standard</u>	<u>Year</u>
PRI Construction Materials Technologies (TST5878)	1094T0004	ASTM D 6083	2021

PRODUCT DESCRIPTION

Products	Specification	Description
Inland Coatings RC-2016 - Aldo Coatings Aldocoat 916 - Truco Coatings 7116NF	ASTM D 6083	One-component, solvent-based rubber roof coating that is brush, roller or spray-applied.

APPLICATION

The following notes shall be observed when using the application tables below:

1. All surfaces shall be repaired, clean, dry, and free of debris prior to application.
2. Roof coating may be spray, brush or roller applied.
3. Applications are valid for new and existing roof systems.

Application of RC-2016, Aldocoat 916 or 7116NF	
Substrate (New or Existing)	Minimum Application Rate
Galvanized Steel Metal Panels	Applied in one coat at a minimum rate of 1.0 gal/100ft ²
Aluminum Metal Panels	Applied in one coat at a minimum rate of 1.0 gal/100ft ²

LIMITATIONS

1. This evaluation is not for use inside the HVHZ.
2. Fire classification is not within the scope of this evaluation.
3. Structural integrity of the roofing substrate or assembly is not within scope of this evaluation. Refer to the appropriate product approval for installation of these components within an *Approved* roof assembly.
4. Installation of the evaluated products shall be in strict compliance with this evaluation report, the FBC, and the manufacturer's published installation instructions. In the event of conflict, the more restrictive and FBC compliant installation shall be enforced.
5. This product shall not be applied in inclement weather conditions.
6. This product shall not be applied over asphaltic shingles, metal shingles, fiber-cement shingles, quarry slate, cement or clay roofing tile, or wood shingles or shakes.
7. This product may be used as described in other current FBC product approval documents.
8. Refer to manufacturer's published instructions for proper storage and shelf life considerations.
9. All products listed in this report shall be manufactured under a quality assurance program in compliance with Rule 61G20-3.

COMPLIANCE STATEMENT

The products evaluated herein by Zachary R. Priest, P.E have demonstrated compliance with the Florida Building Code, 8th Edition (2023) as evidenced in the referenced documents submitted by the named manufacturer.



This item has been
digitally signed and
sealed by Zachary R.
Priest, PE, on 12/13/2023.

Printed copies of this
document are not
considered signed and
sealed and the signature
must be verified on any
electronic copies.


Digitally signed by Zachary R. Priest
CREEK Technical Services, LLC

2023.12.13
13:08:34
-05'00'

Zachary R. Priest, P.E.
Florida Registration No. 74021
Organization No. ANE9641

CERTIFICATION OF INDEPENDENCE

CREEK Technical Services, LLC does not have, nor will it acquire, a financial interest in any company manufacturing or distributing products under this evaluation.

CREEK Technical Services, LLC is not owned, operated, or controlled by any company manufacturing or distributing products under this evaluation.

Zachary R. Priest, P.E. does not have, nor will acquire, a financial interest in any company manufacturing or distributing products under this evaluation.

Zachary R. Priest, P.E. does not have, nor will acquire, a financial interest in any other entity involved in the approval process of the product.

END OF REPORT