

PanoramAH! AMERICA, LLC

ah!38 TILT & TURN WINDOW (WZ3)(IMPACT)

GENERAL NOTES:

- THE PRODUCT SHOWN HEREIN IS DESIGNED AND MANUFACTURED TO COMPLY WITH THE CURRENT EDITION OF THE FLORIDA BUILDING CODE (FBC), **EXCLUDING** HVHZ AND HAS BEEN EVALUATED ACCORDING TO THE FOLLOWING:
 - TAS 201-94
 - TAS 202-94
 - TAS 203-94
- ADEQUACY OF THE EXISTING STRUCTURAL CONCRETE/MASONRY, 2X FRAMING, AND METAL FRAMING AS A MAIN WIND FORCE RESISTING SYSTEM CAPABLE OF WITHSTANDING AND TRANSFERRING APPLIED PRODUCT LOADS TO THE FOUNDATION IS THE RESPONSIBILITY OF THE ENGINEER OR ARCHITECT OF RECORD FOR THE PROJECT OF INSTALLATION.
- 1X AND 2X BUCKS (WHEN USED) SHALL BE DESIGNED AND ANCHORED TO PROPERLY TRANSFER ALL LOADS TO THE STRUCTURE. BUCK DESIGN AND INSTALLATION IS THE RESPONSIBILITY OF THE ENGINEER OR ARCHITECT OF RECORD FOR THE PROJECT OF INSTALLATION.
- THE INSTALLATION DETAILS DESCRIBED HEREIN ARE GENERIC AND MAY NOT REFLECT ACTUAL CONDITIONS FOR A SPECIFIC SITE. IF SITE CONDITIONS CAUSE INSTALLATION TO DEVIATE FROM THE REQUIREMENTS DETAILED HEREIN, A LICENSED ENGINEER OR ARCHITECT SHALL PREPARE SITE SPECIFIC DOCUMENTS FOR USE WITH THIS DOCUMENT.
- APPROVED IMPACT PROTECTIVE SYSTEM **IS NOT REQUIRED** ON THIS PRODUCT IN AREAS REQUIRING IMPACT RESISTANCE IN WIND ZONE 3 OR LESS.
- APPROVED IMPACT PROTECTIVE SYSTEM **IS REQUIRED** ON THIS PRODUCT IN AREAS REQUIRING IMPACT RESISTANCE IN WIND ZONE 4.
- WINDOW FRAME MATERIAL: ALUMINUM 6063-T5
- GLASS MEETS THE REQUIREMENTS OF ASTM E1300 GLASS CHARTS. SEE SHEET 5 FOR GLAZING DETAIL.

INSTALLATION NOTES:

- TWO (2) INSTALLATION ANCHORS ARE REQUIRED AT EACH ANCHOR LOCATION SHOWN, UNLESS OTHERWISE STATED ON SHEET 4.
- INSTALL INDIVIDUAL INSTALLATION ANCHORS WITHIN A TOLERANCE OF ±1/4 INCH THE DEPICTED LOCATION & SPACING IN THE ANCHOR LAYOUT DETAILS (I.E., WITHOUT CONSIDERATION OF TOLERANCES). TOLERANCES ARE NOT CUMULATIVE FROM ONE INSTALLATION ANCHOR TO THE NEXT.
- SHIM AS REQUIRED AT EACH INSTALLATION ANCHOR WITH LOAD BEARING SHIM(S). MAXIMUM ALLOWABLE SHIM STACK TO BE 3/8 INCH. SHIM WHERE SPACE OF 1/16 INCH OR GREATER OCCURS. SHIM(S) SHALL BE CONSTRUCTED OF HIGH DENSITY PLASTIC OR BETTER.
- MINIMUM EMBEDMENT AND EDGE DISTANCE EXCLUDE WALL FINISHES, INCLUDING BUT NOT LIMITED TO STUCCO, FOAM, BRICK VENEER, AND SIDING.
- INSTALLATION ANCHORS AND ASSOCIATED HARDWARE MUST BE MADE OF CORROSION RESISTANT MATERIAL OR HAVE A CORROSION RESISTANT COATING.
- FOR MASONRY OR CONCRETE OPENINGS, A 1X WOOD BUCK MAY BE USED (OPTIONAL) AS LONG AS THE MINIMUM EMBEDMENT AND EDGE DISTANCE REQUIREMENTS ARE STILL MET WITHIN THE CORRESPONDING HOST SUBSTRATE. SEE GENERAL NOTE #3 ON SHEET 1 FOR MORE INFORMATION.
- FOR HOLLOW BLOCK AND GROUT FILLED BLOCK, DO NOT INSTALL INSTALLATION ANCHORS INTO MORTAR JOINTS. EDGE DISTANCE IS MEASURED FROM FREE EDGE OF BLOCK OR EDGE OF MORTAR JOINT INTO FACE SHELL OF BLOCK.
- INSTALLATION ANCHORS SHALL BE INSTALLED IN ACCORDANCE WITH ANCHOR MANUFACTURER'S INSTALLATION INSTRUCTIONS, AND ANCHORS SHALL NOT BE USED IN SUBSTRATES WITH STRENGTHS LESS THAN THE MINIMUM STRENGTH SPECIFIED BY THE ANCHOR MANUFACTURER.

TABLE OF CONTENTS	
SHEET	SHEET DESCRIPTION
1	GENERAL NOTES AND INSTALLATION NOTES
2	"XX" ELEVATION & DESIGN PRESSURE TABLE
3	"X" ELEVATION & DESIGN PRESSURE TABLE
4	ANCHOR LAYOUTS
5	VERTICAL SECTIONS & GLAZING DETAIL
6	HORIZONTAL SECTIONS
7	ANCHOR DETAILS & ANCHOR SCHEDULE

DESIGN PRESSURE RATING (PSF)				
CONFIGURATION	WIDTH (IN.)	HEIGHT (IN.)	DESIGN PRESSURE	MISSILE IMPACT RATING
XX	SEE TABLE ON SHEET 2			LARGE & SMALL MISSILE IMPACT
X	SEE TABLE ON SHEET 3			



1000 WOODBURY ROAD, STE. 206
WOODBURY, NY 11797
PH: (631)683-8580

TITLE: ah!38 TILT & TURN WINDOW (WZ3)(IMPACT) GENERAL NOTES & INSTALLATION NOTES


PREPARED BY: BUILDING DROPS, INC.
1900 NE MIAMI COURT, STE. 2-15
MIAMI, FL 33132
PH: (954)399-8478
FAX: (954)744-4738
WEB: www.buildingdrops.com



REMARKS	BY	DATE

THE INSTALLATION DETAILS DESCRIBED HEREIN ARE GENERIC AND MAY NOT REFLECT ACTUAL CONDITIONS FOR A SPECIFIC SITE. IF SITE CONDITIONS CAUSE INSTALLATION TO DEVIATE FROM THE REQUIREMENTS DETAILED HEREIN, A LICENSED ENGINEER OR ARCHITECT SHALL PREPARE SITE SPECIFIC DOCUMENTS FOR USE WITH THIS DOCUMENT.

Digitally signed by Hermes F. Norero, P.E.
Reason: I am approving this document
Date: 2024.04.13 15:28:56 -04'00'



FL #: **FL46512**

DATE: **04.18.2024**

DWG. BY: **SH** CHK. BY: **HFN**


SCALE: **NTS**

DWG. #: **PAN021**

SECTION: **1**

OF 7

c:\users\sebastianherrerros\building drops, inc\building drops\landing - common\projects\panoramahi\america ltc\bc-21-0429 - fhc submittal - ah\38 fixed window, ah\ tilt & turn\dwgs\l&t window\pan021.dwg 7/23/2024 2:14 PM



"XX" ELEVATION
TYPICAL

D.L.O. HEIGHT = FRAME HEIGHT - 4.9375"
D.L.O. WIDTH = FRAME WIDTH/2 - 4.00"
SASH HEIGHT = FRAME HEIGHT - 1.1875"
SASH WIDTH = FRAME WIDTH/2 + 0.4375"

FRENCH TILT & TURN ALLOWABLE DESIGN PRESSURE (PSF)												
FRAME HEIGHT (IN.)	FRAME WIDTH (IN.)											
		32	44	56	68	80	92	104	116	128	140	152
	36	80.0	80.0	68.6	65.0	65.0	65.0	65.0	65.0	65.0	65.0	65.0
	42	80.0	80.0	68.6	65.0	65.0	61.9	61.9	61.9	61.9	-	-
	48	80.0	80.0	68.6	65.0	65.0	56.5	54.2	54.2	-	-	-
	54	80.0	80.0	65.0	65.0	65.0	56.5	50.0	-	-	-	-
	60	80.0	80.0	65.0	65.0	65.0	56.5	-	-	-	-	-
	66	65.0	65.0	65.0	65.0	65.0	-	-	-	-	-	-
	72	65.0	65.0	65.0	65.0	65.0	-	-	-	-	-	-
	78	65.0	65.0	65.0	57.2	-	-	-	-	-	-	-
	84	65.0	65.0	53.8	45.3	-	-	-	-	-	-	-
	90	65.0	54.6	43.5	-	-	-	-	-	-	-	-
	96	61.0	44.8	35.7	-	-	-	-	-	-	-	-
	102	50.8	37.3	29.6	-	-	-	-	-	-	-	-
	108	42.8	31.3	-	-	-	-	-	-	-	-	-
	114	36.3	26.6	-	-	-	-	-	-	-	-	-
	120	31.1	22.8	-	-	-	-	-	-	-	-	-

PANORAMAH!
unlimited perspective

1000 WOODBURY ROAD, STE. 206
WOODBURY, NY 11797
PH: (631)683-8580


TITLE: ah\38 TILT & TURN
WINDOW
(WZ3)/(IMPACT)
"XX" ELEVATION & DESIGN
PRESSURE TABLE

PREPARED BY:
BUILDING DROPS, INC.
1900 NE MIAMI COURT, STE. 2-15
MIAMI, FL 33132
PH: (954)399-8478
FAX: (954)744-4738
WEB: www.buildingdrops.com



REMARKS	BY	DATE

THE INSTALLATION DETAILS DESCRIBED HEREIN ARE
GENERIC AND MAY NOT REFLECT ACTUAL CONDITIONS FOR
A SPECIFIC SITE. IF SITE CONDITIONS CAUSE INSTALLATION
TO DEVIATE FROM THE REQUIREMENTS DETAILED HEREIN, A
LICENSED ENGINEER OR ARCHITECT SHALL PREPARE SITE
SPECIFIC DOCUMENTS FOR USE WITH THIS DOCUMENT.



FL #:

FL46512

DATE: 04.18.2024

DWG. BY: SH
CHK. BY: HFN


SCALE: NTS

DWG. #: PAN021

SECTION:

2

c:\users\sebastianherrerros\building_drops_in\building_drops_in\common\projects\panoramahi\america\lca\lca-21-0429-fbc-submittal-ah\38-fixed_window_ah\tilt&turn\dwgs\pan021.dwg 7/23/2024 2:14 PM



"X" ELEVATION
TYPICAL

D.L.O. HEIGHT = FRAME HEIGHT - 4.9375"
D.L.O. WIDTH = FRAME WIDTH - 4.9375"
SASH HEIGHT = FRAME HEIGHT - 1.1875"
SASH WIDTH = FRAME WIDTH - 1.125"

SINGLE TILT & TURN ALLOWABLE DESIGN PRESSURE (PSF)												
FRAME HEIGHT (IN.)	FRAME WIDTH (IN.)											
		16	22	28	34	40	46	52	58	64	70	76
	36	80.0	80.0	68.6	65.0	65.0	65.0	65.0	65.0	65.0	65.0	65.0
	42	80.0	80.0	68.6	65.0	65.0	61.9	61.9	61.9	61.9	-	-
	48	80.0	80.0	68.6	65.0	65.0	56.5	54.2	54.2	-	-	-
	54	80.0	80.0	65.0	65.0	65.0	56.5	50.0	-	-	-	-
	60	80.0	80.0	65.0	65.0	65.0	56.5	-	-	-	-	-
	66	80.0	65.0	65.0	65.0	65.0	-	-	-	-	-	-
	72	80.0	65.0	65.0	65.0	65.0	-	-	-	-	-	-
	78	80.0	65.0	65.0	65.0	-	-	-	-	-	-	-
	84	80.0	65.0	65.0	65.0	-	-	-	-	-	-	-
	90	80.0	65.0	65.0	-	-	-	-	-	-	-	-
	96	65.0	65.0	65.0	-	-	-	-	-	-	-	-
	102	65.0	65.0	65.0	-	-	-	-	-	-	-	-
	108	65.0	65.0	-	-	-	-	-	-	-	-	-
	114	65.0	65.0	-	-	-	-	-	-	-	-	-
	120	65.0	65.0	-	-	-	-	-	-	-	-	-

PANORAMAH!
unlimited perspective

1000 WOODBURY ROAD, STE. 206
WOODBURY, NY 11797
PH: (631)683-8580


TITLE: ah!38 TILT & TURN
WINDOW
(WZ3)/(IMPACT)
"X" ELEVATION & DESIGN
PRESSURE TABLE

PREPARED BY:
BUILDING DROPS, INC.
1900 NE MIAMI COURT, STE. 2-15
MIAMI, FL 33132
PH: (954)399-8478
FAX: (954)744-4738
WEB: www.buildingdrops.com



REMARKS	BY	DATE

THE INSTALLATION DETAILS DESCRIBED HEREIN ARE
GENERIC AND MAY NOT REFLECT ACTUAL CONDITIONS FOR
A SPECIFIC SITE. IF SITE CONDITIONS CAUSE INSTALLATION
TO DEVIATE FROM THE REQUIREMENTS DETAILED HEREIN, A
LICENSED ENGINEER OR ARCHITECT SHALL PREPARE SITE
SPECIFIC DOCUMENTS FOR USE WITH THIS DOCUMENT.



FL #:
FL46512

DATE: **04.18.2024**

DWG. BY: **SH** CHK. BY: **HFN**

SCALE: **NTS**

DWG. #: **PAN021**

SECTION:
3

OF 7

TITLE: *ch138 TILT & TURN WINDOW (WZ3)/(IMPACT)*
ANCHOR LAYOUTS

REMARKS	BY	DATE

HERMES F. NORERO, P.E.
 FLORIDA #E-1047778
 BUILDINGDROPS, INC
 1900 NE MIAMI COURT, STE. 2-15
 MIAMI, FL 33132
 FBPE CERT. OF AUTHORIZATION NO. 29578

DATE: 04.18.2024

SCALE: **NTS**

SECTION:

OF 7




NOTE: TWO (2) ANCHORS PER LOCATION.



REMARKS	BY	DATE

THE INSTALLATION DETAILS DESCRIBED HEREIN ARE GENERIC AND MAY NOT REFLECT ACTUAL CONDITIONS FOR A SPECIFIC SITE. IF SITE CONDITIONS CAUSE INSTALLATION TO DEVIATE FROM THE REQUIREMENTS DETAILED HEREIN, LICENSED ENGINEER OR ARCHITECT SHALL PREPARE SITE SPECIFIC DOCUMENTS FOR USE WITH THIS DOCUMENT.



FL #: **FL46512**

DATE: 04.18.2024

DWG. BY: SH	CHK. BY: HFN
-----------------------	------------------------

SCALE: NTS

DWG. #: PAN021

SECTION:

6

