


		PRIMARY ANCHOR (TO SUBSTRATE CONDITION)						"BACK" ANCHOR (TRIM TO FRAME)				
SUBSTRATE	LOCATION	HARDWARE (ACCEPTABLE TRADE NAME OR EQUIVALENT)	O.C. SPACING (MAX)	END DISTANCE (MAX)	EMBEDMENT (MIN)	SUBSTRATE EDGE DISTANCE (MIN)	d1 INSTALL DIMENSION	HARDWARE (ACCEPTABLE TRADE NAME OR EQUIVALENT)	O.C. SPACING (MAX)	END DISTANCE (MAX)	EMBEDMENT (MIN)	d2 INSTALL DIMENSION
WOOD SG = 0.42	HEAD	1/4" Ø LAG SCREW, FULL BODY	12"	4"	1-1/2"	1"	13/16"	#10-16 OR #10-24 S.S. CONDITION CW OR SAE GR. 5 STEEL PAN HEAD SCREW	12"	4"	3 THREADS	1/2"
	SILL											
	JAMB											
CONCRETE 3,000 PSI	HEAD	1/4" Ø HILTI KWIK HUS-EZ (KH-EZ)	15"	4"	2-1/2"	1-3/4"	13/16"					
	SILL		15"									
	JAMB		16"									
CONCRETE 4,000 PSI	HEAD	1/4" Ø HILTI KWIK HUS-EZ (KH-EZ)	18"	4"	2-1/2"	1-3/4"	13/16"					
	SILL		18"									
	JAMB		18"									
CMU (GROUT FILLED) f'm = 1,500 PSI	HEAD	1/4" Ø HILTI KWIK HUS-EZ (KH-EZ)	12"	4"	2-1/2"	1-1/2"	13/16"					
	SILL		8"									
	JAMB		12"									
STEEL STUD (18 ga. 33ksi)	HEAD	1/4"-14 SAE GR. 5 HEX/HWH HILTI KWIK FLEX OR DEWALT DRIL-FLEX	12"	4"	3 THREADS	9/16"	13/16"					
	SILL											
	JAMB											



1. Installations depicted comply with:
Florida Building Code - 8th Ed. (FBC 2023)
International Building Code (IBC 2021)
National Design Specifications (ANSI/AWC NDS 2018)
Aluminum Design Manual (ADM 2020)
Cold-Formed Steel Design Manual (AISI-S100 2020)

2. The installation depicted in this drawing and all calculations are based on a maximum size and design wind pressure rating listed below. The products **have** been proven for resistance to Large Missile Impact per ASTM E1886 / E1996 Missile Level D.

Test Assembly Size: **103-3/4" x 99"** Design pressure: **+/- 70 psf**

3. Lag screws shall be used for a wood substrate. Screw materials and dimensions shall meet the requirements of ANSI / ASME Standard B18.2.1. All lag screw conditions must be pre-drilled with hole diameters of 40-70% of the fastener diameter. Wood buck installations are assumed to use 2 X S-P-F (G= 0.42) or denser. Tapered or partial bucks are not allowed.
4. Approved screw anchors shall be used for concrete substrate. Anchor embedment shall be as indicated herein. Install per ESR-3027 requirements. Concrete installations are assumed to be at least f'c = 3,000 (or 4,000) psi, normal weight concrete, with a minimum thickness of 4-1/2".
5. Approved screw anchors shall be used for CMU substrate. Anchor materials and dimensions shall meet the requirements of ICC-ES AC106 - Acceptance Criteria for Predrilled Fasteners (Screw Anchors) in masonry elements. Anchor embedment shall be as indicated herein. Install per ESR-3056 requirements. Concrete masonry installations are assumed at least ASTM C90, Type II, Grade N, with f'm = 1,500 psi, and type M or S mortar.

6. Approved self-drilling screws shall be used for steel stud substrate. All fasteners installed in steel studs shall be SAE grade 5 or better. Steel stud installations assume 18 gauge, 33 ksi studs and follow AISI-S100 rules and procedures.





7. Maximum shim thickness of 1/4" permitted at each fastener location. Shims shall be non-compressible and load-bearing type.

8. Drawings depict details necessary to meet structural load requirements, but do not address air infiltration, water penetration, intrusion or thermal performance requirements of the installation. See manufacturer's Installation Instructions for sealing, flashing, drainage and other requirements.





9. Minimum fastener on center spacing to be coordinated with fastener manufacturer's technical data for the expected substrate.

10. All substrate types shall be secured to the building structure to resist all design loads, and shall have widths that exceed the window frame widths.





11. Only the 1450 Series is shown in the various sections for convenience. Anchorage requirements apply equally to 1450S Series.



HEAD



SILL




JAMBS

RICE
ENGINEERING

105 School Creek Trail
Luxemburg, WI 54217
Phone: (920) 617-1042
Fax: (920) 617-1100
www.rice-inc.com

Florida Firm No: F-01000005061
Certificate of Authorization: #9090
Wayne K. Helmila
Registration No: 59092



09/03/2024
COA: 9090

Wayne K Helmila

Digitally signed by Wayne K Helmila
DN: cn=Wayne K Helmila,
dnQualifier=A01410C0000018CDB8F4AFB001A652B,
o=Wisconsin, c=US
Date: 2024.09.03 08:32:19-05'00'

Rev.	Description	Date
△		
△		
△		
△		
△		

Scale: NONE Drawn by: B. FOOTE

Winco Window Co.
6200 Maple Ave.
St. Louis, MO 63130

PHONE: 314-725-8088

Winco Product:

1450-1450S FIXED & CASEMENT



Installation:

ANCHORAGE: SNAP TRIM SHT 1 OF 2

Certification:

LMI - 1450-1450S - D MISSILE

TABLE 2: ANCHOR CLUSTER CENTERED ON MULLION SUPERCEDES NORMAL O.C. SPACING WHERE CLUSTER OCCURS							
PRIMARY ANCHOR (TO SUBSTRATE CONDITION)					"BACK" ANCHOR (TRIM TO FRAME)		
SUBSTRATE	LOCATION	HARDWARE (ACCEPTABLE TRADENAME OR EQUIVALENT)	NUMBER OF ANCHORS IN CLUSTER	O.C. SPACING	HARDWARE (ACCEPTABLE TRADE NAME OR EQUIVALENT)	NUMBER OF ANCHORS IN CLUSTER	O.C. SPACING (MAX)
WOOD SG = 0.42	HEAD	1/4" Ø LAG SCREW, FULL BODY	6	4"	#10-16 OR #10-24 S.S. CONDITION CW OR SAE GR. 5 STEEL PAN HEAD SCREW	5	4"
	SILL						
CONCRETE 3,000 PSI	HEAD	1/4" Ø HILTI KWIK HUS-EZ (KH-EZ)	4	5"			
	SILL						
CONCRETE 4,000 PSI	HEAD	1/4" Ø HILTI KWIK HUS-EZ (KH-EZ)	4	5"			
	SILL						
CMU (GROUT FILLED) f _m = 1,500 PSI	HEAD	1/4" Ø HILTI KWIK HUS-EZ (KH-EZ)	6	4"			
	SILL		8				
STEEL STUD (18 ga. 33ksi)	HEAD	1/4"-14 SAE GR. 5 HEX/HWH HILTI KWIK FLEX OR DEWALT DRIL-FLEX	7	4"			
	SILL						




See Sheet 1 for general notes.


RICE
ENGINEERING

105 School Creek Trail
Luxemburg, WI 54217
Phone: (920) 617-1042
Fax: (920) 617-1100
www.rice-inc.com

Florida Firm No: F-01000005061
Certificate of Authorization: #9090
Wayne K. Helmila
Registration No: 59092



SECTION A





SECTION B: ANCH4 @ SILL (HEAD SIMILAR)

Non-Structural Mullion Installation Anchors
Mullion Loading Transferred through
adjacent window frames and resolved by
the anchor cluster in the installation trim

ATTACHMENTS AT MULLION

MULLION CLAMP
ANCHORAGE
TO MULLION &
FRAME



09/03/2024
COA: 9090

Rev.	Description	Date
△		
△		
△		
△		
△		
Scale: NONE Drawn by: B. FOOTE		
Winco Window Co. 6200 Maple Ave. St. Louis, MO 63130		
PHONE: 314-725-8088		
WINCO Product: 1450-1450S FIXED & CASEMENT		
Installation: ANCHORAGE: SNAP TRIM SHT. 2 OF 2		
Certification: LMI - 1450-1450S - D MISSILE		