



NOTES:

1. GLAZED LITE OPTIONS IN MOLDED FRAMES:
- .125 DSB TEMPERED GLASS ALLOWED
 - TALLEST LITES: MIN DSB GLASS
 - CLEAR OPENING SIZE: MAX WD=49"; MAX HT=19"
 - (16) MIN QTY SCREWS #8X1
 - DECORATIVE TRIM INSERTS ALLOWED.
 - (1) GLAZING SECTION ALLOWED IN TOP SECTION.
 - NOT IMPACT RESISTANT
2. VINYL OR WOOD DOOR STOP SECURED WITH 6D NAILS A MAXIMUM OF 6" O.C. MUST OVERLAP TOP AND BOTH ENDS OF PANELS MINIMUM 7/16" TO MEET NEGATIVE PRESSURES.
3. SLIDE LOCKS, OR LOCK BAR LOCK REQUIRED.
4. FACER STEEL TO HAVE A MINIMUM 27 GA THICKNESS AND BACKER STEEL TO HAVE A MINIMUM 29 GA THICKNESS.
5. A 4-1/2" x 6" x 21 GA BACKER PLATE IS TO BE LOCATED AT EVERY INTERMEDIATE AND OUTER END HINGE LOCATION.
6. THE DESIGN OF THE SUPPORTING STRUCTURAL ELEMENTS SHALL BE THE RESPONSIBILITY OF THE PROFESSIONAL OF RECORD FOR THE BUILDING OR STRUCTURE AND IN ACCORDANCE WITH CURRENT BUILDING CODES FOR THE LOADS LISTED ON THIS DRAWING.
7. DOOR JAMB TO BE MINIMUM 2x6 SOUTHERN PINE LUMBER. REFER TO JAMB CONNECTION SUPPLEMENT FOR ATTACHMENT TO SUPPORTING STRUCTURE.
8. COMPLIES WITH THE REQUIREMENTS OF IBC/IRC 2018 AND 2021.
9. PROFESSIONAL ENGINEER SEAL PROVIDED ONLY FOR VERIFICATION OF WINDLOAD CONSTRUCTION DETAILS.



REVISIONS				
ER	REV	DESCRIPTION	DATE	APVL
WL022	-	INITIAL RELEASE	2/14/25	AR
WL022	A	UPDATED WINDOW SIZING	5/9/25	AR



SUPERIMPOSED DESIGN PRESSURE LOADS ON SUPPORTING STRUCTURE		
DOOR WIDTH	DOOR HEIGHT	UNIFORM LOAD EACH JAMB (PLF)
9'-0"	ALL	+69.3/-80.1
10'-0"	ALL	+77.0/-89.0

JAMB BRACKET SCHEDULE				
DOOR HEIGHT	NO. OF SECTIONS	NO. OF JAMB BRACKETS (EACH JAMB)	TRACK TYPE	LOCATION OF CENTERLINE OF JAMB BRACKETS MEASURED FROM BOTTOM OF TRACK (ALL DIMENSIONS ± 2")
7'-0"	3	2	FAT	13" (JB), 45" (JB)
8'-0"	4	3	FAT	10" (JB), 48" (JB), 66" (JB)
> 8'-0"				SEE NOTE BELOW



NOTE:

(JB-US) FOLLOWING DIMENSION DENOTES SLOTTED JAMB BRACKET ATTACHED TO TRACK WITH 1/4-20x9/16" TRACK BOLT AND NUT AS SHOWN ABOVE.










ALL DOORS GREATER THAN 8' IN HEIGHT REQUIRE USE OF CONTINUOUS WALL ANGLE. SEE SUPPLEMENT TRACK CHART FOR DETAILS.

Digitally signed by John E Scates
Date: 2025.05.15 14:30:29 -05'00'

JOHN E. SCATES, PE
8811 TEEL PKWY #100-5175
FRISCO, TX 75036
FL PE 51737
TX PE 56308 / F2203
PRINTED COPIES OF THIS DOCUMENT ARE NOT CONSIDERED SIGNED AND SEALED AND THE SIGNATURE MUST BE VERIFIED ON ANY ELECTRONIC COPIES.



STATIC PRESSURE RATINGS		APPROVED SIZES		SCALE: N.T.S.		SIZE: A	
DESIGN (PSF):	+15.4/-17.8	MAX WIDTH:	10'-0"	DATE	NAME		
TEST (PSF):	+23.1/-26.7	MAX HEIGHT:	14'-0"	DRAWN	1/6/25	AR	
IMPACT/CYCLIC RATED (YES/NO):	NO	MAX SECTION HEIGHT: 28"	CHECKED				
MODELS 7540/5800				SHEET 1 OF 4			
WINDLOAD SPECIFICATION OPTION CODE 0554				DRAWING PART NO. 412939		REV. A	




The Genuine. The Original.



OVERHEAD DOOR CORP
2501 S STATE HWY 121 BUS. STE 200
LEWISVILLE, TX 75067
1-800-929-DOOR

STATIC PRESSURE RATINGS		APPROVED SIZES		SCALE: N.T.S.		SIZE: A	
DESIGN (PSF):	+15.4/-17.8	MAX WIDTH:	10'-0"	DATE		NAME	
TEST (PSF):	+23.1/-26.7	MAX HEIGHT:	14'-0"	DRAWN	1/6/25	AR	
IMPACT/CYCLIC RATED (YES/NO):	NO	MAX SECTION HEIGHT: 28"	CHECKED				
MODELS 7540/5800					SHEET 2 OF 4		
WINDLOAD SPECIFICATION OPTION CODE 0554					DRAWING PART NO.	REV.	
					412939	A	


(7) SECTION DOORS
WITH (6) 2" 20 GA
80 KSI U-BARS —
LOCATED AS SHOWN




OPTIONAL WALL ANGLE TRACK



LOW HEADROOM
TRACK DETAIL




DOOR HEIGHT



VERTICAL LIFT
TRACK DETAIL

ATTACH U-BAR WITH (1)
1/4-14x7/8" SELF DRILLING
CRIMPITE SCREW AT EACH HOLE
LOCATION. THERE SHALL BE A TOTAL
OF (18) SCREWS PER U-BAR. 

NOTE: U-BARS LOCATED AT THE TOP OF THE SECTION SHALL BE PLACED ON TOP OF THE BOTTOM HINGE LEAFS AS SHOWN (NOT APPLICABLE TO TOP SECTION)
(SEE DETAIL E)




(5) SECTION DOORS
WITH (4) 2" 20 GA
80 KSI U-BARS —
LOCATED AS SHOWN

(4) SECTION DOORS
WITH (3) 2" 20 GA
80 KSI U-BARS —
LOCATED AS SHOWN

(3) SECTION DOORS
WITH (2) 2" 20 GA
80 KSI U-BARS —
LOCATED AS SHOWN


(6) SECTION DOORS
WITH (5) 2" 20 GA
80 KSI U-BARS —
LOCATED AS SHOWN




OVERHEAD DOOR CORP
2501 S STATE HWY 121 BUS, STE 200
LEWISVILLE, TX 75067
1-800-929-DOOR

STATIC PRESSURE RATINGS		APPROVED SIZES		SCALE: N.T.S.		SIZE: A	
DESIGN (PSF): +15.4/-17.8		MAX WIDTH: 10'-0"		DATE		NAME	
TEST (PSF): +23.1/-26.7		MAX HEIGHT: 14'-0"		DRAWN 1/6/25		AR	
IMPACT/CYCLIC RATED (YES/NO): NO		MAX SECTION HEIGHT: 28"		CHECKED			
MODELS 7540/5800				SHEET 3 OF 4			
WINDLOAD SPECIFICATION OPTION CODE 0554				DRAWING PART NO. 412939		REV. A	

NOTES: (UNLESS OTHERWISE SPECIFIED)
1. FOR DIMENSIONS AND NOTE REFERENCES, REFER TO INDIVIDUAL DRAWINGS.




TOP FIXTURE DETAILS




2" STRUT OPEN WL (UBAR)
80 KSI MIN. YIELD STRENGTH, 2" X 20 GA

STRUT DETAILS




BOTTOM FIXTURE, BB-12
14 GA

BOTTOM FIXTURE DETAILS




HINGE DETAILS




SIDE LOCK ASSY

LOCK DETAILS




ROLLER ASSY, 2" (STEEL ROLLER)
10-BALL




ROLLER ASSY, 2" (NYLON ROLLER)
11-BALL (WHITE)

ROLLER STEM ASSY DETAILS



JAMB BRACKET
16 GA

BRACKET DETAILS



The Genuine. The Original.



OVERHEAD DOOR CORP
2501 S STATE HWY 121 BUS, STE 200
LEWISVILLE, TX 75067
1-800-929-DOOR

STATIC PRESSURE RATINGS		APPROVED SIZES		SCALE: N.T.S.		SIZE: A	
DESIGN (PSF):	+15.4/-17.8	MAX WIDTH:	10'-0"	DATE		NAME	
TEST (PSF):	+23.1/-26.7	MAX HEIGHT:	14'-0"	DRAWN	1/6/25	AR	
IMPACT/CYCLIC RATED (YES/NO):	NO	MAX SECTION HEIGHT: 28"	CHECKED				
MODELS 7540/5800					SHEET 4 OF 4		
WINDLOAD SPECIFICATION OPTION CODE 0554					DRAWING PART NO. 412939		REV. A