

QUICKMOUNT ROCKIT RAIL-LESS PHOTOVOLTAIC PANEL RACKING SYSTEM
WITH QUICKMOUNT GF1 COMP SLIDE ROOF ATTACHMENTS



GENERAL NOTES:

- 1. THIS SYSTEM MEETS ALL OF THE REQUIREMENTS OF THE 8TH EDITION (2023) FLORIDA BUILDING CODE, INCLUDING THE HVHZ PROVISIONS.
- 2. THIS SYSTEM HAS BEEN TESTED PER TAS 100(A) AND ASTM D7147. IT IS NOT A PART OF THE BUILDING ENVELOPE, AND IMPACT RESISTANCE IS NOT REQUIRED.
- 3. THIS SYSTEM SHALL BE INSTALLED PER THE QUICKMOUNT ROCKIT INSTALLATION MANUAL.
- 4. THIS SYSTEM IS DESIGNED TO WORK WITH SEVERAL TYPES OF PV PANELS. THE DESIGN OF THE PANELS IS BY OTHERS AND IS NOT A PART OF THIS APPROVAL.
- 5. THE DESIGN OF THE ROOF SUBSTRATE IS THE RESPONSIBILITY OF THE ENGINEER OF RECORD OR OTHER SPECIALTY ENGINEER, AND IS NOT A PART OF THIS APPROVAL. THE SUBSTRATE MUST SAFELY TRANSMIT THE LOADS APPLIED TO THIS SYSTEM TO THE BUILDING STRUCTURE.
- 6. FIRE RATINGS OR FIRE RESISTANCE IS NOT A PART OF THIS REVIEW.
- 7. ALL ANCHORS SECURING THE SYSTEM TO PRESSURE TREATED WOOD SHALL BE CAPABLE OF RESISTING CORROSION CAUSED BY THE CHEMICALS IN THE WOOD.
- 8. MATERIALS INCLUDING BUT NOT LIMITED TO STEEL/METAL SCREWS THAT COME INTO CONTACT WITH OTHER DISSIMILAR MATERIALS SHALL BE PROTECTED PER FBC REQUIREMENTS.
- 9. NO INCREASE IN ALLOWABLE STRESS HAS BEEN USED IN THE DESIGN OF THIS PRODUCT. Cd=1.6 WAS USED FOR WOOD SCREWS ONLY.

WINDLOAD NOTES:

- 1. DESIGN WINDLOADS MUST BE CALCULATED BY A LICENSED PROFESSIONAL ENGINEER OR ARCHITECT FOR EACH PROJECT, PER ASCE 7-22 SECTION 29.4.4. (ASD) DESIGN WINDLOADS MAY NOT EXCEED THE ALLOWABLE WINDLOADS SHOWN IN THE CHART BELOW.
- 2. THE ALLOWABLE LOADS (ASD) FOR THE ROCKIT SYSTEM COMPONENTS ARE LISTED BELOW. THE ENGINEER OF RECORD (EOR) OR THE AUTHORITIES HAVING JURISDICTION (AHJ) MUST VERIFY THE PV PANELS USED WITH THIS PRODUCT WILL MEET THE LOAD REQUIREMENTS OF EACH PROJECT WHEN INSTALLED AS PART OF A RAIL-LESS SYSTEM.
- 3. PANEL SYSTEM LOCATION, HEIGHT, AND SPACING MUST MEET THE REQUIREMENTS OF ASCE 7-22 SECTION 29.4.4. WINDLOADS ACT NORMAL TO THE SURFACE OF THE PV PANEL SYSTEM.
- 4. ALLOWABLE WINDLOADS ARE BASED ON ANCHORING IN WOOD RAFTERS WITH S.G.=0.42 MIN.

ALLOWABLE WINDLOADS							
PANEL WIDTH (in)	PANEL LENGTH (in)	ANCHOR SPAN (L) (in)	ROCKIT MOUNT WITH GF1 COMP SLIDE (psf)	PANEL WIDTH (in)	PANEL LENGTH (in)	ANCHOR SPAN (L) (in)	ROCKIT MOUNT WITH GF1 COMP SLIDE (psf)
LANDSCAPE LAYOUT:				PORTRAIT LAYOUT:			
41.5	86	16	136.7	45	67.5	16	84.0
		24	91.6			24	56.3
		32	69.4			32	42.6
		36	61.4			36	37.7
		48	45.8			48	28.1
		60	36.8	45	80	16	70.9
45	92.5	64	34.3			24	47.5
		72	30.5			32	36.0
		16	126.1			36	31.8
		24	84.5	45	86	48	23.7
		32	64.0			16	66.0
		36	56.6			24	44.2
		48	42.2			32	33.5
		60	33.9			36	29.6
		64	31.7			48	22.1
		72	28.1				



SEAL

SCOTT WOLTERS

FL PE# 62354

WOLTERS ENGINEERING

(COA# 27194)

15211 97TH ROAD N

WEST PALM BEACH, FL 33412

(561) 225-1982

1ST SUBMITTAL

PRINTS ISSUED FOR

8/16/25

DATE

IRONRIDGE

DWG: IRROCK-GF1

SHEET: 1/6






28357 INDUSTRIAL BLVD.

HAYWARD, CA 94545

PHONE: (800) 227-9523

info@ironridge.com

QUICKMOUNT ROCKIT RAIL-LESS PHOTOVOLTAIC PANEL RACKING SYSTEM WITH QUICKMOUNT GF1 COMP SLIDE ROOF ATTACHMENTS


IRONRIDGE

28357 INDUSTRIAL BLVD.
HAYWARD, CA 94545

PHONE: (800) 227-9523
info@ironridge.com

SCOTT WOLTERS
FL PE# 62354

WOLTERS ENGINEERING
(COA# 27194)
15211 97TH ROAD N
WEST PALM BEACH, FL 33411
(561) 225-1982

62354

★ STATE OF
AUG 16 2022

AUG 16 2024

919A AUG 16 2025

PRINTS ISSUED FOR

REV.#	
-------	--


DATE

DWG:


IRROCK-GF1
SHEET: 2/6

/6


QUICKMOUNT ROCKIT RAIL-LESS PHOTOVOLTAIC PANEL RACKING SYSTEM
WITH QUICKMOUNT GF1 COMP SLIDE ROOF ATTACHMENTS



5
3
ROCKIT MOUNT
AND GF1 COMP SLIDE



6
3
ROCKIT MOUNT
AND GF1 COMP SLIDE



7
3
ROCKIT COUPLING
DETAIL




SCOTT WALTERS
FL PE# 62354
WALTERS ENGINEERING
(COA# 27194)
15211 97TH ROAD N
WEST PALM BEACH, FL 33412
(561) 225-1982

IRONRIDGE
28357 INDUSTRIAL BLVD.
HAYWARD, CA 94545
PHONE: (800) 227-9523
info@ironridge.com


DWG: IRROCK-GF1
SHEET: 3/6

DATE	8/16/25
REV.#	
PRINTS ISSUED FOR	1ST SUBMITTAL


QUICKMOUNT ROCKIT RAIL-LESS PHOTOVOLTAIC PANEL RACKING SYSTEM WITH QUICKMOUNT GF1 COMP SLIDE ROOF ATTACHMENTS




ROCKIT MOUNT
(TOP VIEW)



ROKIT COUPLING
(TOP VIEW)



ROCKIT MOUNT
(TOP VIEW)



ROKIT COUPLING
(TOP VIEW)


IRONRIDGE

 **IRONRIDGE**

28357 INDUSTRIAL BLVD.
HAYWARD, CA 94545

PHONE: (800) 227-9523
info@ironridge.com

DWG:	IRROCK-GF1
SHEET:	4/6

SCOTT WOLTERS
FL PE# 62354

WOLTERS ENGINEERING
(COA# 27194)
15211 97TH ROAD N
WEST PALM BEACH, FL 33411
(561) 225-1982




SEAL:  No 62354
AUG 16 2005
STATE OF FLORIDA
PROFESSIONAL ENGINEER

1ST SUBMITTAL
PRINTS ISSUED FOR





8/16/25
DATE

QUICKMOUNT ROCKIT RAIL-LESS PHOTOVOLTAIC PANEL RACKING SYSTEM
WITH QUICKMOUNT GF1 COMP SLIDE ROOF ATTACHMENTS

BILL OF MATERIALS- ROCKIT SYSTEM		
#	DESCRIPTION	MATERIALS/NOTES
1	ROCKIT MOUNT ASSEMBLY	6000 SERIES ALUMINUM & 300 SERIES STAINLESS & POLYMERIC
2	ROCKIT COUPLING ASSEMBLY	6000 SERIES ALUMINUM & 300 SERIES STAINLESS & POLYMERIC
3a	ROCKIT SKIRT 35MM&40MM AXX	6000 SERIES ALUMINUM
3b	ROCKIT SKIRT 32MM&38MM BXX	6000 SERIES ALUMINUM
3c	ROCKIT SKIRT 30MM CXX	6000 SERIES ALUMINUM
4	ROCKIT SKIRT END CAP	POLYMERIC
5	ROCKIT COUPLING FOOT ASSEMBLY (OPTIONAL)	POLYMERIC
6	ROCKIT MID CLAMP CAP PLUG (OPTIONAL)	POLYMERIC



5/16"x1 1/4" HH FLANGE
BOLTS (300 SERIES SS,
Fut=100 ksi min)



28357 INDUSTRIAL BLVD.
HAYWARD, CA 94545

PHONE: (800) 227-9523
info@ironridge.com

DWG: **IRROCK-GF1**

SHEET: **5/6**

SCOTT WOLTERS
FL PE# 62354

WOLTERS ENGINEERING
(COA# 27194)
15211 97TH ROAD N
WEST PALM BEACH, FL 33412
(561) 225-1982

SEAL: [Signature]
NO 62354


STATE OF FLORIDA
AUG 16 2025
PROFESSIONAL ENGINEER

1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	7																													




QUICKMOUNT ROCKIT RAIL-LESS PHOTOVOLTAIC PANEL RACKING SYSTEM
WITH QUICKMOUNT GF1 COMP SLIDE ROOF ATTACHMENTS

BILL OF MATERIALS- ROCKIT GF-1 COMP SLIDE		
#	DESCRIPTION	MATERIALS/NOTES
1	ROCKIT MOUNT ASSEMBLY	6000 SERIES ALUMINUM & 300 SERIES STAINLESS & POLYMERIC
8	ROCKIT COMP SLIDE	6000 SERIES ALUMINUM
9	GF1 FLASHING	ALUMINUM OR COATED STEEL & EPDM
10	LAG SCREW 5/16" X 4", 3" THREAD WITH EPDM BACKED WASHER	300 SERIES STAINLESS & EPDM

- ANCHOR NOTES:
1. ANCHOR CAPACITIES LISTED ARE PER FLPA# 3987.1.
 2. CAPACITIES APPLY TO RAFTER SIZE OF 2x4 OR GREATER, DECK THICKNESS OF 15/32" OR GREATER, AND LAG BOLTS SECURED WITHIN THE CENTER 1/3 OF RAFTER WITH 2 1/2" MIN. END DISTANCE.



F1 = 668 lb (max)
(Direct Tension/Uplift)



SCOTT WOLTERS
FL PE# 62354
WOLTERS ENGINEERING
(COA# 27194)
15211 97TH ROAD N
WEST PALM BEACH, FL 33412
(561) 225-1982

DWG: IRROCK-GF1
SHEET: 6/6

28357 INDUSTRIAL BLVD.
HAYWARD, CA 94545
PHONE: (800) 227-9523
info@ironridge.com