


LEAL GLASS INC.

TNT15000 TILT & TURN WINDOW

(HVHZ)(IMPACT)

GENERAL NOTES:

1. THE PRODUCT SHOWN HEREIN IS DESIGNED AND MANUFACTURED TO COMPLY WITH THE CURRENT EDITION OF THE FLORIDA BUILDING CODE (FBC), **INCLUDING** HVHZ AND HAS BEEN EVALUATED ACCORDING TO THE FOLLOWING:
- AAMA/WDMA/CSA 101/I.S.2/A440-22
 - TAS 201-94
 - TAS 202-94
 - TAS 203-94
 - ASTM E1886-19
 - ASTM E1996-20
2. ADEQUACY OF THE EXISTING STRUCTURAL CONCRETE/MASONRY, 2X FRAMING, AND METAL FRAMING AS A MAIN WIND FORCE RESISTING SYSTEM CAPABLE OF WITHSTANDING AND TRANSFERRING APPLIED PRODUCT LOADS TO THE FOUNDATION IS THE RESPONSIBILITY OF THE ENGINEER OR ARCHITECT OF RECORD FOR THE PROJECT OF INSTALLATION.
3. 1X AND 2X BUCKS (WHEN USED) SHALL BE DESIGNED AND ANCHORED TO PROPERLY TRANSFER ALL LOADS TO THE STRUCTURE. BUCK DESIGN AND INSTALLATION IS THE RESPONSIBILITY OF THE ENGINEER OR ARCHITECT OF RECORD FOR THE PROJECT OF INSTALLATION.
4. INSTALL INDIVIDUAL INSTALLATION ANCHORS WITHIN A TOLERANCE OF ±1/2 INCH OF THE DEPICTED LOCATION IN THE ANCHOR LAYOUT DETAIL (I.E., WITHOUT CONSIDERATION OF TOLERANCES). TOLERANCES ARE NOT CUMULATIVE FROM ONE INSTALLATION ANCHOR TO THE NEXT.
5. THE INSTALLATION DETAILS DESCRIBED HEREIN ARE GENERIC AND MAY NOT REFLECT ACTUAL CONDITIONS FOR A SPECIFIC SITE. IF SITE CONDITIONS CAUSE INSTALLATION TO DEVIATE FROM THE REQUIREMENTS DETAILED HEREIN, A LICENSED ENGINEER OR ARCHITECT SHALL PREPARE SITE SPECIFIC DOCUMENTS FOR USE WITH THIS DOCUMENT.
6. APPROVED IMPACT PROTECTIVE SYSTEM **IS NOT REQUIRED** ON THIS PRODUCT IN AREAS REQUIRING IMPACT RESISTANCE.
7. WINDOW FRAME MATERIAL: ALUMINUM 6060-T66
8. GLASS MEETS THE REQUIREMENTS OF ASTM E1300 GLASS CHARTS. SEE SHEET 1 FOR GLAZING DETAIL.



GLAZING NOTES:

1. GLASS TYPE COMPLIES WITH ASTM E1300 REQUIREMENTS. PER THE FBC TEMPER AND SAFETY GLAZING REQUIREMENTS SHALL BE REVIEWED ON A SITE SPECIFIC BASIS.
2. SETTING BLOCK DUROMETER HARDNESS OF 70-90 (SHORE A) AS REFERENCED IN FBC CHAPTER 24.
3. SETTING BLOCKS TO BE LOCATED AT 1/4 SPAN LENGTH FOR GLASS WIDER THAN 36" AS PER FBC CHAPTER 24.
4. D.L.O. AND DESIGN PRESSURES MAY NOT EXCEED MAX VALUES SHOWN HEREIN.

TABLE OF CONTENTS	
SHEET	SHEET DESCRIPTION
1	GENERAL NOTES AND GLAZING DETAIL
2	ELEVATION AND DESIGN PRESSURE TABLES
3	ANCHOR LAYOUT
4	VERTICAL SECTION
5	HORIZONTAL SECTION
6	ANCHOR DETAILS AND INSTALLATION NOTES
7	BILL OF MATERIALS & COMPONENTS

DESIGN PRESSURE RATING (PSF)				
CONFIGURATION	WIDTH (IN.)	HEIGHT (IN.)	DESIGN PRESSURE	MISSILE IMPACT RATING
X	SEE TABLE ON SHEET 2			LARGE & SMALL MISSILE IMPACT



LEAL GLASS INC.
1530 SWEETBAY WAY,
HOLLYWOOD, FL 33019
PH: +1 (305) 842-0305

TITLE:
TNT15000
TILT & TURN WINDOW
(HVHZ) (IMPACT)
GENERAL NOTES &
GLAZING DETAIL


PREPARED BY:
BUILDING DROPS, INC.
1900 NE MIAMI COURT, STE. 2-15
MIAMI, FL 33132
PH: (954) 399-8478
FAX: (954) 744-4738
WEB: www.buildingdrops.com



REMARKS	BY	DATE
2026 FBC UPDATE	LS	07/26

THE INSTALLATION DETAILS DESCRIBED HEREIN ARE GENERIC AND MAY NOT REFLECT ACTUAL CONDITIONS FOR A SPECIFIC SITE. IF SITE CONDITIONS CAUSE INSTALLATION TO DEVIATE FROM THE REQUIREMENTS DETAILED HEREIN, A LICENSED ENGINEER OR ARCHITECT SHALL PREPARE SITE SPECIFIC DOCUMENTS FOR USE WITH THIS DOCUMENT.


Digitally signed by Hermes F. Norero, P.E.
Reason: I am approving this document
Date: 2026.09.11 12:24:00 -0400



FL #:	FL47745
DATE:	11.26.24
DWG. BY:	DB
CHK. BY:	HFN
SCALE:	NTS
DWG. #:	LLG002
SHEET:	1
REV.	A
OF 7	

c:\users\lucianosanchez\building drops, inc\building drops landing - documents\common\projects\2026 code change projects\leal glass\cc-26-6104 - 2026 code change\dwgs\fl47745\llg002.dwg

7/28/2026 10:51 AM



ELEVATION

SASH HEIGHT = FRAME HEIGHT - 2.375"
SASH WIDTH = FRAME WIDTH - 2.375"
D.L.O. HEIGHT = FRAME HEIGHT - 8.375"
D.L.O. WIDTH = FRAME WIDTH - 8.375"

DESIGN PRESSURE TABLE (PSF)			
NOMINAL DIMS.		POS. (+)	NEG. (-)
FRAME WIDTH (IN.)	FRAME HEIGHT (IN.)		
24	24	70.0	70.0
30		70.0	70.0
37.4375		70.0	70.0
42		70.0	70.0
48		70.0	70.0
54		70.0	70.0
60		70.0	70.0
66		70.0	70.0
72		70.0	70.0
78		70.0	70.0
84	30	70.0	70.0
90		70.0	70.0
96		70.0	70.0
24		70.0	70.0
30		70.0	70.0
37.4375		70.0	70.0
42		70.0	70.0
48		70.0	70.0
54		70.0	70.0
60		70.0	70.0
66	36	70.0	70.0
72		70.0	70.0
78		70.0	70.0
84		70.0	70.0
90		70.0	70.0
96		70.0	70.0
24		70.0	70.0
30		70.0	70.0
37.4375		70.0	70.0
42		70.0	70.0
48	42	62.4	62.4
54		62.4	62.4
60		62.4	62.4
66		62.4	62.4
72		62.4	62.4
78		62.4	62.4
24		70.0	70.0
30		70.0	70.0
37.4375		70.0	70.0
42		70.0	70.0

DESIGN PRESSURE TABLE (PSF)			
NOMINAL DIMS.		POS. (+)	NEG. (-)
FRAME WIDTH (IN.)	FRAME HEIGHT (IN.)		
24	48	70.0	70.0
30		70.0	70.0
37.4375		70.0	70.0
42		62.4	62.4
48		54.6	54.6
54		54.6	54.6
60	54	54.6	54.6
66		54.6	54.6
24		70.0	70.0
30		70.0	70.0
37.4375		70.0	70.0
42		62.4	62.4
48	60	54.6	54.6
54		48.5	48.5
60		48.5	48.5
24		70.0	70.0
30		70.0	70.0
37.4375		70.0	70.0
42	66	62.4	62.4
48		54.6	54.6
54		48.5	48.5
60		48.5	48.5
24		70.0	70.0
30		70.0	70.0
37.4375	72	70.0	70.0
42		62.4	62.4
48		54.6	54.6
54		48.5	48.5
60		48.5	48.5
66		48.5	48.5
24	78	70.0	70.0
30		70.0	70.0
37.4375		70.0	70.0
42		62.4	62.4
48		54.6	54.6
54		48.5	48.5
60	87.625	48.5	48.5
66		48.5	48.5
72		48.5	48.5
78		48.5	48.5
84		48.5	48.5
90		48.5	48.5
24	90	70.0	70.0
30		70.0	70.0
37.4375		66.6	66.6
42		64.1	64.1
48		64.1	64.1
54		64.1	64.1
60	96	64.1	64.1
66		64.1	64.1
72		64.1	64.1
78		64.1	64.1
84		64.1	64.1
90		64.1	64.1



LEAL GLASS INC.

1530 SWEETBAY WAY,
HOLLYWOOD, FL 33019
PH: +1 (305) 842-0305


TITLE:
TNT15000
TILT & TURN WINDOW
(HVHZ) (IMPACT)
ELEVATION & DESIGN
PRESSURE TABLES

PREPARED BY:
BUILDING DROPS, INC.
1900 NE MIAMI COURT, STE. 2-15
MIAMI, FL 33132
PH: (954) 399-8478
FAX: (954) 744-4738
WEB: www.buildingdrops.com



REMARKS	BY	DATE
2026 FBC UPDATE	LS	07/26

THE INSTALLATION DETAILS DESCRIBED HEREIN ARE GENERIC AND MAY NOT REFLECT ACTUAL CONDITIONS FOR A SPECIFIC SITE. IF SITE CONDITIONS CAUSE INSTALLATION TO DEVIATE FROM THE REQUIREMENTS DETAILED HEREIN, A LICENSED ENGINEER OR ARCHITECT SHALL PREPARE SITE SPECIFIC DOCUMENTS FOR USE WITH THIS DOCUMENT.



FL #:
FL47745

DATE: **11.26.24**

DWG. BY: **DB** CHK. BY: **HFN**


SCALE: **NTS**

DWG. #: **LLG002**

SHEET: **2** REV. **A**

OF 7

c:\users\lucianosanchez\building drops, inc\building drops landing - documents\common\projects\2026 code change projects\leal glass\cc-26-6104 - 2026 code change\dwgs\lfg002.dwg 7/28/2026 10:51 AM



ANCHOR LAYOUT
THROUGH FRAME INSTALLATION



LEAL GLASS INC.
1530 SWEETBAY WAY,
HOLLYWOOD, FL 33019
PH: +1 (305) 842-0305


TITLE:
TNT15000
TILT & TURN WINDOW
(HVHZ) (IMPACT)
ANCHOR LAYOUT

PREPARED BY:
BUILDING DROPS, INC.
1900 NE MIAMI COURT, STE. 2-15
MIAMI, FL 33132
PH: (954) 399-8478
FAX: (954) 744-4738
WEB: www.buildingdrops.com





REMARKS	BY	DATE
2026 FBC UPDATE	LS	07/26

THE INSTALLATION DETAILS DESCRIBED HEREIN ARE GENERIC AND MAY NOT REFLECT ACTUAL CONDITIONS FOR A SPECIFIC SITE. IF SITE CONDITIONS CAUSE INSTALLATION TO DEVIATE FROM THE REQUIREMENTS DETAILED HEREIN, A LICENSED ENGINEER OR ARCHITECT SHALL PREPARE SITE SPECIFIC DOCUMENTS FOR USE WITH THIS DOCUMENT.



FL #:	FL47745
DATE:	11.26.24
DWG. BY:	CHK. BY:
DB	HFN
SCALE:	NTS
DWG. #:	LLG002
SHEET:	REV.
3	A
OF 7	

c:\users\lucianosanchez\building drops, inc\building drops landing - documents\common\projects\2026 code change projects\leal glass\cc-26-6104 - 2026 code change\dwgs\lf47745\llg002.dwg 7/28/2026 10:51 AM



A
4 VERTICAL SECTION



LEAL GLASS INC.
1530 SWEETBAY WAY,
HOLLYWOOD, FL 33019
PH: +1 (305) 842-0305

TITLE:
TNT15000
TILT & TURN WINDOW
(HVHZ) (IMPACT)
VERTICAL SECTION

PREPARED BY:
BUILDING DROPS, INC.
1900 NE MIAMI COURT, STE. 2-15
MIAMI, FL 33132
PH: (954) 399-8478
FAX: (954) 744-4738
WEB: www.buildingdrops.com





REMARKS	BY	DATE
2026 FBC UPDATE	LS	07/26

THE INSTALLATION DETAILS DESCRIBED HEREIN ARE GENERIC AND MAY NOT REFLECT ACTUAL CONDITIONS FOR A SPECIFIC SITE. IF SITE CONDITIONS CAUSE INSTALLATION TO DEVIATE FROM THE REQUIREMENTS DETAILED HEREIN, A LICENSED ENGINEER OR ARCHITECT SHALL PREPARE SITE SPECIFIC DOCUMENTS FOR USE WITH THIS DOCUMENT.



FL #:	FL47745
DATE:	11.26.24
DWG. BY:	DB
CHK. BY:	HFN
SCALE:	NTS
DWG. #:	LLG002
SHEET:	4
REV.	A

c:\users\lucianosanchez\building drops, inc\building drops landing - documents\common\projects\2026 code change projects\leal glass\cc-26-6104 - 2026 code change\dwgs\lf47745\llg002.dwg 7/28/2026 10:51 AM



A
5 HORIZONTAL SECTION



LEAL GLASS INC.
1530 SWEETBAY WAY,
HOLLYWOOD, FL 33019
PH: +1 (305) 842-0305

TITLE:
TNT15000
TILT & TURN WINDOW
(HVHZ) (IMPACT)
HORIZONTAL SECTION

PREPARED BY:
BUILDING DROPS, INC.
1900 NE MIAMI COURT, STE. 2-15
MIAMI, FL 33132
PH: (954) 399-8478
FAX: (954) 744-4738
WEB: www.buildingdrops.com




REMARKS	BY	DATE
2026 FBC UPDATE	LS	07/26

THE INSTALLATION DETAILS DESCRIBED HEREIN ARE GENERIC AND MAY NOT REFLECT ACTUAL CONDITIONS FOR A SPECIFIC SITE. IF SITE CONDITIONS CAUSE INSTALLATION TO DEVIATE FROM THE REQUIREMENTS DETAILED HEREIN, A LICENSED ENGINEER OR ARCHITECT SHALL PREPARE SITE SPECIFIC DOCUMENTS FOR USE WITH THIS DOCUMENT.



FL #:	FL47745
DATE:	11.26.24
DWG. BY:	DB
CHK. BY:	HFN
SCALE:	NTS
DWG. #:	LLG002
SHEET:	5
REV.	A

c:\users\lucianosanchez\building drops, inc\building drops landing - documents\common\projects\2026 code change\dwgs\lgl002.dwg 7/28/2026 10:51 AM



NOTE: JAMB & HEAD SIMILAR

INSTALLATION NOTES:

- ONE (1) INSTALLATION ANCHOR IS REQUIRED AT EACH ANCHOR LOCATION SHOWN, UNLESS OTHERWISE STATED ON SHEET 3.
- INSTALL INDIVIDUAL INSTALLATION ANCHORS WITHIN A TOLERANCE OF $\pm 1/2$ INCH THE DEPICTED LOCATION & SPACING IN THE ANCHOR LAYOUT DETAILS (I.E., WITHOUT CONSIDERATION OF TOLERANCES). TOLERANCES ARE NOT CUMULATIVE FROM ONE INSTALLATION ANCHOR TO THE NEXT.
- SHIM AS REQUIRED AT EACH INSTALLATION ANCHOR WITH LOAD BEARING SHIM(S). MAXIMUM ALLOWABLE SHIM STACK TO BE 1/4 INCH. SHIM WHERE SPACE OF 1/16 INCH OR GREATER OCCURS. SHIM(S) SHALL BE CONSTRUCTED OF HIGH DENSITY PLASTIC OR BETTER.
- MINIMUM EMBEDMENT AND EDGE DISTANCE EXCLUDE WALL FINISHES, INCLUDING BUT NOT LIMITED TO STUCCO, FOAM, BRICK VENEER, AND SIDING.
- INSTALLATION ANCHORS AND ASSOCIATED HARDWARE MUST BE MADE OF CORROSION RESISTANT MATERIAL OR HAVE A CORROSION RESISTANT COATING:
 - FASTENERS USED WITHIN 3,000 FEET OF A SALTWATER COASTLINE AND INSTALLED IN ENCLOSED SPACES SHALL BE GALVANIZED IN ACCORDANCE WITH SECTION 1711.1.1 (E.G., ASTM A153 CLASS D, ASTM A641 CLASS 3S, OR EQUIVALENT CORROSION RESISTANCE).
 - CONNECTORS AND METAL PLATES USED WITHIN 3,000 FEET OF A SALTWATER COASTLINE SHALL BE STANDARD GALVANIZED IN ACCORDANCE WITH SECTION 1711.1.2 (E.G., ASTM A653 G90, ASTM A123, OR PROTECTIVE COATING PER TPI 1).
- FOR MASONRY OR CONCRETE OPENINGS, A 1X WOOD BUCK MAY BE USED (OPTIONAL) AS LONG AS THE MINIMUM EMBEDMENT AND EDGE DISTANCE REQUIREMENTS ARE STILL MET WITHIN THE CORRESPONDING HOST SUBSTRATE. SEE GENERAL NOTE #3 ON SHEET 1 FOR MORE INFORMATION.
- FOR HOLLOW BLOCK AND GROUT FILLED BLOCK, DO NOT INSTALL INSTALLATION ANCHORS INTO MORTAR JOINTS. EDGE DISTANCE IS MEASURED FROM FREE EDGE OF BLOCK OR EDGE OF MORTAR JOINT INTO FACE SHELL OF BLOCK.
- INSTALLATION ANCHORS SHALL BE INSTALLED IN ACCORDANCE WITH ANCHOR MANUFACTURER'S INSTALLATION INSTRUCTIONS, AND ANCHORS SHALL NOT BE USED IN SUBSTRATES WITH STRENGTHS LESS THAN THE MINIMUM STRENGTH SPECIFIED BY THE ANCHOR MANUFACTURER.

ANCHOR SCHEDULE				
METHOD	SUBSTRATE	ANCHOR TYPE	MIN. EMBEDMENT	MIN. EDGE DISTANCE
THROUGH FRAME	WOOD: MIN. SG = 0.55	#10 WOOD SCREW	1.50"	0.75"
	METAL: 18 GAUGE STEEL, MIN. Fy = 33KSI ALUMINUM: 1/8" MIN., 6063-T5	#10 SELF-DRILLING SCREW	3 THREADS MIN. PENETRATION BEYOND STRUCTURE	0.50"
	CONCRETE: f'c=3000PSI	3/16" ITW TAPCON	1.00"	2.25"
	MASONRY: CMU per ASTM C90 MIN. 2000 PSI			4.00"



LEAL GLASS INC.
1530 SWEETBAY WAY,
HOLLYWOOD, FL 33019
PH: +1 (305) 842-0305

TITLE:
TNT15000
TILT & TURN WINDOW
(HVHZ) (IMPACT)
ANCHOR DETAILS &
INSTALLATION NOTES

PREPARED BY:
BUILDING DROPS, INC.
1900 NE MIAMI COURT, STE. 2-15
MIAMI, FL 33132
PH: (954) 399-8478
FAX: (954) 744-4738
WEB: www.buildingdrops.com



REMARKS	BY	DATE
2026 FBC UPDATE	LS	07/26

THE INSTALLATION DETAILS DESCRIBED HEREIN ARE GENERIC AND MAY NOT REFLECT ACTUAL CONDITIONS FOR A SPECIFIC SITE. IF SITE CONDITIONS CAUSE INSTALLATION TO DEVIATE FROM THE REQUIREMENTS DETAILED HEREIN, A LICENSED ENGINEER OR ARCHITECT SHALL PREPARE SITE SPECIFIC DOCUMENTS FOR USE WITH THIS DOCUMENT.



FL #:
FL47745

DATE: **11.26.24**

DWG. BY: **DB** CHK. BY: **HFN**

SCALE: **NTS**


DWG. #: **LLG002**

SHEET: **6** REV. **A**


OF 7

BILL OF MATERIALS			
ITEM	PART NO.	DESCRIPTION	MATERIAL
1	M15010	FRAME	6060-T66
2	M15033	SASH	6060-T66
3	M9312	GLAZING BEAD	6060-T66
4	200-04-023/045/067-01	INNER GLAZING GASKET	EPDM
5	200-06-860-01/12	OUTER GLAZING GASKET	EPDM
6	-	GASKET	EPDM
7	210-15-000-01	CENTRAL SEAL GASKET	EPDM
8	220-63-000-01	SHUTTER SASH SEAL GASKET	EPDM


1 FRAME




2 SASH




3 GLAZING BEAD




4 INNER GLAZING GASKET




5 OUTER GLAZING GASKET




6 GASKET



7 CENTRAL SEAL GASKET



8 SHUTTER SASH SEAL GASKET



LEAL GLASS INC.

1530 SWEETBAY WAY,
HOLLYWOOD, FL 33019
PH: +1 (305) 842-0305

TITLE:
TNT15000
TILT & TURN WINDOW
(HVHZ) (IMPACT)

BILL OF MATERIALS
& COMPONENTS

PREPARED BY:

BUILDING DROPS, INC.

1900 NE MIAMI COURT, STE. 2-15

MIAMI, FL 33132

PH: (954) 399-8478

FAX: (954) 744-4738

WEB: www.buildingdrops.com



REMARKS

BY

DATE

2026 FBC UPDATE

LS

07/26

THE INSTALLATION DETAILS DESCRIBED HEREIN ARE GENERIC AND MAY NOT REFLECT ACTUAL CONDITIONS FOR A SPECIFIC SITE. IF SITE CONDITIONS CAUSE INSTALLATION TO DEVIATE FROM THE REQUIREMENTS DETAILED HEREIN, A LICENSED ENGINEER OR ARCHITECT SHALL PREPARE SITE SPECIFIC DOCUMENTS FOR USE WITH THIS DOCUMENT.



FL #:

FL47745

DATE: 11.26.24

DWG. BY:

DB

CHK. BY:

HFN

SCALE:

NTS

DWG. #:

LLG002

SHEET:

7

REV.

A

OF 7