

EUROLINE STEEL WINDOWS & DOORS

SERIES 900 THERMAL STEEL FRENCH/SINGLE DOOR


(NON-HVHZ) (NON-IMPACT)

GENERAL NOTES:

1. THE PRODUCT SHOWN HEREIN IS DESIGNED AND MANUFACTURED TO COMPLY WITH THE CURRENT EDITION FLORIDA BUILDING CODE (FBC) **EXCLUDING** HVHZ. ALL PRODUCTS UNDER THE SCOPE OF THIS DOCUMENT HAVE BEEN EVALUATED ACCORDING TO THE FOLLOWING:
- AAMA/WDMA/CSA 101/I.S.2/A440-17
 - ASTM E283/E283M-19
 - ASTM E330/E330M-14(21)
 - ASTM E331-00(16)
2. ADEQUACY OF THE EXISTING STRUCTURAL CONCRETE/MASONRY, 2X STUD FRAMING AS A MAIN WIND FORCE RESISTING SYSTEM CAPABLE OF WITHSTANDING AND TRANSFERRING APPLIED PRODUCT LOADS TO THE FOUNDATION IS THE RESPONSIBILITY OF THE ENGINEER OR ARCHITECT OF RECORD FOR THE PROJECT OF INSTALLATION.
3. 1X AND 2X BUCKS (WHEN USED) SHALL BE DESIGNED AND ANCHORED TO PROPERLY TRANSFER ALL LOADS TO THE STRUCTURE. BUCK DESIGN AND INSTALLATION IS THE RESPONSIBILITY OF THE ENGINEER OR ARCHITECT OF RECORD FOR THE PROJECT OF INSTALLATION.
4. THE INSTALLATION DETAILS DESCRIBED HEREIN ARE GENERIC AND MAY NOT REFLECT ACTUAL CONDITIONS FOR A SPECIFIC SITE. IF SITE CONDITIONS CAUSE INSTALLATION TO DEVIATE FROM THE REQUIREMENTS DETAILED HEREIN, A LICENSED ENGINEER OR ARCHITECT SHALL PREPARE SITE SPECIFIC DOCUMENTS FOR USE WITH THIS DOCUMENT.
5. APPROVED IMPACT PROTECTIVE SYSTEM **IS REQUIRED** TO PROTECT THIS PRODUCT IN AREAS REQUIRING IMPACT RESISTANCE.
6. FRAME MATERIAL: STEEL (MIN. $F_y = 33$ ksi).
7. ALL STRUCTURAL MATERIALS & DISSIMILAR METALS SHALL BE PROTECTED, TREATED, PAINTED, COATED, AND/OR ISOLATED AS REQUIRED IN THE APPLICABLE SECTIONS OF THE CURRENT FLORIDA BUILDING CODE AND REFERENCED DESIGN SPECIFICATIONS.
8. GLASS SHALL MEET THE REQUIREMENTS OF ASTM E 1300 GLASS CHARTS. SEE SHEET 1 FOR GLAZING DETAILS.

TABLE OF CONTENTS	
SHEET	SHEET DESCRIPTION
1	GENERAL NOTES AND GLAZING DETAIL
2	TYPICAL ELEVATIONS AND DESIGN PRESSURE TABLE
3	ALTERNATE ELEVATIONS
4	ANCHOR LAYOUTS
5	VERTICAL SECTIONS
6	HORIZONTAL SECTIONS
7	INSTALLATION DETAILS AND NOTES

DESIGN PRESSURE RATING		
FRAME SIZE	DESIGN PRESSURE	MISSILE RATING
SEE SHEET 2		NON-IMPACT



- GLAZING NOTES:
- GLASS TYPE & THICKNESS SHALL COMPLY WITH ASTM E1300 REQUIREMENTS AS WELL AS APPLICABLE SAFETY GLAZING REQUIREMENTS PER THE FBC. TEMPER AND SAFETY GLAZING REQUIREMENTS SHALL BE REVIEWED ON A SITE SPECIFIC BASIS.
 - SETTING BLOCK DUROMETER HARDNESS OF 70-90 (SHORE A) AS REFERENCED IN FBC CHAPTER 24.
 - SETTING BLOCKS TO BE LOCATED AT 1/4 SPAN LENGTH FOR GLASS WIDER THAN 36" AS PER FBC CHAPTER 24.
 - D.L.O. AND DESIGN PRESSURES MAY NOT EXCEED MAX VALUES IN SHEET 2.



22600 SAVI RANCH PKWY
YORBA LINDA, CA 92887
PH: (877) 590-2714

TITLE:
SERIES 900 THERMAL STEEL
FRENCH/SINGLE DOOR
(NON-HVHZ) (NON-IMPACT)
GENERAL NOTES & GLAZING DETAIL

PREPARED BY:
BUILDING DROPS, INC.
1900 NE MIAMI COURT, SUITE 2-15
MIAMI, FL 33132
PH: (954) 399-8478
FAX: (954) 744-4738
WEB: www.buildingdrops.com

REMARKS	BY	DATE

THE INSTALLATION DETAILS DESCRIBED HEREIN ARE GENERIC AND MAY NOT REFLECT ACTUAL CONDITIONS FOR A SPECIFIC SITE. IF SITE CONDITIONS CAUSE INSTALLATION TO DEVIATE FROM THE REQUIREMENTS DETAILED HEREIN, A LICENSED ENGINEER OR ARCHITECT SHALL PREPARE SITE SPECIFIC DOCUMENTS FOR USE WITH THIS DOCUMENT.

Digitally signed by Hermes F. Norero, P.E.
Reason: I am approving this document
Date: 2025.12.10 18:04:02 -05'00'



FL #:
FL47872

DATE:
10.20.2025

DWG. BY:
MS


CHK. BY:
HFN

SCALE:
NTS

DWG. #:
ELS009

SHEET:
1

c:\users\mengqium\building drops - common\projects\euroline steel windows & doors\fbc-25-1105-1 - steel impact products - qa updates\dwgs\els009.dwg 12/5/2025 2:35 PM




TYPICAL ELEVATION
FRENCH DOOR

FRAME HEIGHT = LEAF HEIGHT + 7/8"
FRENCH DOOR FRAME WIDTH = 2 × LEAF WIDTH
SINGLE DOOR FRAME WIDTH = LEAF WIDTH + 7/8"

D.L.O. HEIGHT = LEAF HEIGHT - 3 3/4"
D.L.O. WIDTH = LEAF WIDTH - 3 3/4"

DESIGN PRESSURE TABLE (+/- PSF) - FRENCH DOOR										
LEAF HEIGHT (IN.)	LEAF WIDTH (IN.)									
	24	27	30	33	36	39	42	45	48	51
119 1/8	65.00	65.00	65.00	65.00	65.00	47.19	35.09	26.62	20.57	16.14
125 1/8	65.00	65.00	65.00	60.72	55.96	47.19	35.09	26.62	20.57	16.14
131 1/8	65.00	63.86	57.70	52.68	48.53	45.03	35.09	26.62	20.57	16.14
137 1/8	62.58	55.80	50.40	46.01	42.36	39.29	35.09	26.62	20.57	16.14
143 1/8	55.02	49.05	44.29	40.42	37.20	34.49	32.18	26.62	20.57	16.14
149 1/8	48.64	43.35	39.13	35.70	32.85	30.44	28.39	26.62	20.57	16.14
155 1/8	43.20	38.50	34.75	31.69	29.15	27.01	25.18	23.60	20.57	16.14
161 1/8	38.55	34.35	31.00	28.26	25.99	24.07	22.44	21.02	19.80	16.14
167 1/8	34.55	30.77	27.76	25.31	23.27	21.55	20.08	18.81	17.71	-
173 1/8	31.08	27.68	24.97	22.76	20.92	19.37	18.04	16.90	-	-
179 1/8	28.06	24.99	22.54	20.54	18.87	17.47	16.27	15.24	-	-
185 1/8	25.42	22.63	20.41	18.60	17.09	15.81	-	-	-	-
191 1/8	23.10	20.57	18.54	16.89	15.52	-	-	-	-	-
197 1/8	21.05	18.74	16.90	15.39	-	-	-	-	-	-
203 1/8	19.24	17.13	15.44	-	-	-	-	-	-	-
209 1/8	17.64	15.70	-	-	-	-	-	-	-	-

* ADDITIONAL HINGES AND LOCK POINTS SHALL BE REQUIRED FOR DOOR TALLER THAN 120" TO MAINTAIN THE SAME MAXIMUM SPACING BETWEEN HINGES AND LOCK POINTS AS THE 120" TALL DOOR.



TYPICAL ELEVATION
SINGLE DOOR

DESIGN PRESSURE TABLE (+/- PSF) - SINGLE DOOR										
LEAF HEIGHT (IN.)	LEAF WIDTH (IN.)									
	24	27	30	33	36	39	42	45	48	51
119 1/8	65.00	65.00	65.00	65.00	65.00	47.19	35.09	26.62	20.57	16.14
125 1/8	65.00	65.00	65.00	65.00	64.49	47.19	35.09	26.62	20.57	16.14
131 1/8	65.00	65.00	65.00	65.00	64.03	47.19	35.09	26.62	20.57	16.14
137 1/8	65.00	65.00	65.00	65.00	63.63	47.19	35.09	26.62	20.57	16.14
143 1/8	65.00	65.00	65.00	65.00	63.26	47.19	35.09	26.62	20.57	16.14
149 1/8	65.00	65.00	65.00	65.00	62.92	47.19	35.09	26.62	20.57	16.14
155 1/8	65.00	65.00	65.00	65.00	62.62	47.19	35.09	26.62	20.57	16.14
161 1/8	65.00	65.00	65.00	65.00	62.34	47.19	35.09	26.62	20.57	16.14
167 1/8	65.00	65.00	65.00	65.00	62.08	47.19	35.09	26.62	20.57	-
173 1/8	65.00	65.00	65.00	65.00	61.84	47.19	35.09	26.62	-	-
179 1/8	65.00	65.00	65.00	65.00	61.62	47.19	35.09	26.62	-	-
185 1/8	65.00	65.00	65.00	65.00	61.42	47.19	35.09	-	-	-
191 1/8	65.00	65.00	65.00	65.00	61.23	47.19	35.09	-	-	-
197 1/8	65.00	65.00	65.00	65.00	61.05	47.19	35.09	-	-	-
203 1/8	65.00	65.00	65.00	65.00	60.89	47.19	-	-	-	-
209 1/8	65.00	65.00	65.00	65.00	60.73	47.19	-	-	-	-

* ADDITIONAL HINGES AND LOCK POINTS SHALL BE REQUIRED FOR DOOR TALLER THAN 120" TO MAINTAIN THE SAME MAXIMUM SPACING BETWEEN HINGES AND LOCK POINTS AS THE 120" TALL DOOR.




22600 SAVI RANCH PKWY
YORBA LINDA, CA 92887
PH: (877) 590-2714

TITLE: SERIES 900 THERMAL STEEL
FRENCH/SINGLE DOOR
(NON-HVHZ) (NON-IMPACT)
TYPICAL ELEVATIONS &
DESIGN PRESSURE TABLE

PREPARED BY:
BUILDING DROPS, INC.
1900 NE MIAMI COURT, SUITE 2-15
MIAMI, FL 33132
PH: (954) 399-8478
FAX: (954) 744-4738
WEB: www.buildingdrops.com

REMARKS	BY	DATE

THE INSTALLATION DETAILS DESCRIBED HEREIN ARE GENERIC AND MAY NOT REFLECT ACTUAL CONDITIONS FOR A SPECIFIC SITE. IF SITE CONDITIONS CAUSE INSTALLATION TO DEVIATE FROM THE REQUIREMENTS DETAILED HEREIN, A LICENSED ENGINEER OR ARCHITECT SHALL PREPARE SITE SPECIFIC DOCUMENTS FOR USE WITH THIS DOCUMENT.



FL #: **FL47872**

DATE: **10.20.2025**

DWG. BY: **MS** CHK. BY: **HFN**


SCALE: **NTS**

DWG. #: **ELS009**


SHEET: **2**

OF 7


c:\users\mengqisun\building drops - common\projects\euroline steel windows & doors\fbc-25-1105-1 - steel impact products - qa updates\dwgs\els009.dwg 12/5/2025 2:35 PM




ALTERNATE ELEVATION
ROUND TOP FRENCH DOOR



ALTERNATE ELEVATION
ARCH TOP FRENCH DOOR



ALTERNATE ELEVATION
ROUND TOP SINGLE DOOR



ALTERNATE ELEVATION
ARCH TOP SINGLE DOOR



22600 SAVI RANCH PKWY
YORBA LINDA, CA 92887
PH: (877) 590-2714

TITLE:
SERIES 900 THERMAL STEEL
FRENCH/SINGLE DOOR
(NON-HVHZ) (NON-IMPACT)
ALTERNATE ELEVATIONS

PREPARED BY:

BUILDING DROPS, INC.
1900 NE MIAMI COURT, SUITE 2-15
MIAMI, FL 33132
PH: (954) 399-8478
FAX: (954) 744-4738
WEB: www.buildingdrops.com

REMARKS	BY	DATE

THE INSTALLATION DETAILS DESCRIBED HEREIN ARE GENERIC AND MAY NOT REFLECT ACTUAL CONDITIONS FOR A SPECIFIC SITE. IF SITE CONDITIONS CAUSE INSTALLATION TO DEVIATE FROM THE REQUIREMENTS DETAILED HEREIN, A LICENSED ENGINEER OR ARCHITECT SHALL PREPARE SITE SPECIFIC DOCUMENTS FOR USE WITH THIS DOCUMENT.



FL #: **FL47872**

DATE: **10.20.2025**

DWG. BY: **MS** CHK. BY: **HFN**


SCALE: **NTS**

DWG. #: **ELS009**


SHEET: **3**

OF 7

c:\users\mengqisun\building drops - common\projects\euroline steel windows & doors\fbc-25-1105-1 - steel impact products - qa updates\dwgs\els009.dwg 12/5/2025 2:35 PM



ANCHOR LAYOUT
FRENCH DOOR



ANCHOR LAYOUT
SINGLE DOOR

ALTERNATE ELEVATIONS SHALL FOLLOW THE
SAME ANCHOR LAYOUTS AS SHOWN ABOVE.



22600 SAVI RANCH PKWY
YORBA LINDA, CA 92887
PH: (877) 590-2714


TITLE: SERIES 900 THERMAL STEEL
FRENCH/SINGLE DOOR
(NON-HVHZ) (NON-IMPACT)
ANCHOR LAYOUTS

PREPARED BY:
BUILDING DROPS, INC.
1900 NE MIAMI COURT, SUITE 2-15
MIAMI, FL 33132
PH: (954) 399-8478
FAX: (954) 744-4738
WEB: www.buildingdrops.com




REMARKS	BY	DATE


THE INSTALLATION DETAILS DESCRIBED HEREIN ARE GENERIC
AND MAY NOT REFLECT ACTUAL CONDITIONS FOR A SPECIFIC
SITE. IF SITE CONDITIONS CAUSE INSTALLATION TO DEVIATE
FROM THE REQUIREMENTS DETAILED HEREIN, A LICENSED
ENGINEER OR ARCHITECT SHALL PREPARE SITE SPECIFIC
DOCUMENTS FOR USE WITH THIS DOCUMENT.




FL #:	FL47872
DATE:	10.20.2025
DWG. BY:	CHK. BY:
MS	HFN
SCALE:	NTS
DWG. #:	ELS009
SHEET:	4



A
5 VERTICAL SECTION
HEAD



B
5 VERTICAL SECTION
SILL



C
5 VERTICAL SECTION
SILL
WITH KICK PANEL




22600 SAVI RANCH PKWY
YORBA LINDA, CA 92887
PH: (877) 590-2714

TITLE: SERIES 900 THERMAL STEEL
FRENCH/SINGLE DOOR
(NON-HVHZ) (NON-IMPACT)
VERTICAL SECTIONS

PREPARED BY:
B.D.
BUILDING DROPS
BUILDING DROPS, INC.
1900 NE MIAMI COURT, SUITE 2-15
MIAMI, FL 33132
PH: (954) 399-8478
FAX: (954) 744-4738
WEB: www.buildingdrops.com

REMARKS	BY	DATE

THE INSTALLATION DETAILS DESCRIBED HEREIN ARE GENERIC AND MAY NOT REFLECT ACTUAL CONDITIONS FOR A SPECIFIC SITE. IF SITE CONDITIONS CAUSE INSTALLATION TO DEVIATE FROM THE REQUIREMENTS DETAILED HEREIN, A LICENSED ENGINEER OR ARCHITECT SHALL PREPARE SITE SPECIFIC DOCUMENTS FOR USE WITH THIS DOCUMENT.



FL #: **FL47872**

DATE: **10.20.2025**

DWG. BY: MS	CHK. BY: HFN
-----------------------	------------------------

SCALE: **NTS**

DWG. #: **ELS009**


SHEET: **5**

TITLE: SERIES 900 THERMAL STEEL
FRENCH/SINGLE DOOR
(NON-HVHZ) (NON-IMPACT)
HORIZONTAL SECTIONS


PREPARED BY:
B.D.
BUILDING DROPS
BUILDING DROPS, INC.
1900 NE MIAMI COURT, SUITE 2-15
MIAMI, FL 33132
PH: (954) 399-8478
FAX: (954) 744-4738
WEB: www.buildingdrops.com

REMARKS	BY	DATE


THE INSTALLATION DETAILS DESCRIBED HEREIN ARE GENERIC AND MAY NOT REFLECT ACTUAL CONDITIONS FOR A SPECIFIC SITE. IF SITE CONDITIONS CAUSE INSTALLATION TO DEVIATE FROM THE REQUIREMENTS DETAILED HEREIN, A LICENSED ENGINEER OR ARCHITECT SHALL PREPARE SITE SPECIFIC DOCUMENTS FOR USE WITH THIS DOCUMENT.




FL #:	FL47872
DATE:	10.20.2025
DWG. BY:	CHK. BY:
MS	HFN
SCALE:	NTS
DWG. #:	ELS009
SHEET:	6



D
6 HORIZONTAL SECTION
LOCK JAMB




E
6 HORIZONTAL SECTION
MEETING STILE



F
6 HORIZONTAL SECTION
HINGE JAMB


c:\users\mengqium\building drops - common\projects\euroline steel windows & doors\lbc-25-1105-1 - steel impact products - qa updates\dwgs\els009.dwg 12/5/2025 2:35 PM



G
7 INSTALLATION DETAILS
HEAD SHOWN
JAMB SIMILAR

INSTALLATION NOTES:

- FOR INSTALLATION AT HEAD AND JAMBS, TWO (2) INSTALLATION ANCHORS INTO SUBSTRATE ARE REQUIRED AT EACH ANCHOR LOCATION SHOWN ON SHEET 4.
- FOR INSTALLATION AT SILL, ONE (1) INSTALLATION ANCHOR INTO SUBSTRATE IS REQUIRED AT EACH ANCHOR LOCATION SHOWN ON SHEET 4.
- THE NUMBER OF INSTALLATION ANCHORS DEPICTED IS THE MINIMUM NUMBER OF ANCHORS TO BE USED FOR PRODUCT INSTALLATION OF THE MAXIMUM SIZE LISTED.
- INSTALL INDIVIDUAL INSTALLATION ANCHORS WITHIN A TOLERANCE OF $\pm 1/4$ INCH THE DEPICTED LOCATION & SPACING IN THE ANCHOR LAYOUT DETAILS (I.E., WITHOUT CONSIDERATION OF TOLERANCES). TOLERANCES ARE NOT CUMULATIVE FROM ONE INSTALLATION ANCHOR TO THE NEXT.
- SHIM AS REQUIRED AT EACH INSTALLATION ANCHOR WITH LOAD BEARING SHIM(S). MAXIMUM ALLOWABLE SHIM STACK TO BE 1/2 INCH. SHIM WHERE SPACE OF 1/16 INCH OR GREATER OCCURS. SHIM(S) SHALL BE CONSTRUCTED OF HIGH DENSITY PLASTIC OR BETTER.
- FOR MASONRY OR CONCRETE OPENINGS, A 1X WOOD BUCK MAY BE USED (OPTIONAL) AS LONG AS THE MINIMUM EMBEDMENT AND EDGE DISTANCE REQUIREMENTS ARE STILL MET WITHIN THE CORRESPONDING HOST SUBSTRATE. SEE GENERAL NOTE #3 ON SHEET 1 FOR MORE INFORMATION.
- MINIMUM EMBEDMENT AND EDGE DISTANCE EXCLUDE WALL FINISHES, INCLUDING BUT NOT LIMITED TO STUCCO, FOAM, BRICK VENEER, AND SIDING.
- INSTALLATION ANCHORS AND ASSOCIATED HARDWARE MUST BE MADE OF CORROSION RESISTANT MATERIAL OR HAVE A CORROSION RESISTANT COATING.
- FOR HOLLOW BLOCK AND GROUT FILLED BLOCK, DO NOT INSTALL INSTALLATION ANCHORS INTO MORTAR JOINTS. EDGE DISTANCE IS MEASURED FROM FREE EDGE OF BLOCK OR EDGE OF MORTAR JOINT INTO FACE SHELL OF BLOCK.
- INSTALLATION ANCHORS SHALL BE INSTALLED IN ACCORDANCE WITH ANCHOR MANUFACTURER'S INSTALLATION INSTRUCTIONS AND ANCHORS SHALL NOT BE USED IN SUBSTRATES WITH STRENGTHS LESS THAN THE MINIMUM STRENGTH SPECIFIED BY THE ANCHOR MANUFACTURER.



H
7 INSTALLATION DETAILS
SILL SHOWN

ANCHOR SCHEDULE			
SUBSTRATE	ANCHOR TYPE	MIN. EMBEDMENT	MIN. EDGE DISTANCE
WOOD: MIN. S.G. = 0.55	#14 WOOD SCREW	1-1/2"	1"
STEEL: MIN. 18 GA. MIN. Fy = 33 ksi	1/4" GRADE 5 SELF-DRILLING/ SELF-TAPPING SCREW	3 THREADS MIN PENETRATION BEYOND METAL	1/2"
ALUMINUM: MIN. 1/8" THICK MIN. 6063-T5			
CONCRETE: MIN. f'c = 3000 psi	1/4" ITW TAPCON	1-1/2"	1-1/2"
MASONRY: HOLLOW OR GROUT- FILLED BLOCK per ASTM C90, MIN. 2000 PSI		1"	2"

TITLE:
SERIES 900 THERMAL STEEL
FRENCH/SINGLE DOOR
(NON-HVHZ) (NON-IMPACT)
INSTALLATION DETAILS & NOTES

PREPARED BY:
B.D.
BUILDING DROPS

BUILDING DROPS, INC.
1900 NE MIAMI COURT, SUITE 2-15
MIAMI, FL 33132
PH: (954) 399-8478
FAX: (954) 744-4738
WEB: www.buildingdrops.com

REMARKS	BY	DATE

THE INSTALLATION DETAILS DESCRIBED HEREIN ARE GENERIC AND MAY NOT REFLECT ACTUAL CONDITIONS FOR A SPECIFIC SITE. IF SITE CONDITIONS CAUSE INSTALLATION TO DEVIATE FROM THE REQUIREMENTS DETAILED HEREIN, A LICENSED ENGINEER OR ARCHITECT SHALL PREPARE SITE SPECIFIC DOCUMENTS FOR USE WITH THIS DOCUMENT.



FL #: **FL47872**

DATE: **10.20.2025**

DWG. BY: **MS** CHK. BY: **HFN**

SCALE: **NTS**

DWG. #: **ELS009**

SHEET:
7