

ARCADIA CUSTOM

T225 - FIXED WINDOW


(NON-HVHZ) (NON-IMPACT)

GENERAL NOTES:

1. THE PRODUCT SHOWN HEREIN IS DESIGNED AND MANUFACTURED TO COMPLY WITH THE CURRENT EDITION FLORIDA BUILDING CODE (FBC) **EXCLUDING** HVHZ. ALL PRODUCTS UNDER THE SCOPE OF THIS DOCUMENT HAVE BEEN EVALUATED ACCORDING TO THE FOLLOWING:
 - AAMA/WDMA/CSA 101/I.S.2/A440-17
 - ASTM E283/E283M-19
 - ASTM E330/E330M-14(21)
 - ASTM E331-00(16)
2. ADEQUACY OF THE EXISTING STRUCTURAL CONCRETE/MASONRY, 2X STUD FRAMING AS A MAIN WIND FORCE RESISTING SYSTEM CAPABLE OF WITHSTANDING AND TRANSFERRING APPLIED PRODUCT LOADS TO THE FOUNDATION IS THE RESPONSIBILITY OF THE ENGINEER OR ARCHITECT OF RECORD FOR THE PROJECT OF INSTALLATION.
3. 1X AND 2X BUCKS (WHEN USED) SHALL BE DESIGNED AND ANCHORED TO PROPERLY TRANSFER ALL LOADS TO THE STRUCTURE. BUCK DESIGN AND INSTALLATION IS THE RESPONSIBILITY OF THE ENGINEER OR ARCHITECT OF RECORD FOR THE PROJECT OF INSTALLATION.
4. THE INSTALLATION DETAILS DESCRIBED HEREIN ARE GENERIC AND MAY NOT REFLECT ACTUAL CONDITIONS FOR A SPECIFIC SITE. IF SITE CONDITIONS CAUSE INSTALLATION TO DEVIATE FROM THE REQUIREMENTS DETAILED HEREIN, A LICENSED ENGINEER OR ARCHITECT SHALL PREPARE SITE SPECIFIC DOCUMENTS FOR USE WITH THIS DOCUMENT.
5. APPROVED IMPACT PROTECTIVE SYSTEM **IS REQUIRED** TO PROTECT THIS PRODUCT IN AREAS REQUIRING IMPACT RESISTANCE.
6. FRAME MATERIAL: ALUMINUM (MIN. 6063-T5).
7. ALL STRUCTURAL MATERIALS & DISSIMILAR METALS SHALL BE PROTECTED, TREATED, PAINTED, COATED, AND/OR ISOLATED AS REQUIRED IN THE APPLICABLE SECTIONS OF THE CURRENT FLORIDA BUILDING CODE AND REFERENCED DESIGN SPECIFICATIONS.
8. GLASS SHALL MEET THE REQUIREMENTS OF ASTM E 1300 GLASS CHARTS. SEE SHEET 1 FOR GLAZING DETAILS.

TABLE OF CONTENTS	
SHEET	SHEET DESCRIPTION
1	GENERAL NOTES AND GLAZING DETAIL
2	TYPICAL ELEVATION, ANCHOR LAYOUT AND DESIGN PRESSURE TABLE
3	QUALIFIED SHAPES
4	VERTICAL SECTIONS
5	HORIZONTAL SECTIONS
6	INSTALLATION DETAILS AND NOTES

DESIGN PRESSURE RATING		
FRAME SIZE	DESIGN PRESSURE	MISSILE RATING
SEE SHEET 2		NON-IMPACT



GLAZING DETAIL

- GLAZING NOTES:
1. GLASS TYPE & THICKNESS SHALL COMPLY WITH ASTM E1300 REQUIREMENTS AS WELL AS APPLICABLE SAFETY GLAZING REQUIREMENTS PER THE FBC. TEMPER AND SAFETY GLAZING REQUIREMENTS SHALL BE REVIEWED ON A SITE SPECIFIC BASIS.
 2. SETTING BLOCK DUROMETER HARDNESS OF 70-90 (SHORE A) AS REFERENCED IN FBC CHAPTER 24.
 3. SETTING BLOCKS TO BE LOCATED AT 1/4 SPAN LENGTH FOR GLASS WIDER THAN 36" AS PER FBC CHAPTER 24.
 4. D.L.O. AND DESIGN PRESSURES MAY NOT EXCEED MAX VALUES IN SHEET 2.



ARCADIA CUSTOM
9280 E OLD VAIL RD
TUCSON, AZ 85747
PH: (520) 284-2061

TITLE:
T225 - FIXED WINDOW
(NON-HVHZ) (NON-IMPACT)
GENERAL NOTES & GLAZING DETAIL

PREPARED BY:
BUILDING DROPS, INC.
1900 NE MIAMI COURT, SUITE 2-15
MIAMI, FL 33132
PH: (954) 399-8478
FAX: (954) 744-4738
WEB: www.buildingdrops.com

REMARKS	BY	DATE

THE INSTALLATION DETAILS DESCRIBED HEREIN ARE GENERIC AND MAY NOT REFLECT ACTUAL CONDITIONS FOR A SPECIFIC SITE. IF SITE CONDITIONS CAUSE INSTALLATION TO DEVIATE FROM THE REQUIREMENTS DETAILED HEREIN, A LICENSED ENGINEER OR ARCHITECT SHALL PREPARE SITE SPECIFIC DOCUMENTS FOR USE WITH THIS DOCUMENT.

Digitally signed by Hermes F. Norero, P.E.
Reason: I am approving this document
Date: 2026.01.29 12:50:28 -05'00'

HERMES F. NORERO, P.E.
FLORIDA P.E. No. 73778
BUILDING DROPS, INC
1900 NE MIAMI COURT, SUITE 2-15
MIAMI, FL 33132
FBPE CERT. OF AUTHORIZATION No. 29578

FL #: **FL48003**

DATE: **01.12.2026**

DWG. BY: **MS** CHK. BY: **HFN**


SCALE: **NTS**

DWG. #: **ADC025**

SHEET: **1**


1/29/2026 12:15 PM

c:\users\mengqium\building drops, inc\building drops landing - common\projects\wilson partition - commercial\bc-19-1205-1.dwg s1225 fixed window adc025.dwg




TYPICAL ELEVATION

D.L.O. HEIGHT = FRAME HEIGHT - 3 15/16"
D.L.O. WIDTH = FRAME WIDTH - 3 3/8"



ANCHOR LAYOUT

DESIGN PRESSURE TABLE (+/- PSF) - T225 Fixed Window																
FRAME HEIGHT (IN.)	FRAME WIDTH (IN.)															
	40	42	48	54	60	66	72	78	84	90	96	102	108	114	120	126
42	70.00	70.00	70.00	70.00	70.00	70.00	70.00	70.00	70.00	70.00	70.00	70.00	70.00	70.00	70.00	70.00
48	70.00	70.00	70.00	70.00	70.00	70.00	70.00	70.00	70.00	70.00	70.00	70.00	70.00	70.00	70.00	70.00
54	70.00	70.00	70.00	70.00	70.00	70.00	70.00	70.00	70.00	70.00	70.00	70.00	70.00	70.00	70.00	70.00
60	70.00	70.00	70.00	70.00	70.00	70.00	70.00	70.00	70.00	70.00	70.00	70.00	70.00	70.00	70.00	70.00
66	70.00	70.00	70.00	70.00	70.00	70.00	70.00	70.00	70.00	70.00	70.00	70.00	70.00	70.00	70.00	70.00
72	70.00	70.00	70.00	70.00	70.00	70.00	70.00	70.00	70.00	70.00	70.00	70.00	70.00	70.00	70.00	70.00
78	70.00	70.00	70.00	70.00	70.00	70.00	70.00	64.87	64.87	64.87	64.87	64.87	64.87	64.87	64.87	64.87
84	70.00	70.00	70.00	70.00	70.00	70.00	70.00	64.37	60.00	60.00	60.00	60.00	60.00	60.00	60.00	60.00
90	70.00	70.00	70.00	70.00	70.00	70.00	70.00	64.37	59.58	55.82	55.82	55.82	55.82	55.82	55.82	55.82
96	70.00	70.00	70.00	70.00	70.00	70.00	70.00	64.37	59.58	55.46	52.18	52.18	52.18	52.18	52.18	52.18
102	70.00	70.00	70.00	70.00	70.00	70.00	70.00	64.37	59.58	55.46	51.86	48.99	48.99	48.99	48.99	48.99
108	70.00	70.00	70.00	70.00	70.00	70.00	70.00	64.37	59.58	55.46	51.86	48.71	46.17	46.17	46.17	46.17
114	70.00	70.00	70.00	70.00	70.00	70.00	70.00	64.37	59.58	55.46	51.86	48.71	45.92	43.65	43.65	43.65
120	70.00	70.00	70.00	70.00	70.00	70.00	70.00	64.37	59.58	55.46	51.86	48.71	45.92	43.43	41.39	41.39
126	70.00	70.00	70.00	70.00	70.00	70.00	68.58	64.37	59.58	55.46	51.86	48.71	45.92	43.43	41.19	39.36
132	70.00	70.00	70.00	70.00	70.00	70.00	67.35	63.98	59.58	55.46	51.86	48.71	45.92	43.43	41.19	39.18
138	70.00	70.00	70.00	70.00	70.00	70.00	66.27	62.83	59.58	55.46	51.86	48.71	45.92	43.43	41.19	-
144	70.00	70.00	70.00	70.00	70.00	69.58	65.30	61.81	58.93	55.46	51.86	48.71	45.92	43.43	-	-
156	70.00	70.00	70.00	70.00	70.00	68.04	63.67	60.08	57.11	54.62	51.86	48.71	45.92	-	-	-
174	70.00	70.00	70.00	70.00	70.00	66.22	61.77	58.09	55.01	52.41	50.20	-	-	-	-	-
198	70.00	70.00	70.00	70.00	69.96	64.42	59.89	56.13	52.97	-	-	-	-	-	-	-
210	70.00	70.00	70.00	70.00	69.27	63.71	59.15	55.37	-	-	-	-	-	-	-	-



NOTES:
FRAME WIDTH (W) AND HEIGHT (H) ARE INTERCHANGEABLE FOR ALL SIZES SHOWN HEREIN NOT TO EXCEED MAXIMUM TESTED SQUARE FOOT AREA. ANCHOR SPACING SHALL NOT EXCEED THOSE SHOWN ABOVE FOR LONG OR SHORT LEG OF UNIT.



ARCADIA CUSTOM
9280 E OLD VAIL RD
TUCSON, AZ 85747
PH: (520) 284-2061


TITLE:
T225 - FIXED WINDOW
(NON-HVHZ) (NON-IMPACT)
TYPICAL ELEVATION, ANCHOR LAYOUT
& DESIGN PRESSURE TABLE

PREPARED BY:
BUILDING DROPS, INC.
1900 NE MIAMI COURT, SUITE 2-15
MIAMI, FL 33132
PH: (954) 399-8478
FAX: (954) 744-4738
WEB: www.buildingdrops.com



REMARKS	BY	DATE

THE INSTALLATION DETAILS DESCRIBED HEREIN ARE GENERIC AND MAY NOT REFLECT ACTUAL CONDITIONS FOR A SPECIFIC SITE. IF SITE CONDITIONS CAUSE INSTALLATION TO DEVIATE FROM THE REQUIREMENTS DETAILED HEREIN, A LICENSED ENGINEER OR ARCHITECT SHALL PREPARE SITE SPECIFIC DOCUMENTS FOR USE WITH THIS DOCUMENT.



FL #: **FL48003**


DATE: **01.12.2026**

DWG. BY: MS	CHK. BY: HFN
--------------------	---------------------


SCALE: **NTS**

DWG. #: **ADC025**


SHEET: **2**




CHORD




CIRCLE TOP




TRIANGLE




RIGHT TRIANGLE




QUARTER CIRCLE - R




EQUAL LEG ARCH




UNEQUAL LEG ARCH




HALF SPRINGLINE




SPRINGLINE




TRAPEZOID




PENTAGON




PEAK PENTAGON



HEXAGON



OCTAGON



CIRCLE

QUALIFIED SHAPES



ARCADIA CUSTOM
9280 E OLD VAIL RD
TUCSON, AZ 85747
PH: (520) 284-2061

TITLE:
T225 - FIXED WINDOW
(NON-HVHZ) (NON-IMPACT)
QUALIFIED SHAPES

PREPARED BY:
BUILDING DROPS, INC.
1900 NE MIAMI COURT, SUITE 2-15
MIAMI, FL 33132
PH: (954) 399-8478
FAX: (954) 744-4738
WEB: www.buildingdrops.com

REMARKS	BY	DATE

THE INSTALLATION DETAILS DESCRIBED HEREIN ARE GENERIC AND MAY NOT REFLECT ACTUAL CONDITIONS FOR A SPECIFIC SITE. IF SITE CONDITIONS CAUSE INSTALLATION TO DEVIATE FROM THE REQUIREMENTS DETAILED HEREIN, A LICENSED ENGINEER OR ARCHITECT SHALL PREPARE SITE SPECIFIC DOCUMENTS FOR USE WITH THIS DOCUMENT.

HERMES F. NORERO, P.E.
FLORIDA P.E. No. 73778
BUILDING DROPS, INC
1900 NE MIAMI COURT, SUITE 2-15
MIAMI, FL 33132
FBPE CERT. OF AUTHORIZATION No. 29578

FL #: **FL48003**



DATE: **01.12.2026**

DWG. BY: **MS** CHK. BY: **HFN**

SCALE: **NTS**

DWG. #: **ADC025**

SHEET:
3



ARCADIA CUSTOM
9280 E OLD VAIL RD
TUCSON, AZ 85747
PH: (520) 284-2061

TITLE:
T225 - FIXED WINDOW
(NON-HVHZ) (NON-IMPACT)
VERTICAL SECTIONS

PREPARED BY:

BUILDING DROPS, INC.
1900 NE MIAMI COURT, SUITE 2-15
MIAMI, FL 33132
PH: (954) 399-8478
FAX: (954) 744-4738
WEB: www.buildingdrops.com

REMARKS	BY	DATE

THE INSTALLATION DETAILS DESCRIBED HEREIN ARE GENERIC AND MAY NOT REFLECT ACTUAL CONDITIONS FOR A SPECIFIC SITE. IF SITE CONDITIONS CAUSE INSTALLATION TO DEVIATE FROM THE REQUIREMENTS DETAILED HEREIN, A LICENSED ENGINEER OR ARCHITECT SHALL PREPARE SITE SPECIFIC DOCUMENTS FOR USE WITH THIS DOCUMENT.

HERMES F. NORERO, P.E.
FLORIDA P.E. No 73778
BUILDING DROPS, INC
1900 NE MIAMI COURT, SUITE 2-15
MIAMI, FL 33132
FBPE CERT. OF AUTHORIZATION No. 29578

FL #: **FL48003**

DATE: **01.12.2026**

DWG. BY:
MS



CHK. BY:
HFN

SCALE: **NTS**

DWG. #: **ADC025**

SHEET:
4

c:\users\mengqisun\building drops, inc\building drops landing - common\projects\wilson partition - commercial\bc-19-1205-1.dwg;t1225 fixed window.adc025.dwg 1/29/2026 12:16 PM



ARCADIA CUSTOM
9280 E OLD VAIL RD
TUCSON, AZ 85747
PH: (520) 284-2061

TITLE:

T225 - FIXED WINDOW
(NON-HVHZ) (NON-IMPACT)

HORIZONTAL SECTIONS


PREPARED BY:

**BUILDING DROPS**

BUILDING DROPS, INC.
1900 NE MIAMI COURT, SUITE 2-15
MIAMI, FL 33132
PH: (954) 399-8478
FAX: (954) 744-4738
WEB: www.buildingdrops.com

REMARKS	BY	DATE

THE INSTALLATION DETAILS DESCRIBED HEREIN ARE GENERIC AND MAY NOT REFLECT ACTUAL CONDITIONS FOR A SPECIFIC SITE. IF SITE CONDITIONS CAUSE INSTALLATION TO DEVIATE FROM THE REQUIREMENTS DETAILED HEREIN, A LICENSED ENGINEER OR ARCHITECT SHALL PREPARE SITE SPECIFIC DOCUMENTS FOR USE WITH THIS DOCUMENT.



HERMES F. NORERO, P.E.
FLORIDA P.E. No. 73778
BUILDING DROPS, INC
1900 NE MIAMI COURT, SUITE 2-15
MIAMI, FL 33132
FBPE CERT. OF AUTHORIZATION No. 29578

FL #: **FL48003**

DATE: **01.12.2026**

DWG. BY:
MS


CHK. BY:
HFN

SCALE: **NTS**


DWG. #: **ADC025**

SHEET:

5



E
6 **INSTALLATION DETAILS**
HEAD SHOWN, JAMB SIMILAR
ANCHOR THROUGH STRAP



F
6 **INSTALLATION DETAILS**
SILL
ANCHOR THROUGH STRAP

INSTALLATION NOTES:

- ONE (1) INSTALLATION ANCHOR INTO SUBSTRATE IS REQUIRED AT EACH ANCHOR LOCATION.
- THE NUMBER OF INSTALLATION ANCHORS DEPICTED IS THE MINIMUM NUMBER OF ANCHORS TO BE USED FOR PRODUCT INSTALLATION OF THE MAXIMUM SIZE LISTED.
- INSTALL INDIVIDUAL INSTALLATION ANCHORS WITHIN A TOLERANCE OF $\pm 1/4$ INCH THE DEPICTED LOCATION & SPACING IN THE ANCHOR LAYOUT DETAILS (I.E., WITHOUT CONSIDERATION OF TOLERANCES). TOLERANCES ARE NOT CUMULATIVE FROM ONE INSTALLATION ANCHOR TO THE NEXT.
- SHIM AS REQUIRED AT EACH INSTALLATION ANCHOR WITH LOAD BEARING SHIM(S). MAXIMUM ALLOWABLE SHIM STACK TO BE 1/4 INCH. SHIM WHERE SPACE OF 1/16 INCH OR GREATER OCCURS. SHIM(S) SHALL BE CONSTRUCTED OF HIGH DENSITY PLASTIC OR BETTER.
- FOR MASONRY OR CONCRETE OPENINGS, A 1X WOOD BUCK MAY BE USED (OPTIONAL) AS LONG AS THE MINIMUM EMBEDMENT AND EDGE DISTANCE REQUIREMENTS ARE STILL MET WITHIN THE CORRESPONDING HOST SUBSTRATE. SEE GENERAL NOTE #3 ON SHEET 1 FOR MORE INFORMATION.
- MINIMUM EMBEDMENT AND EDGE DISTANCE EXCLUDE WALL FINISHES, INCLUDING BUT NOT LIMITED TO STUCCO, FOAM, BRICK VENEER, AND SIDING.
- INSTALLATION ANCHORS AND ASSOCIATED HARDWARE MUST BE MADE OF CORROSION RESISTANT MATERIAL OR HAVE A CORROSION RESISTANT COATING.
- FOR HOLLOW BLOCK AND GROUT FILLED BLOCK, DO NOT INSTALL INSTALLATION ANCHORS INTO MORTAR JOINTS. EDGE DISTANCE IS MEASURED FROM FREE EDGE OF BLOCK OR EDGE OF MORTAR JOINT INTO FACE SHELL OF BLOCK.
- INSTALLATION ANCHORS SHALL BE INSTALLED IN ACCORDANCE WITH ANCHOR MANUFACTURER'S INSTALLATION INSTRUCTIONS AND ANCHORS SHALL NOT BE USED IN SUBSTRATES WITH STRENGTHS LESS THAN THE MINIMUM STRENGTH SPECIFIED BY THE ANCHOR MANUFACTURER.

ANCHOR SCHEDULE				
METHOD	SUBSTRATE	ANCHOR TYPE	MIN. EMBEDMENT	MIN. EDGE DISTANCE
THROUGH STRAP	WOOD: MIN. S.G. = 0.55	#12 WOOD SCREW	1-1/2"	1"
	STEEL: MIN. 18 GA. MIN. Fy = 33 ksi	#12 GRADE 5 SELF-DRILLING/ SELF-TAPPING SCREW	3 THREADS MIN PENETRATION BEYOND METAL	1/2"
	ALUMINUM: MIN. 1/8" THICK MIN. 6063-T5			
	CONCRETE: MIN. f'c = 3000 psi	1/4" ITW TAPCON	1-1/2"	1-1/2"
	MASONRY: HOLLOW OR GROUT- FILLED BLOCK per ASTM C90, MIN. 2000 PSI		1"	2"



ARCADIA CUSTOM
9280 E OLD VAIL RD
TUCSON, AZ 85747
PH: (520) 284-2061

TITLE:
T225 - FIXED WINDOW
(NON-HVHZ) (NON-IMPACT)

INSTALLATION DETAILS & NOTES


PREPARED BY:

BUILDING DROPS

BUILDING DROPS, INC.
1900 NE MIAMI COURT, SUITE 2-15
MIAMI, FL 33132
PH: (954) 399-8478
FAX: (954) 744-4738
WEB: www.buildingdrops.com

REMARKS	BY	DATE

THE INSTALLATION DETAILS DESCRIBED HEREIN ARE GENERIC AND MAY NOT REFLECT ACTUAL CONDITIONS FOR A SPECIFIC SITE. IF SITE CONDITIONS CAUSE INSTALLATION TO DEVIATE FROM THE REQUIREMENTS DETAILED HEREIN, A LICENSED ENGINEER OR ARCHITECT SHALL PREPARE SITE SPECIFIC DOCUMENTS FOR USE WITH THIS DOCUMENT.



FL #: **FL48003**

DATE: **01.12.2026**

DWG. BY:
MS

CHK. BY:
HFN

SCALE: **NTS**

DWG. #: **ADC025**

SHEET:
6