



ENERLUX WINDOWS & DOORS

LOW-PROFILE PICTURE WINDOW (WZ3)(IMPACT)

GENERAL NOTES:

- THE PRODUCT SHOWN HEREIN IS DESIGNED AND MANUFACTURED TO COMPLY WITH THE CURRENT EDITION OF THE FLORIDA BUILDING CODE (FBC), **EXCLUDING** HVHZ AND HAS BEEN EVALUATED ACCORDING TO THE FOLLOWING:
 - AAMA/WDMA/CSA 101/I.S.2/A440-17
 - ASTM E1886-19
 - ASTM E1996-20
- ADEQUACY OF THE EXISTING STRUCTURAL CONCRETE/MASONRY, 2X FRAMING, AND METAL FRAMING AS A MAIN WIND FORCE RESISTING SYSTEM CAPABLE OF WITHSTANDING AND TRANSFERRING APPLIED PRODUCT LOADS TO THE FOUNDATION IS THE RESPONSIBILITY OF THE ENGINEER OR ARCHITECT OF RECORD FOR THE PROJECT OF INSTALLATION.
- 1X AND 2X BUCKS (WHEN USED) SHALL BE DESIGNED AND ANCHORED TO PROPERLY TRANSFER ALL LOADS TO THE STRUCTURE. BUCK DESIGN AND INSTALLATION IS THE RESPONSIBILITY OF THE ENGINEER OR ARCHITECT OF RECORD FOR THE PROJECT OF INSTALLATION.
- INSTALL INDIVIDUAL INSTALLATION ANCHORS WITHIN A TOLERANCE OF $\pm 1/2$ INCH OF THE DEPICTED LOCATION IN THE ANCHOR LAYOUT DETAIL (I.E., WITHOUT CONSIDERATION OF TOLERANCES). TOLERANCES ARE NOT CUMULATIVE FROM ONE INSTALLATION ANCHOR TO THE NEXT.
- THE INSTALLATION DETAILS DESCRIBED HEREIN ARE GENERIC AND MAY NOT REFLECT ACTUAL CONDITIONS FOR A SPECIFIC SITE. IF SITE CONDITIONS CAUSE INSTALLATION TO DEVIATE FROM THE REQUIREMENTS DETAILED HEREIN, A LICENSED ENGINEER OR ARCHITECT SHALL PREPARE SITE SPECIFIC DOCUMENTS FOR USE WITH THIS DOCUMENT.
- APPROVED IMPACT PROTECTIVE SYSTEM **IS NOT REQUIRED** ON THIS PRODUCT IN AREAS REQUIRING IMPACT RESISTANCE IN WIND ZONE 3 OR LESS.
- APPROVED IMPACT PROTECTIVE SYSTEM **IS REQUIRED** ON THIS PRODUCT IN AREAS REQUIRING IMPACT RESISTANCE IN WIND ZONE 4.
- WINDOW FRAME MATERIAL: FIBERGLASS
- GLASS MEETS THE REQUIREMENTS OF ASTM E1300 GLASS CHARTS. SEE SHEET 1 FOR GLAZING DETAILS.



- GLAZING NOTES:
- GLASS TYPE COMPLIES WITH ASTM E1300 REQUIREMENTS. PER THE FBC TEMPER AND SAFETY GLAZING REQUIREMENTS SHALL BE REVIEWED ON A SITE SPECIFIC BASIS.
 - SETTING BLOCK DUROMETER HARDNESS OF 70-90 (SHORE A) AS REFERENCED IN FBC CHAPTER 24.
 - SETTING BLOCKS TO BE LOCATED AT 1/4 SPAN LENGTH FOR GLASS WIDER THAN 36" AS PER FBC CHAPTER 24.
 - D.L.O. AND DESIGN PRESSURES MAY NOT EXCEED MAX VALUES SHOWN HEREIN.

TABLE OF CONTENTS	
SHEET	SHEET DESCRIPTION
1	GENERAL NOTES AND GLAZING DETAIL
2	ELEVATION AND DESIGN PRESSURE TABLE
3	ELEVATION AND DESIGN PRESSURE TABLE
4	ANCHOR LAYOUTS
5	ANCHOR LAYOUTS
6	VERTICAL SECTION
7	HORIZONTAL SECTIONS
8	ANCHOR DETAILS AND INSTALLATION NOTES

DESIGN PRESSURE RATING (PSF)				
CONFIGURATION	WIDTH (IN.)	HEIGHT (IN.)	DESIGN PRESSURE	MISSILE IMPACT RATING
O	SEE TABLE ON SHEET 2			LARGE & SMALL MISSILE IMPACT
OO	SEE TABLE ON SHEET 3			



1530 PINE AVENUE
CRETE, NE
PH: (402)-205-3055

LOW-PROFILE
PICTURE WINDOW
(WZ3) (IMPACT)
GENERAL NOTES &
GLAZING DETAIL


PREPARED BY:
BUILDING DROPS, INC.
1900 NE MIAMI COURT, STE. 2-15
MIAMI, FL 33132
PH: (954) 399-8478
FAX: (954) 744-4738
WEB: www.buildingdrops.com



REMARKS	BY	DATE


THE INSTALLATION DETAILS DESCRIBED HEREIN ARE GENERIC AND MAY NOT REFLECT ACTUAL CONDITIONS FOR A SPECIFIC SITE. IF SITE CONDITIONS CAUSE INSTALLATION TO DEVIATE FROM THE REQUIREMENTS DETAILED HEREIN, A LICENSED ENGINEER OR ARCHITECT SHALL PREPARE SITE SPECIFIC DOCUMENTS FOR USE WITH THIS DOCUMENT.

Digitally signed by Hermes F. Norero, P.E.
Reason: I am approving this document
Date: 2026.05.28 19:52:41 -0400'



FL #:	FL48241
DATE:	05.28.26
DWG. BY:	HJ
CHK. BY:	HFN
SCALE:	NTS
DWG. #:	ELX001
SHEET:	1
OF 8	

c:\users\sebastianh\appdata\local\temp\project\enerlux\windows and doors\fbp-25-0375 - fbc submittal - fiberglass impact products\dwgs\k\elx001 - wz3.dwg 6/2/2026 8:35 AM




ELEVATION
FIXED WINDOW
SINGLE UNIT

D.L.O. HEIGHT = FRAME HEIGHT - 3.125"
D.L.O. WIDTH = FRAME WIDTH - 3.125"

SINGLE UNIT DESIGN PRESSURE TABLE (PSF)			
NOMINAL DIMS.		G1	G2
FRAME WIDTH (IN.)	FRAME HEIGHT (IN.)		
36	60	70.0	60.0
42		70.0	60.0
48		70.0	60.0
54		62.2	60.0
60	66	56.0	60.0
36		70.0	60.0
42		70.0	60.0
48		70.0	60.0
54	72	62.2	60.0
60		56.0	60.0
66		-	54.5
72		-	50.0
36	78	70.0	60.0
42		70.0	60.0
48		70.0	60.0
54		-	60.0
60	84	-	60.0
66		-	54.5
72		-	50.0
78		-	46.2
36	90	70.0	60.0
42		70.0	60.0
48		-	60.0
54		-	60.0
60	96	-	60.0
66		-	54.5
72		-	50.0
78		-	46.2

SINGLE UNIT DESIGN PRESSURE TABLE (PSF)			
NOMINAL DIMS.		G1	G2
FRAME WIDTH (IN.)	FRAME HEIGHT (IN.)		
36	102	70.0	60.0
42		-	60.0
48		-	60.0
54		-	60.0
60	108	-	60.0
36		70.0	60.0
42		-	60.0
48		-	60.0
54	114	-	60.0
60		-	60.0
36		-	60.0
42		-	60.0
48	120	-	60.0
54		-	60.0
60		-	60.0
66		-	54.5
72	126	-	50.0
36		70.0	60.0
42		70.0	60.0
48		70.0	60.0
54	132	-	60.0
60		-	60.0
66		-	54.5
72		-	50.0
78	138	-	46.2
36		70.0	60.0
42		70.0	60.0
48		70.0	60.0
54	144	-	60.0
60		-	60.0
66		-	54.5
72		-	50.0
78	150	-	46.2
36		70.0	60.0
42		70.0	60.0
48		70.0	60.0
54	156	-	60.0
60		-	60.0
66		-	54.5
72		-	50.0



1530 PINE AVENUE
CRETE, NE
PH: (402)-205-3055


LOW-PROFILE
PICTURE WINDOW
(WZ3) (IMPACT)
ELEVATION & DESIGN
PRESSURE TABLES

PREPARED BY:
BUILDING DROPS, INC.
1900 NE MIAMI COURT, STE. 2-15
MIAMI, FL 33132
PH: (954)399-8478
FAX: (954)744-4738
WEB: www.buildingdrops.com




REMARKS	BY	DATE

THE INSTALLATION DETAILS DESCRIBED HEREIN ARE GENERIC AND MAY NOT REFLECT ACTUAL CONDITIONS FOR A SPECIFIC SITE. IF SITE CONDITIONS CAUSE INSTALLATION TO DEVIATE FROM THE REQUIREMENTS DETAILED HEREIN, A LICENSED ENGINEER OR ARCHITECT SHALL PREPARE SITE SPECIFIC DOCUMENTS FOR USE WITH THIS DOCUMENT.



FL #:	FL48241
DATE:	05.28.26
DWG. BY:	HJ
CHK. BY:	HFN
SCALE:	NTS
DWG. #:	ELX001
SHEET:	2

c:\users\sebastianherroeros\building drops, including drops landing - common\projects\enerlux windows and doors\fbp-25-0375 - fbp submittal - fiberglass impact products\dwgs\k\elx001 - w23.dwg 6/2/2026 8:35 AM




ELEVATION

FIXED WINDOW
MULLION UNIT

D.L.O. HEIGHT = FRAME HEIGHT - 3.125"
D.L.O. WIDTH = FRAME WIDTH - 3.125"

ADDITIONAL QUALIFIED CONFIGURATIONS




DESIGN PRESSURE TABLE (PSF)			
NOMINAL DIMS.		POS. (+)	NEG. (-)
TRIBUTARY WIDTH - 'W' (IN.)	SPAN - 'L' (IN.)		
30	60	70.0	70.0
36		70.0	70.0
42		70.0	70.0
48		70.0	70.0
54		70.0	70.0
60		70.0	70.0
66		70.0	70.0
30	66	70.0	70.0
36		70.0	70.0
42		70.0	70.0
48		70.0	70.0
54		70.0	70.0
60		70.0	70.0
30	72	70.0	70.0
36		70.0	70.0
42		70.0	70.0
48		70.0	70.0
54		70.0	70.0
60		70.0	70.0
30	78	70.0	70.0
36		70.0	70.0
42		70.0	70.0
48		70.0	70.0

DESIGN PRESSURE TABLE (PSF)			
NOMINAL DIMS.		POS. (+)	NEG. (-)
TRIBUTARY WIDTH - 'W' (IN.)	SPAN - 'L' (IN.)		
30	84	70.0	70.0
36		70.0	70.0
42		70.0	70.0
48		70.0	70.0
30	90	70.0	70.0
36		70.0	70.0
42		62.1	62.1
30	96	68.2	68.2
36		57.8	57.8
42		50.6	50.6
30	102	56.6	56.6
36		47.9	47.9
30	108	47.5	47.5
36		40.1	40.1
30	114	40.3	40.3
30	120	34.4	34.4

NOTE: LESSER DESIGN PRESSURE OF
MULLION TABLE AND INDIVIDUAL UNIT
SHALL APPLY TO THE ENTIRE SYSTEM.

TRIBUTARY WIDTH $W = \frac{A+B}{2}$



1530 PINE AVENUE
CRETE, NE
PH: (402)-205-3055

TITLE:
LOW-PROFILE
PICTURE WINDOW
(WZ3) (IMPACT)
ELEVATION & DESIGN
PRESSURE TABLES

PREPARED BY:
BUILDING DROPS, INC.
1900 NE MIAMI COURT, STE. 2-15
MIAMI, FL 33132
PH: (954) 399-8478
FAX: (954) 744-4738
WEB: www.buildingdrops.com




REMARKS	BY	DATE

THE INSTALLATION DETAILS DESCRIBED HEREIN ARE GENERIC
AND MAY NOT REFLECT ACTUAL CONDITIONS FOR A SPECIFIC
SITE. IF SITE CONDITIONS CAUSE INSTALLATION TO DEVIATE
FROM THE REQUIREMENTS DETAILED HEREIN, A LICENSED
ENGINEER OR ARCHITECT SHALL PREPARE SITE SPECIFIC
DOCUMENTS FOR USE WITH THIS DOCUMENT.




FL #:	FL48241
DATE:	05.28.26
DWG. BY:	HJ
CHK. BY:	HFN
SCALE:	NTS
DWG. #:	ELX001
SHEET:	3

c:\users\sebastianh\appdata\local\temp\project\enerlux\windows and doors\fbp-25-0375 - fbc submittal - fiberglass impact products\dwgs\k\elx001 - wz3.dwg 6/2/2026 8:35 AM




ANCHOR LAYOUT
FIXED WINDOW
THROUGH FRAME INSTALLATION



ANCHOR LAYOUT
FIXED WINDOW
CLIP INSTALLATION

NOTE: TWO (2) INSTALLATION ANCHORS
PER CLIP LOCATION.

ANCHOR LEGEND	
○	NAIL FIN ANCHOR LOCATION
—	THROUGH FRAME ANCHOR LOCATION
⌘	CLIP LOCATION



ANCHOR LAYOUT
FIXED WINDOW
NAIL FIN INSTALLATION



1530 PINE AVENUE
CRETE, NE
PH: (402)-205-3055

LOW-PROFILE
PICTURE WINDOW
(WZ3) (IMPACT)
ANCHOR LAYOUTS

PREPARED BY:
BUILDING DROPS, INC.
1900 NE MIAMI COURT, STE. 2-15
MIAMI, FL 33132
PH: (954) 399-8478
FAX: (954) 744-4738
WEB: www.buildingdrops.com



REMARKS	BY	DATE

THE INSTALLATION DETAILS DESCRIBED HEREIN ARE GENERIC
AND MAY NOT REFLECT ACTUAL CONDITIONS FOR A SPECIFIC
SITE. IF SITE CONDITIONS CAUSE INSTALLATION TO DEVIATE
FROM THE REQUIREMENTS DETAILED HEREIN, A LICENSED
ENGINEER OR ARCHITECT SHALL PREPARE SITE SPECIFIC
DOCUMENTS FOR USE WITH THIS DOCUMENT.



FL #:
FL48241

DATE: **05.28.26**

DWG. BY: **HJ** CHK. BY: **HFN**

SCALE: **NTS**


DWG. #: **ELX001**

SHEET:

4


OF 8

c:\users\sebastianh\documents\building drops, including drops landing - common\projects\enerlux windows and doors\fbc-25-0375 - fbc submittal - fiberglass impact products\dwgs\kyle\001 - wz3.dwg 6/2/2026 8:35 AM



ANCHOR LAYOUT
FIXED WINDOW MULLED UNIT
THROUGH FRAME INSTALLATION


NOTE: WHEN THROUGH FRAME
INSTALLATION IS USED, STRAPS MUST BE
USED AT THE SILL.



ANCHOR LAYOUT
FIXED WINDOW MULLED UNIT
CLIP INSTALLATION

NOTE: TWO (2) INSTALLATION ANCHORS
PER CLIP LOCATION.

ANCHOR LEGEND	
○	NAIL FIN ANCHOR LOCATION
—	THROUGH FRAME ANCHOR LOCATION
⊞	CLIP LOCATION



ANCHOR LAYOUT
FIXED WINDOW MULLED UNIT
NAIL FIN INSTALLATION



1530 PINE AVENUE
CRETE, NE
PH: (402)-205-3055


TITLE:
LOW-PROFILE
PICTURE WINDOW
(WZ3) (IMPACT)
ANCHOR LAYOUTS

PREPARED BY:
BUILDING DROPS, INC.
1900 NE MIAMI COURT, STE. 2-15
MIAMI, FL 33132
PH: (954)399-8478
FAX: (954)744-4738
WEB: www.buildingdrops.com



REMARKS	BY	DATE

THE INSTALLATION DETAILS DESCRIBED HEREIN ARE GENERIC
AND MAY NOT REFLECT ACTUAL CONDITIONS FOR A SPECIFIC
SITE. IF SITE CONDITIONS CAUSE INSTALLATION TO DEVIATE
FROM THE REQUIREMENTS DETAILED HEREIN, A LICENSED
ENGINEER OR ARCHITECT SHALL PREPARE SITE SPECIFIC
DOCUMENTS FOR USE WITH THIS DOCUMENT.



FL #:
FL48241

DATE: **05.28.26**

DWG. BY: **HJ**
CHK. BY: **HFN**

SCALE: **NTS**


DWG. #: **ELX001**

SHEET:

5

OF 8

c:\users\sebastianh\appdata\local\temp\project\enerlux\windows and doors\fbp-25-0375 - fbp-submittal - fiberglass impact products\dwgs\k\elx001 - wz3.dwg 6/2/2026 8:35 AM



A
6 **VERTICAL SECTION**
TYP. HEAD AND SILL



1530 PINE AVENUE
CRETE, NE
PH: (402)-205-3055


TITLE:
LOW-PROFILE
PICTURE WINDOW
(WZ3) (IMPACT)
VERTICAL SECTION

PREPARED BY:
BUILDING DROPS, INC.
1900 NE MIAMI COURT, STE. 2-15
MIAMI, FL 33132
PH: (954)399-8478
FAX: (954)744.4738
WEB: www.buildingdrops.com



REMARKS	BY	DATE

THE INSTALLATION DETAILS DESCRIBED HEREIN ARE GENERIC AND MAY NOT REFLECT ACTUAL CONDITIONS FOR A SPECIFIC SITE. IF SITE CONDITIONS CAUSE INSTALLATION TO DEVIATE FROM THE REQUIREMENTS DETAILED HEREIN, A LICENSED ENGINEER OR ARCHITECT SHALL PREPARE SITE SPECIFIC DOCUMENTS FOR USE WITH THIS DOCUMENT.



FL #:
FL48241

DATE: **05.28.26**

DWG. BY: **HJ** CHK. BY: **HFN**

SCALE: **NTS**


DWG. #: **ELX001**

SHEET:

6

OF 8


c:\users\sebastianherrerros\building drops, including drops landing - common\projects\enerlux windows and doors\fbp-25-0375 - fbp submittal - fiberglass impact products\dwgs\k\elx001 - w23.dwg 6/22/2026 8:35 AM



A
7 HORIZONTAL SECTION
JAMB

INTERIOR


EXTERIOR



B
7 HORIZONTAL SECTION
MULLION

INTERIOR

EXTERIOR



C
7 HORIZONTAL SECTION
JAMB



1530 PINE AVENUE
CRETE, NE
PH: (402)-205-3055

LOW-PROFILE
PICTURE WINDOW
(WZ3) (IMPACT)
HORIZONTAL SECTIONS

TITLE:

PREPARED BY:

BUILDING DROPS, INC.
1900 NE MIAMI COURT, STE. 2-15
MIAMI, FL 33132
PH: (954) 399-8478
FAX: (954) 744-4738
WEB: www.buildingdrops.com



REMARKS	BY	DATE

THE INSTALLATION DETAILS DESCRIBED HEREIN ARE GENERIC AND MAY NOT REFLECT ACTUAL CONDITIONS FOR A SPECIFIC SITE. IF SITE CONDITIONS CAUSE INSTALLATION TO DEVIATE FROM THE REQUIREMENTS DETAILED HEREIN, A LICENSED ENGINEER OR ARCHITECT SHALL PREPARE SITE SPECIFIC DOCUMENTS FOR USE WITH THIS DOCUMENT.



FL #:
FL48241

DATE: **05.28.26**

DWG. BY: **HJ** CHK. BY: **HFN**

SCALE: **NTS**


DWG. #: **ELX001**

SHEET:

7

OF 8

c:\users\sebastianhereros\building drops, inc\building drops landing - common\projects\enerlux windows and doors\lbc-25-0375 - lbc submittal - fiberglass impact products\dwgs\k\k\elx001 - wz3.dwg 6/2/2026 8:35 AM




A
8

VERTICAL SECTION

HEAD
CLIP INSTALLATION

NOTE: SILL & JAMB SIMILAR




B
8

VERTICAL SECTION

HEAD
THROUGH FRAME INSTALLATION

NOTE: JAMB SIMILAR



C
8

VERTICAL SECTION

HEAD
NAIL FIN INSTALLATION

NOTE: SILL & JAMB SIMILAR

INSTALLATION NOTES:

- (1) ONE INSTALLATION ANCHOR IS REQUIRED AT EACH ANCHOR LOCATION SHOWN, UNLESS OTHERWISE STATED ON SHEETS 4 & 5.
- INSTALL INDIVIDUAL INSTALLATION ANCHORS WITHIN A TOLERANCE OF $\pm 1/2$ INCH THE DEPICTED LOCATION & SPACING IN THE ANCHOR LAYOUT DETAILS (I.E., WITHOUT CONSIDERATION OF TOLERANCES). TOLERANCES ARE NOT CUMULATIVE FROM ONE INSTALLATION ANCHOR TO THE NEXT.
- SHIM AS REQUIRED AT EACH INSTALLATION ANCHOR WITH LOAD BEARING SHIM(S). MAXIMUM ALLOWABLE SHIM STACK TO BE 1/4 INCH. SHIM WHERE SPACE OF 1/16 INCH OR GREATER OCCURS. SHIM(S) SHALL BE CONSTRUCTED OF HIGH DENSITY PLASTIC OR BETTER.
- MINIMUM EMBEDMENT AND EDGE DISTANCE EXCLUDE WALL FINISHES, INCLUDING BUT NOT LIMITED TO STUCCO, FOAM, BRICK VENEER, AND SIDING.
- INSTALLATION ANCHORS AND ASSOCIATED HARDWARE MUST BE MADE OF CORROSION RESISTANT MATERIAL OR HAVE A CORROSION RESISTANT COATING.
- FOR MASONRY OR CONCRETE OPENINGS, A 1X WOOD BUCK MAY BE USED (OPTIONAL) AS LONG AS THE MINIMUM EMBEDMENT AND EDGE DISTANCE REQUIREMENTS ARE STILL MET WITHIN THE CORRESPONDING HOST SUBSTRATE. SEE GENERAL NOTE #3 ON SHEET 1 FOR MORE INFORMATION.
- FOR HOLLOW BLOCK AND GROUT FILLED BLOCK, DO NOT INSTALL INSTALLATION ANCHORS INTO MORTAR JOINTS. EDGE DISTANCE IS MEASURED FROM FREE EDGE OF BLOCK OR EDGE OF MORTAR JOINT INTO FACE SHELL OF BLOCK.
- INSTALLATION ANCHORS SHALL BE INSTALLED IN ACCORDANCE WITH ANCHOR MANUFACTURER'S INSTALLATION INSTRUCTIONS, AND ANCHORS SHALL NOT BE USED IN SUBSTRATES WITH STRENGTHS LESS THAN THE MINIMUM STRENGTH SPECIFIED BY THE ANCHOR MANUFACTURER.

ANCHOR SCHEDULE				
METHOD	SUBSTRATE	ANCHOR TYPE	MIN. EMBEDMENT	MIN. EDGE DISTANCE
NAIL FIN INSTALLATION	WOOD: MIN. SG = 0.55	#8 WOOD SCREW	1.50"	0.75"
	METAL: 18 GAUGE STEEL, MIN. Fy = 33KSI ALUMINUM: 1/8" MIN., 6063-T5	#8 SELF-DRILLING SCREW	3 THREADS MIN PENETRATION BEYOND STRUCTURE	0.50"
CLIP & THROUGH FRAME INSTALLATION	WOOD: MIN. SG = 0.55	#10 WOOD SCREW	1.50"	0.75"
	METAL: 18 GAUGE STEEL, MIN. Fy = 33KSI ALUMINUM: 1/8" MIN., 6063-T5	#10 SELF-DRILLING SCREW	3 THREADS MIN PENETRATION BEYOND STRUCTURE	0.50"
	CONCRETE: f'c=3000PSI	3/16" ITW TAPCON	1.25"	2.00"
	MASONRY: CMU per ASTM C90 MIN. 2000 PSI	3/16" ITW TAPCON	1.00"	2.00"



1530 PINE AVENUE
CRETE, NE
PH: (402)-205-3055

LOW-PROFILE
PICTURE WINDOW
(WZ3) (IMPACT)
ANCHOR DETAILS &
INSTALLATION NOTES

PREPARED BY:
BUILDING DROPS, INC.
1900 NE MIAMI COURT, STE. 2-15
MIAMI, FL 33132
PH: (954) 399-8478
FAX: (954) 744-4738
WEB: www.buildingdrops.com



REMARKS	BY	DATE

THE INSTALLATION DETAILS DESCRIBED HEREIN ARE GENERIC AND MAY NOT REFLECT ACTUAL CONDITIONS FOR A SPECIFIC SITE. IF SITE CONDITIONS CAUSE INSTALLATION TO DEVIATE FROM THE REQUIREMENTS DETAILED HEREIN, A LICENSED ENGINEER OR ARCHITECT SHALL PREPARE SITE SPECIFIC DOCUMENTS FOR USE WITH THIS DOCUMENT.



FL #: **FL48241**

DATE: **05.28.26**

DWG. BY: **HJ** CHK. BY: **HFN**

SCALE: **NTS**

DWG. #: **ELX001**

SHEET: **8** OF 8