


GRAVITY NOTES:

1.	PRODUCT NAME (PATENT NO. 6367209); PREFORMED POWERS STEEL LINTEL SHALL BE GALVANIZED COIL STEEL AS MANUFACTURED BY POWERS STEEL AND WIRE PRODUCTS, INC. STEEL GRADE SHALL BE ASTM A570 GRADE C (FY = 40 ksi). NOTE: DEFORMATIONS DO NOT EFFECT STRUCTURAL CAPACITY. FOR SPANS LESS THAN 18'-0" BOX LINTELS TO BE 22 GA. FOR SPANS GREATER THAN AND EQUAL TO 18'-0" BOX LINTELS TO BE 16 GA.	14.	#5 REINFORCING BAR(S) GRADE 40 ARE TO SET APPROX. 1-1/2" FROM TOP OF ALL LINTEL DESIGNS AND IN SOME CASES THE BOTTOM OF LINTEL AS SHOWN ON LOAD TABLES. TOP HORIZONTAL REINFORCEMENT IS TO BE A CONTINUOUS TIE AS NOTED IN NOTE #9. IN THE CASE THAT THE LINTEL IS NOT WITHIN A COMPOSITE BOND BEAM SYSTEM, TOP HORIZONTAL REINFORCEMENT IS TO EXTEND 2'-0" PAST INSIDE OF JAMBS.
2.	SHORE LINTELS AS REQUIRED TO COMPENSATE FOR DEAD LOAD DEFLECTION ON NON-CURED MASONRY GROUT. ALL LINTELS GREATER THAN 18'-0" ARE BUILT WITH 1/2" CAMBER.	15.	MANUFACTURER: POWERS STEEL 4118 E. ELWOOD PHOENIX, AZ 85040 PH# 602-437-1160 FAX# 602-437-5409
3.	LINTEL TO BE USED WITH BRICK OR CONCRETE MASONRY UNITS HAVING MINIMUM f_m AS SHOWN.	16.	TECHNICAL DATA AND ENGINEERING POWERS LINTELS HAVE BEEN DESIGNED IN ACCORDANCE WITH THE FOLLOWING: + FLORIDA BUILDING CODE - 2023 (EIGHTH EDITION) + AISI NORTH AMERICAN SPECIFICATIONS FOR THE DESIGN OF COLD-FORMED STEEL - 2016 (2020) + TMS 402-16
4.	STEEL SURFACES IN CONTACT WITH GROUT AND/OR MORTAR SHALL BE UNPAINTED AND FREE OF MATERIAL THAT MIGHT INHIBIT BOND.	17.	TECHNICAL ASSISTANCE IS AVAILABLE FROM THE MANUFACTURER ON SPECIAL DESIGN CONCERNS OR LINTEL DEPTHS DIFFERENT THAN THOSE SHOWN IN THE LOAD TABLES. STRUCTURAL ENGINEER FOR THESE LINTELS IS: S.E. CONSULTANTS, INC. 5800 E. THOMAS RD. SUITE 104 SCOTTSDALE, AZ 85251 PHONE No. (480) 946-2010 FAX (480) 946-1909
5.	DESIGN BEARING OF POWERS STEEL LINTELS IS 8" FOR ALL LINTELS GREATER THAN 18'-0" IN SPAN OR GREATER THAN 32" IN DEPTH. ALL OTHER LINTELS REQUIRE A MINIMUM OF 4" BEARING PER THE STANDARD AND FLORIDA BUILDING CODES.		IF AN INSPECTOR, CONTRACTOR, SUBCONTRACTOR, OR PLANS EXAMINER HAS ANY TECHNICAL QUESTIONS PLEASE CALL.
6.	f_m = 1500 psi. MASONRY UNITS SHALL CONFORM TO ASTM C90, GRADE N.	18.	INSTALLATION: POWERS LINTELS ARE TO BE INSTALLED IN ACCORDANCE WITH STANDARD CONSTRUCTIONS PRACTICES, SET TO PROPER LINE AND LEVEL, PLUMB AND TRUE, AND IN CORRECT RELATION TO OTHER WORK.
7.	GROUT = 3,000 psi. SLUMP RANGE: 8" TO 11". ROD OR VIBRATE GROUT ADEQUATELY TO ENSURE CONSOLIDATION OF GROUT (NO AIR POCKETS). GROUT SHALL COMPLY WITH ASTM C476-19 AND BE EITHER COARSE OR FINE GROUT.		
8.	MORTAR: TYPE "S" OR TYPE "M" 1800 psi.		PSbox8LT STEEL LINTELS NOTE: NO SCALE 22 GAGE IS .030 INCHES THICK.
9.	TOP REINFORCING OR TOP OF WALL REINFORCING, IS REQUIRED BY CODES TO PROVIDE A CONTINUOUS TIE AROUND A STRUCTURE AND TO PROVIDE FOR UPLIFT RESISTANCE AT LINTELS.		
10.	ATTACHMENTS TO TOP OF WALL PER ARCHITECTURAL AND/OR ENGINEERING DRAWINGS.		
11.	LIMITATIONS: THE LINTELS SHALL NOT EXCEED THE ALLOWABLE DESIGN LOADS AND SPANS SHOWN IN THIS REPORT. THE LINTELS SHALL NOT BE USED IN A FIRE RESISTANCE RATED ASSEMBLY UNLESS A TEST REPORT DOCUMENTING FIRE RESISTANCE IS SUBMITTED TO THE BUILDING OFFICIAL. A PROPER BARRIER IS REQUIRED WHEN USING CORROSIVE LUMBER PRODUCTS IN CONTACT WITH THE STEEL LINTELS. A PROPER BARRIER WOULD BE A POLYETHYLENE BARRIER WITH A 10 MIL THICKNESS OR TO MAINTAIN A MIN. 1/4" SPACING BETWEEN THE CORROSIVE LUMBER AND STEEL LINTEL. NOT FOR USE IN THE HVHZ IN MIAMI OR BROWARD COUNTIES AT THIS TIME. MIAMI DADE COMPLIANCE IS BEING SOUGHT.		
12.	DEFLECTION LIMITS ARE SET TO L/600 FOR ALL LOADS SHOWN ABOVE THE DARKENED SOLID LINE. DEFLECTION LIMITS ARE SET TO L/360 [LIVE LOAD] AND L/240 [DEAD + LIVE LOAD] FOR ALL LOADS SHOWN BELOW DARKENED SOLID LINE.		
13.	ALL LOADS SHOWN IN TABLES ARE SUPERIMPOSED LOADS. TABLES ARE DATED 01/2024 AND CLEARLY INDICATE SUPERIMPOSED LOADS.		



Powers Steel Product Lintel (Gravity)

LINTEL DESCRIPTION

INDICATES HEIGHT OF GROUT

PSbox8LT - 16"

HEIGHT OF COMPOSITE LINTEL
VARIES - SEE PLAN AND
SCHEDULES.




S.E. CONSULTANTS, INC.



5800 E. THOMAS ROAD, SUITE 104
SCOTTSDALE, ARIZONA 85251
(480) 946-2010 FAX: (480) 946-1909

UPLIFT/LATERAL NOTES:

1.	PRODUCT NAME (PATENT NO. 6367209) PREFORMED POWERS STEEL LINTEL SHALL BE GALVANIZED COIL STEEL AS MANUFACTURED BY POWERS STEEL AND WIRE PRODUCTS, INC. STEEL GRADE SHALL BE ASTM A570 GRADE C (FY = 40 ksi). NOTE: DEFORMATIONS DO NOT EFFECT STRUCTURAL CAPACITY. FOR SPANS LESS THAN 18'-0" BOX LINTELS TO BE 22 GA. FOR SPANS GREATER THAN AND EQUAL TO 18'-0" BOX LINTELS TO BE 16 GA.	14.	#5 REINFORCING BAR (GRADE 40) IS TO SET APPROX. 1-1/2" FROM TOP OF ALL LINTEL DESIGNS AND IN SOME CASES THE BOTTOM OF LINTEL AS SHOWN ON LOAD TABLES. TOP HORIZONTAL REINFORCEMENT IS TO BE A CONTINUOUS TIE AS NOTED IN NOTE #9. IN THE CASE THAT THE LINTEL IS NOT WITHIN A COMPOSITE BOND BEAM SYSTEM, TOP HORIZONTAL REINFORCEMENT IS TO EXTEND 2'-0" PAST INSIDE OF JAMBS.
2.	SHORE LINTELS AS REQUIRED TO COMPENSATE FOR DEAD LOAD DEFLECTION ON NON-CURED MASONRY GROUT. ALL LINTELS GREATER THAN 18'-0" ARE BUILT WITH 1/2" CAMBER.	15.	MANUFACTURER: POWERS STEEL 4118 E. ELWOOD PHOENIX, AZ 85040 PH# 602-437-1160 FAX# 602-437-5409
3.	LINTEL TO BE USED WITH BRICK OR CONCRETE MASONRY UNITS HAVING MINIMUM f_m AS SHOWN.	16.	TECHNICAL DATA AND ENGINEERING POWERS LINTELS HAVE BEEN DESIGNED IN ACCORDANCE WITH THE FOLLOWING: + FLORIDA BUILDING CODE - 2023 (EIGHTH EDITION) + AISI NORTH AMERICAN SPECIFICATIONS FOR THE DESIGN OF COLD-FORMED STEEL - 2016 (2020) + TMS 402-16
4.	STEEL SURFACES IN CONTACT WITH GROUT AND/OR MORTAR SHALL BE UNPAINTED AND FREE OF MATERIAL THAT MIGHT INHIBIT BOND.	17.	TECHNICAL ASSISTANCE IS AVAILABLE FROM THE MANUFACTURER ON SPECIAL DESIGN CONCERNS OR LINTEL DEPTHS DIFFERENT THAN THOSE SHOWN IN THE LOAD TABLES. STRUCTURAL ENGINEER FOR THESE LINTELS IS: S.E. CONSULTANTS, INC. 5800 E. THOMAS RD. SUITE 104 SCOTTSDALE, AZ 85251 PHONE No. (480) 946-2010 FAX (480) 946-1909 IF AN INSPECTOR, CONTRACTOR, SUBCONTRACTOR, OR PLANS EXAMINER HAS ANY TECHNICAL QUESTIONS PLEASE CALL.
5.	DESIGN BEARING OF POWERS STEEL LINTELS IS 8" FOR ALL LINTELS GREATER THAN 18'-0" IN SPAN OR GREATER THAN 32" IN DEPTH. ALL OTHER LINTELS REQUIRE A MINIMUM OF 4" BEARING PER THE STANDARD AND FLORIDA BUILDING CODES.	18.	INSTALLATION: POWERS LINTELS ARE TO BE INSTALLED IN ACCORDANCE WITH STANDARD CONSTRUCTIONS PRACTICES, SET TO PROPER LINE AND LEVEL, PLUMB AND TRUE, AND IN CORRECT RELATION TO OTHER WORK.
6.	f_m = 1500 psi. MASONRY UNITS SHALL CONFORM TO ASTM C90, GRADE N.		
7.	GROUT = 3,000 psi. SLUMP RANGE: 8" TO 11". ROD OR VIBRATE GROUT ADEQUATELY TO ENSURE CONSOLIDATION OF GROUT (NO AIR POCKETS). GROUT SHALL COMPLY WITH ASTM C476-19 AND BE EITHER COARSE OR FINE GROUT.		PShox8LT STEEL LINTELS NOTE: NO SCALE 22 GAGE IS .030 INCHES THICK.
8.	MORTAR: TYPE "S" OR TYPE "M" 1800 psi.		
9.	TOP REINFORCING OR TOP OF WALL REINFORCING, IS REQUIRED BY CODES TO PROVIDE A CONTINUOUS TIE AROUND A STRUCTURE AND TO PROVIDE FOR UPLIFT RESISTANCE AT LINTELS.		
10.	ATTACHMENTS TO TOP OF WALL PER ARCHITECTURAL AND/OR ENGINEERING DRAWINGS.		
11.	LIMITATIONS: THE LINTELS SHALL NOT BE USED IN A FIRE RESISTANCE RATED ASSEMBLY UNLESS A TEST REPORT DOCUMENTING FIRE RESISTANCE IS SUBMITTED TO THE BUILDING OFFICIAL. A PROPER BARRIER IS REQUIRED WHEN USING CORROSIVE LUMBER PRODUCTS IN CONTACT WITH THE STEEL LINTELS. A PROPER BARRIER WOULD BE A POLYETHYLENE BARRIER WITH A 10 MIL THICKNESS OR TO MAINTAIN A MIN. 1/4" SPACING BETWEEN THE CORROSIVE LUMBER AND STEEL LINTEL NOT FOR USE IN THE HVHZ IN MIAMI OR BROWARD COUNTIES AT THIS TIME. MIAMI DADE COMPLIANCE IS BEING SOUGHT.		
12.	ALLOWABLE LOADS SHOWN IN THE TABLES FOR UPLIFT AND LATERAL LOAD CAPACITY INCLUDE A 1/3 INCREASE FOR WIND OR SEISMIC LOADING WITH NO FURTHER INCREASES ALLOWED. TABLE VALUES SHOULD BE USED WITH ALTERNATE ALLOWABLE STRESS COMBINATIONS WITH A W OF 1.3. OTHERWISE REDUCE TABLE VALUES FOR ALLOWABLE STRESS COMBINATION BY 1/3. IF COMBINED LOADING CONDITIONS ARE APPLIED TO THE LINTELS FOR SIMULTANEOUS LOADING DIRECTIONS, THE ALLOWABLE LOADS SHOWN IN THE TABLES MUST BE ADJUSTED USING A UNITY EQUATION.		
13.	ALL LOADS SHOWN IN TABLES ARE SUPERIMPOSED LOADS. TABLES ARE DATED 01/2024 AND CLEARLY INDICATE SUPERIMPOSED LOADS.		



Powers Steel Product Lintel (Lateral)

LINTEL DESCRIPTION

INDICATES HEIGHT OF GROUT

PSbox8LT - 16"

HEIGHT OF COMPOSITE LINTEL
VARIES - SEE PLAN AND
SCHEDULES.




S.E. CONSULTANTS, INC.



5800 E. THOMAS ROAD, SUITE 104
SCOTTSDALE, ARIZONA 85251
(480) 946-2010 FAX: (480) 946-1909

UPLIFT/LATERAL NOTES:

1.	PRODUCT NAME (PATENT NO. 6367209) PREFORMED POWERS STEEL LINTEL SHALL BE GALVANIZED COIL STEEL AS MANUFACTURED BY POWERS STEEL AND WIRE PRODUCTS, INC. STEEL GRADE SHALL BE ASTM A570 GRADE C (FY = 40 ksi). NOTE: DEFORMATIONS DO NOT EFFECT STRUCTURAL CAPACITY. FOR SPANS LESS THAN 18'-0" BOX LINTELS TO BE 22 GA. FOR SPANS GREATER THAN AND EQUAL TO 18'-0" BOX LINTELS TO BE 16 GA.	14.	#5 REINFORCING BAR (GRADE 40) IS TO SET APPROX. 1-1/2" FROM TOP OF ALL LINTEL DESIGNS AND IN SOME CASES THE BOTTOM OF LINTEL AS SHOWN ON LOAD TABLES. TOP HORIZONTAL REINFORCEMENT IS TO BE A CONTINUOUS TIE AS NOTED IN NOTE #9. IN THE CASE THAT THE LINTEL IS NOT WITHIN A COMPOSITE BOND BEAM SYSTEM, TOP HORIZONTAL REINFORCEMENT IS TO EXTEND 2'-0" PAST INSIDE OF JAMBS.
2.	SHORE LINTELS AS REQUIRED TO COMPENSATE FOR DEAD LOAD DEFLECTION ON NON-CURED MASONRY GROUT. ALL LINTELS GREATER THAN 18'-0" ARE BUILT WITH 1/2" CAMBER.	15.	MANUFACTURER: POWERS STEEL 4118 E. ELWOOD PHOENIX, AZ 85040 PH# 602-437-1160 FAX# 602-437-5409
3.	LINTEL TO BE USED WITH BRICK OR CONCRETE MASONRY UNITS HAVING MINIMUM f_m AS SHOWN.	16.	TECHNICAL DATA AND ENGINEERING POWERS LINTELS HAVE BEEN DESIGNED IN ACCORDANCE WITH THE FOLLOWING: + FLORIDA BUILDING CODE - 2023 (EIGHTH EDITION) + AISI NORTH AMERICAN SPECIFICATIONS FOR THE DESIGN OF COLD-FORMED STEEL - 2016 (2020) + TMS 402-16
4.	STEEL SURFACES IN CONTACT WITH GROUT AND/OR MORTAR SHALL BE UNPAINTED AND FREE OF MATERIAL THAT MIGHT INHIBIT BOND.	17.	TECHNICAL ASSISTANCE IS AVAILABLE FROM THE MANUFACTURER ON SPECIAL DESIGN CONCERNS OR LINTEL DEPTHS DIFFERENT THAN THOSE SHOWN IN THE LOAD TABLES. STRUCTURAL ENGINEER FOR THESE LINTELS IS: S.E. CONSULTANTS, INC. 5800 E. THOMAS RD. SUITE 104 SCOTTSDALE, AZ 85251 PHONE No. (480) 946-2010 FAX (480) 946-1909 IF AN INSPECTOR, CONTRACTOR, SUBCONTRACTOR, OR PLANS EXAMINER HAS ANY TECHNICAL QUESTIONS PLEASE CALL.
5.	DESIGN BEARING OF POWERS STEEL LINTELS IS 8" FOR ALL LINTELS GREATER THAN 18'-0" IN SPAN OR GREATER THAN 32" IN DEPTH. ALL OTHER LINTELS REQUIRE A MINIMUM OF 4" BEARING PER THE STANDARD AND FLORIDA BUILDING CODES.	18.	INSTALLATION: POWERS LINTELS ARE TO BE INSTALLED IN ACCORDANCE WITH STANDARD CONSTRUCTIONS PRACTICES, SET TO PROPER LINE AND LEVEL, PLUMB AND TRUE, AND IN CORRECT RELATION TO OTHER WORK.
6.	$f_m = 1500$ psi. MASONRY UNITS SHALL CONFORM TO ASTM C90, GRADE N.		
7.	GROUT = 3,000 psi. SLUMP RANGE: 8" TO 11". ROD OR VIBRATE GROUT ADEQUATELY TO ENSURE CONSOLIDATION OF GROUT (NO AIR POCKETS). GROUT SHALL COMPLY WITH ASTM C476-19 AND BE EITHER COARSE OR FINE GROUT.		PSBox8LT STEEL LINTELS NOTE: NO SCALE 22 GAGE IS .030 INCHES THICK.
8.	MORTAR: TYPE "S" OR TYPE "M" 1800 psi.		
9.	TOP REINFORCING OR TOP OF WALL REINFORCING, IS REQUIRED BY CODES TO PROVIDE A CONTINUOUS TIE AROUND A STRUCTURE AND TO PROVIDE FOR UPLIFT RESISTANCE AT LINTELS.		
10.	ATTACHMENTS TO TOP OF WALL PER ARCHITECTURAL AND/OR ENGINEERING DRAWINGS.		
11.	LIMITATIONS: THE LINTELS SHALL NOT BE USED IN A FIRE RESISTANCE RATED ASSEMBLY UNLESS A TEST REPORT DOCUMENTING FIRE RESISTANCE IS SUBMITTED TO THE BUILDING OFFICIAL. A PROPER BARRIER IS REQUIRED WHEN USING CORROSIVE LUMBER PRODUCTS IN CONTACT WITH THE STEEL LINTELS. A PROPER BARRIER WOULD BE A POLYETHYLENE BARRIER WITH A 10 MIL THICKNESS OR TO MAINTAIN A MIN. 1/4" SPACING BETWEEN THE CORROSIVE LUMBER AND STEEL LINTEL NOT FOR USE IN THE HVHZ IN MIAMI OR BROWARD COUNTIES AT THIS TIME. MIAMI DADE COMPLIANCE IS BEING SOUGHT.		
12.	ALLOWABLE LOADS SHOWN IN THE TABLES FOR UPLIFT AND LATERAL LOAD CAPACITY INCLUDE A 1/3 INCREASE FOR WIND OR SEISMIC LOADING WITH NO FURTHER INCREASES ALLOWED. TABLE VALUES SHOULD BE USED WITH ALTERNATE ALLOWABLE STRESS COMBINATIONS WITH A W OF 1.3. OTHERWISE REDUCE TABLE VALUES FOR ALLOWABLE STRESS COMBINATION BY 1/3. IF COMBINED LOADING CONDITIONS ARE APPLIED TO THE LINTELS FOR SIMULTANEOUS LOADING DIRECTIONS, THE ALLOWABLE LOADS SHOWN IN THE TABLES MUST BE ADJUSTED USING A UNITY EQUATION.		
13.	ALL LOADS SHOWN IN TABLES ARE SUPERIMPOSED LOADS. TABLES ARE DATED 01/2024 AND CLEARLY INDICATE SUPERIMPOSED LOADS.		



Powers Steel Product Lintel (Uplift)

LINTEL DESCRIPTION

INDICATES HEIGHT OF GROUT

PSbox8LT - 16"

HEIGHT OF COMPOSITE LINTEL
VARIES - SEE PLAN AND
SCHEDULES.



S.E. CONSULTANTS, INC.



5800 E. THOMAS ROAD, SUITE 104
SCOTTSDALE, ARIZONA 85251
(480) 946-2010 FAX: (480) 946-1909