

NOTES:

1. VINYL OR WOOD DOOR STOP
NAILED A MAXIMUM OF 6" O.C. MUST
OVERLAP TOP AND BOTH ENDS OF
PANELS MINIMUM 7/16" TO MEET
NEGATIVE PRESSURES.

2. SLIDE LOCK OR OPERATOR
REQUIRED. LOW HEADROOM REQUIRES
A LOCK ON THE LEFT AND RIGHT
SIDE OF THE DOOR.


3. THE DESIGN OF THE SUPPORTING
STRUCTURAL ELEMENTS SHALL BE
THE RESPONSIBILITY OF THE
PROFESSIONAL OF RECORD FOR THE
BUILDING OR STRUCTURE AND IN
ACCORDANCE WITH CURRENT
BUILDING CODES FOR THE LOADS
LISTED ON THIS DRAWING.

4. SECTION STEEL TO HAVE THE
FOLLOWING MINIMUM THICKNESS:
EXTERIOR - 27 GA
INTERIOR - 30 GA

5. TRACK MOUNTING SURFACE TO BE
MINIMUM SOUTHERN PINE
STRUCTURAL GRADE LUMBER. REFER
TO JAMB CONNECTION SUPPLEMENT
FOR ATTACHMENT OF A 2X6 TO THE
BUILDING JAMBS, IF NEEDED.


6. FOR LOW HEAD ROOM LIFT
CONDITIONS, TOP BRACKET SHALL BE
A LHR TOP BRACKET IN LIEU OF
THE BRACKET SHOWN ON THIS
DRAWING. SEE LHR, DETAIL A, SHEET
2.

7. 11 GA ROLLER SLIDES WITH
WELDED ENDS AND 11 GA
REINFORCING BRACKETS REQUIRED
FOR DOORS > 8' TALL.



JOHN E. SCATES, P.E.
2560 KING ARTHUR #124-54
LEWISVILLE, TX 75056
FL PE 51737 TX PE 56308/F-2203

Digitally signed by John E. Scates, P.E.
Date: 2020.08.11 15:47:41 -05'00'



NOTE: (3) SECTION DOOR SHOWN.
SEE SHEET 2 FOR U-BAR LOCATIONS
ON DOORS WITH OTHER SECTION
QUANTITIES.

JAMB BRACKET SCHEDULE			
DOOR HEIGHT	NO. OF SECTIONS	NO. OF JAMB BRACKETS (EACH JAMB)	LOCATION OF CENTERLINE OF JAMB BRACKETS MEASURED FROM BOTTOM OF TRACK (ALL DIMENSIONS ± 2")
7'-0"	3	3	2", 26", 53"
8'-0"	4	4	2", 26", 48", 75"
> 8'-0"			SEE NOTE BELOW

NOTE:

ALL DOORS GREATER THAN 8' IN HEIGHT REQUIRE USE OF CONTINUOUS WALL ANGLE. SEE SUPPLEMENT TRACK CHART FOR DETAILS.


SUPERIMPOSED DESIGN PRESSURE LOADS ON SUPPORTING STRUCTURE

DOOR WIDTH	DOOR HEIGHT	UNIFORM LOAD EACH JAMB (PLF)
9'-0"	ALL	+140.4/-161.1
8'-0"	ALL	+124.8/-143.2

PROFESSIONAL ENGINEER'S SEAL PROVIDED ONLY FOR
VERIFICATION OF WINDLOAD CONSTRUCTION DETAILS.



A DIVISION OF OVERHEAD DOOR CORP
3395 ADDISON DRIVE
PENSACOLA, FLORIDA 32514
(850) 474-9890



This door has been tested per ANSI/DASMA 108

STATIC PRESSURE RATINGS		APPROVED SIZES		SCALE: N.T.S.		SIZE: A	
DESIGN (PSF):	+31.20/-35.80	MAX WIDTH:	9'-0"		DATE		NAME
		MAX HEIGHT:	14'-0"	DRAWN	1/12/06	GRT	
IMPACT/CYCLIC RATED (YES/NO): NO		MAX SECTION HEIGHT: 28"	CHECKED	2/10/06	MRB		
MODELS 9700/9510				SHEET 1 OF 2			
WINDLOAD SPECIFICATION OPTION CODE 0506				DRAWING PART NO.		REV.	
				313587		G	

REVISIONS
D CHANGES MADE
PER ETC
LABORATORIES
TESTING AND
CHANGES TO
GENERAL FORMAT
1/12/06 GRT


E UPDATED TITLE
BLOCK
4/15/13 GRT

F UPDATED FOR
TESTING AND
CHANGES TO
GENERAL FORMAT
8-19-16 GAC

G UPDATED ADDING
NYLON ROLLER PCR
32442 8-5-20 JQ


LOW HEADROOM TRACK

2" STEEL ROLLER WITH 4" STEM. OPTIONAL NYLON, 10/11 BALL BEARLING AVAILABLE.
14GA LHR TOP BRACKET ATTACHED TO DOOR WITH (3) 1/4-20 X 11/16" SELF DRILLING AND (2) #12 X 1/2" PHILLIPS SCREWS



(2) 15 GA HINGE LEAFS ATTACHED WITH (3) 1/4-14x5/8" CRIMPTITE SCREWS EACH


14 GA HINGE BASE FACTORY ATTACHED TO DOOR WITH (5) 1/4-14x5/8" CRIMPTITE SCREWS



2" STEEL ROLLER WITH 9" STEM. OPTIONAL NYLON, 10/11 BALL BEARLING AVAILABLE.
13 GA ROLLER CARRIERS FACTORY ATTACHED TO HINGE BASE AND REINFORCING BRACKET. (EXCEPTION: NOTE #7)


BEFORE U-BAR INSTALLATION

13 GA REINFORCING BRACKET ATTACHED BENEATH HINGE BASE. (EXCEPTION: NOTE #7)



15 GA HINGE ATTACHED WITH (6) 1/4-14x5/8" CRIMPTITE SCREWS

BEFORE U-BAR INSTALLATION



JOHN E. SCATES, PE
2560 KING ARTHUR #124-54
LEWISVILLE, TX 75056
FL PE 51737 TX PE 56308/F-2203

PROFESSIONAL ENGINEER'S SEAL PROVIDED ONLY FOR VERIFICATION OF WINDLOAD CONSTRUCTION DETAILS.

STANDARD LIFT TRACK


13 GA STEEL ROLLER SLIDE ATTACHED WITH (2) 1/4-20x5/8" CARRIAGE BOLTS, (2) RETENSION WASHERS, AND (2) 1/4-20 HEX FLANGE NUT.

2" STEEL ROLLER WITH 4" STEM. OPTIONAL NYLON, 10/11 BALL BEARLING AVAILABLE.
13 GA COMMERCIAL 'A' FRAME TOP BRACKET ATTACHED WITH (4) 1/4-20x7/8" SELF DRILLING SCREWS



13 GA ROLLER SLIDE ATTACHED TO BRACKET WITH 5/16-18 BOLT & NUT IN CENTER SLOT AND 1/4-20x9/16" TRACK BOLT & 1/4-20 HEX NUT THROUGH ANY TWO ALIGNING HOLES

DETAIL A



POSITION U-BAR OVER REINFORCING BRACKET AND ATTACH WITH (3) 1/4-20x7/8" SELF DRILLING SCREWS AS SHOWN (2 OF WHICH ATTACH THROUGH REINFORCING BRACKET)

AFTER U-BAR INSTALLATION

DETAIL B




POSITION U-BAR OVER HINGE LEAF AND ATTACH WITH (1) 1/4-14x5/8" CRIMPTITE SCREW AND (1) 1/4-20x7/8" SELF DRILLING SCREW AS SHOWN (SELF DRILLING SCREW ATTACHES THROUGH HINGE LEAF)

AFTER U-BAR INSTALLATION

DETAIL C

15 GA HINGE BRACKET ATTACHED WITH (2) 1/4-20x7/8" SELF DRILLING SCREWS



BEFORE U-BAR INSTALLATION


POSITION U-BAR OVER HINGE BRACKET AND ATTACH WITH (1) 1/4-14x5/8" CRIMPTITE SCREW AND (1) 1/4-20x7/8" SELF DRILLING SCREW AS SHOWN (SELF DRILLING SCREW ATTACHES THROUGH HINGE BRACKET)



AFTER U-BAR INSTALLATION

DETAIL D

UNLESS NOTED OTHERWISE, ALL U-BARS SHALL BE ATTACHED WITH A MINIMUM OF (2) FASTENERS AT EACH END, AT ALL INTERMEDIATE HINGE LOCATIONS (OR IN LINE WITH INTERMEDIATE HINGE LOCATIONS IF U-BAR IS NOT LOCATED AT A HINGE), AND MIDWAY BETWEEN INTERMEDIATE HINGE LOCATIONS (MINIMUM OF (10) FASTENERS EACH U-BAR). ALL FASTENERS USED TO ATTACH U-BARS SHALL BE 1/4-14x5/8" CRIMPTITE SCREWS EXCEPT 1/4-20x7/8" SELF DRILLING SCREWS SHALL BE USED AT END CAPS AND WHERE FASTENING THROUGH HINGE LEAFS OR BRACKETS.




U-BAR LOCATIONS (7) SECTION DOORS WITH (8) 3" 20 GA 80 KSI U-BARS LOCATED AS SHOWN (TOP BRACKET REMOVED FOR CLARITY)

(6) SECTION DOORS WITH (7) 3" 20 GA 80 KSI U-BARS LOCATED AS SHOWN (TOP BRACKET REMOVED FOR CLARITY)

(5) SECTION DOORS WITH (6) 3" 20 GA 80 KSI U-BARS LOCATED AS SHOWN (TOP BRACKET REMOVED FOR CLARITY)

(4) SECTION DOORS WITH (5) 3" 20 GA 80 KSI U-BARS LOCATED AS SHOWN (TOP BRACKET REMOVED FOR CLARITY)

(3) SECTION DOORS WITH (4) 3" 20 GA 80 KSI U-BARS LOCATED AS SHOWN (TOP BRACKET REMOVED FOR CLARITY)



REVISIONS



A DIVISION OF OVERHEAD DOOR CORP
3395 ADDISON DRIVE
PENSACOLA, FLORIDA 32514
(850) 474-9890

STATIC PRESSURE RATINGS		APPROVED SIZES		SCALE: N.T.S.		SIZE: A	
DESIGN (PSF):	+31.20/-35.80	MAX WIDTH:	9'-0"	DATE	1/12/06	NAME	GRT
IMPACT/CYCLIC RATED (YES/NO): NO		MAX HEIGHT:	14'-0"	DRAWN	2/10/06	MRB	
MODELS 9700/9510				SHEET 2 OF 2			
WINDLOAD SPECIFICATION OPTION CODE 0506				DRAWING PART NO.		REV.	
				313587		G	