

Evaluation Report

"200 MS"

Metal Roof Assembly

Manufacturer:

Streamline Roofing & Construction, Inc.

3654 W. Orange Ave.

Tallahassee, Florida 32310

(850) 575-1168

for

Florida Product Approval

FL 7207.8 R6

Florida Building Code 8th Edition (2023)

Method: 1 - D

Category: Roofing

Sub - Category: Metal Roofing

Product: "200 MS"

Material: Steel

Support: Steel Deck

Prepared by:

James L. Buckner, P.E., S.E.C.B.

Florida Professional Engineer # 31242

Florida Evaluation ANE ID: 1916

Project Manager: Diana Galloway

Report No. 23-625-200MS-S4S-ER

(Revises 20-228-200MS-S4S-ER, FL7207.8 R5)


Date: 10/17/2023

Contents:

Evaluation Report

Pages 1 – 7

This item has been digitally signed and sealed by James L. Buckner, P.E., on this date below. Printed copies of this document are not considered signed and sealed, and the signature must be verified on any electronic copies.



James L. Buckner, P.E.

FL31242

Date: 2023.10.17

'11:05:47 -04'00

CBUCK, Inc. dba CBUCK Engineering

Phone: (561) 491-9927 · Email: cbuck@cbuckinc.net · Website: www.cbuckinc.net

Business: 1374 Community Dr., Jupiter, FL 33458

Manufacturer:	Streamline Roofing 3654 W. Orange Ave. Tallahassee, Florida 32310 (850) 575-1168 http://www.streamlineroofing.com/
Product Name:	"200 MS"
Product Category:	Roofing
Product Sub-Category	Metal Roofing
Compliance Method:	State Product Approval Rule 61G20-3.005 (1) (d)
Product/System Description:	"200 MS" 24 gauge Steel roof panel mechanically attached to Steel Deck with screws.
Product Assembly as Evaluated:	Refer to Page 4 of this report for product assembly components/materials & standards: 1. Roof Panel 2. Fasteners 3. Underlayment 4. Insulation (Optional) 5. Bearing Plate (Optional)
Support:	Type: Steel Deck (Design of steel deck and its attachment to support framing is outside the scope of this evaluation.) Description: • 22 Gauge minimum • Yield Strength: 40 ksi minimum
Slope:	Minimum slope shall be in compliance with FBC Chapter 15 based on the type of roof covering, applicable code sections and in accordance with manufacturer's recommendations.
Performance:	Wind Uplift Resistance: • Design Uplift Pressure: (Refer to "Table A" attachment details herein) Refer To Table "A"

Performance Standards:	The product described herein has demonstrated compliance with: • UL580-06 – <i>Test for Uplift Resistance of Roof Assemblies</i>
Standards Equivalency:	The UL580-94 standard version used to test the product meets the prescribed standards in UL580-06 standard version adopted by the Florida Building Code 8th Edition (2023) for use as evaluated in this report.
Code Compliance:	The product described herein has demonstrated compliance with Florida Building Code 8th Edition (2023).
Evaluation Report Scope:	This product evaluation is limited to compliance with the structural requirements of the Florida Building Code, as related to the scope section to Florida Product Approval Rule 61G20-3.001.
Limitations and Conditions of Use:	• <u>Scope of “Limitations and Conditions of Use” for this evaluation:</u> This evaluation report for “Optional Statewide Approval” contains technical documentation, specifications and installation method(s) which include “Limitations and Conditions of Use” throughout the report in accordance with Rule 61G20-3.005. Per Rule 61G20-3.004, the Florida Building Commission is the authority to approve products under “Optional Statewide Approval”. • <u>Option for application outside “Limitations and Conditions of Use”</u> Rule 61G20-3.005(1)(e) allows engineering analysis for “project specific approval by the local authorities having jurisdiction in accordance with the alternate methods and materials authorized in the Code”. Any modification of the product as evaluated in this report and approved by the Florida Building Commission is outside the scope of this evaluation and will be the responsibility of others. • This report is a building code product evaluation per FLPE rule (FAC) 61G15-36 to comply with Florida product approval rule (FAC) 61G20-3. This evaluation report is part of the Florida Building Commission approval for the listed code related criteria. This report by James Buckner, P.E. and CBUCK Engineering is not a design certification of code compliance construction submittal documentation, per FBC section 107, for any individual structure, site specific or permit design. • All metal components and fasteners shall be corrosion resistant in accordance with applicable sections of FBC, including but limited to Sections 1504.3.2, 1506.6 and 1507.4.4. • Design of support system is outside the scope of this report. • Fire Classification is outside the scope of Rule 61G20-3, and is therefore not included in this evaluation. • This evaluation report does not evaluate the use of this product for use in the High Velocity Hurricane Zone code section. (Dade & Broward Counties)
Quality Assurance:	The manufacturer has demonstrated compliance of roof panel products in accordance with the Florida Building Code and Rule 61G20-3.0005 (3) for manufacturing under a quality assurance program audited by an approved quality assurance entity through UL, LLC (FBC Organization #: QUA 9625).

**Components/Materials
(by Manufacturer):**

Roof Panel: "200 MS"
Material: Steel
Thickness: 24 gauge (min.)
Panel Width(s): 16" (max.) Coverage
Rib Height: 2"
Yield Strength: 40 ksi min.
Corrosion Resistance: In compliance with FBC Section 1507.4.3:

- ASTM A792 coated, or
- ASTM A653 G90 galvanized steel

Roof Panel Clips:

Type: Two-part, floating assembly
Material/Thickness: Upper Tab: 24 Ga. Galv. Steel or Stainless Steel
Base: 18 Ga. Stainless Steel
Yield Strength: 40 ksi min.
Dimensions: Upper Tab: 3-1/2" (tall) x 3" (wide)
Base: 1" (wide) x 1-1/4" (long)
Corrosion Resistance: Per FBC Section 1506.7

Fastener:

Type: Hex-Head Self-Drilling Screws with WSW
Size : #12 - 14 x 1"
Corrosion Resistance: Per FBC Section 1506.6 and 1507.4.4
Standard: Per 1507.4.4 and SAE J78-1979

Underlayment:

Material and application shall be in compliance with FBC Section 1507.1.1 and in accordance with applicable code sections and manufacturer's recommendations.

**Components/Materials
(by Others):**

Insulation (Optional):

Type: Rigid Insulation Board
Thickness: 3" (max.)
Properties:
Density: 2.25 pcf (lbs/ft³) min.
Or Compressive Strength: 20 psi min.

Bearing Plate (Optional with Insulation)

Material: Steel
Thickness: 18 gauge min.
Yield Strength: 50 ksi min.
Dimensions: 3" (wide) x 3-1/4" (long) with 3/8" legs
Corrosion Resistance: Per FBC Section 1506.7

Insulation shall comply with FBC Section 1508. When insulation is incorporated, fastener length shall conform to penetrate thru bottom of support a minimum of 3/4".

Installation:

Installation Method:

(Refer to drawings at the end of this report.)

- Clip spacing: **Refer to Table "A" Below**
(along the length of the panel)
- Rib Interlock: Mechanically seamed 45°
(Panel ribs shall be mechanically seamed.)
- Minimum fastener penetration thru bottom of support, 3/4".
- For panel construction at the end of panels, refer to manufacturer's instructions and any site specific design.

TABLE "A"	
	METHOD 1:
Design Pressure*:	- 52.5 PSF
Clip Spacing:	30"
# Fasteners per Clip:	2
Panel Interlock:	45° Seam
* Allowable design pressure(s) for allowable stress design (ASD).	


Install the "200 MS" roof panel assembly in compliance with the installation method listed in this report and applicable code sections of FBC 8th Edition (2023). The installation method described herein is in accordance with the scope of this evaluation report. Refer to manufacturer's installation instructions as a supplemental guide for attachment.

Referenced Data:


1. Uplift Class 90 Based on UL580-94
By Underwriters Laboratories, Inc.
Construction No. , TGKX.238A (FBC Organization #CER ID: 1739)
2. Quality Assurance
By UL, LLC (FBC Organization #: QUA 9625)
3. Engineering Analysis
By CBUCK Engineering
4. Equivalency of Test Standard Certification
By James L. Buckner, P.E. @ CBUCK Engineering
(FBC Organization # ANE 1916)
5. Certification of Independence
By James L. Buckner, P.E. @ CBUCK Engineering
(FBC Organization # ANE 1916)

Installation Method Streamline Roofing "200 MS" Steel Roof Panel Attached to Steel Deck

Profile Drawings




Typical Panel Profile View




Typical Panel Clip Profile

Installation Method Streamline Roofing "200 MS" Steel Roof Panel Attached to Steel Deck



Typical Assembly Profile View



Typical Assembly Isometric View

TABLE "A"	
	METHOD 1:
Design Pressure:	- 52.5 PSF
Clip Spacing:	30"
# Fasteners per Clip:	2
Panel Interlock:	45° Seam