

REVISIONS	
P1 MODIFIED NOTES TO STATE THAT LOUVERS ARE NOT IMPACT RESISTANT.	GRT 6/29/07
P2 ADDED IMPACT RESISTANT GLAZING.	
ADDED DETAIL E SHEET 2 FOR GLAZING. ADDED MAX GLAZING DIMENSION TO NOTES SHEET 1. MODIFIED JAMB BRACKET SCHEDULE. ADDED TRACK TO FLAG CONNECTION NOTE.	GRT 11/10/07
P3 MODIFIED LOUVER OPTION. ADDED TEXAS LICENSE NUMBER TO TITLE BLOCK.	GRT 9/19/08
P4 UPDATED TITLE BLOCK AND IMPACT GLAZING	GRT 4/16/12
P5 UPDATED TITLE BLOCK	ESC 10/3/17
P6 UPDATED TITLE BLOCK, REV PER ER 31052	ESC 9/25/18
P7 UPDATED NOTES	
ADDED LHR DETAIL ER 31052	
ESC 2/12/19	

12 GA ROLLER SLIDE ATTACHED TO BRACKET WITH 5/16-18 BOLT & NUT IN CENTER SLOT AND 1/4-20x9/16" TRACK BOLT & 1/4-20 HEX NUT THROUGH ANY TWO ALIGNING HOLES

(2) 12 GA COMMERCIAL 'A' FRAME TOP BRACKETS EACH ATTACHED WITH (4) 1/4-14x7/8" SELF DRILLING CRIMPITTE SCREWS

ADD (2) 1/4-14x7/8" SELF DRILLING CRIMPITTE SCREWS (INSIDE OF EACH INSIDE END HINGE)









2" STEEL ROLLER WITH 9" GRADE 1144 OR EQUIVALENT STEM AND 7/16" PUSHNUT AT EACH ROLLER LOCATION. 1/4" MAX BETWEEN PUSHNUT AND BRACKET OR HINGE. OPTIONAL- 11 BALL BEARING NYLON ROLLER WITH 9" GRADE 1144 OR EQUIVALENT STEM

#1 HINGE IS 14 GA
#2 HINGE IS 13 GA
#3 HINGE (AND ALL ABOVE) ARE 13 GA WIDE BODY END HINGE ATTACHED WITH (4) 1/4-14x5/8" SELF TAPPING SCREWS

14 GA WIDE BODY INTERMEDIATE HINGE ATTACHED WITH (4) 1/4-14x5/8" SELF TAPPING SCREWS

12 GA EXTENSION BRACKET ATTACHED WITH (3) 1/4-14x7/8" SELF DRILLING CRIMPITTE SCREWS (2 THROUGH STRUT AND BRACKET)

14 GA BOTTOM BRACKET ATTACHED WITH (4) 1/4-14x7/8" SELF DRILLING CRIMPITTE SCREWS (2 OF WHICH IS THROUGH STRUT AND AND (1) 1/4-14x5/8" SELF DRILLING RED SCREW



REVISIONS

P1 MODIFIED NOTES TO STATE THAT LOUVERS ARE NOT IMPACT RESISTANT.
GRT 6/29/07

P2 ADDED IMPACT RESISTANT GLAZING. ADDED DETAIL E SHEET 2 FOR GLAZING. ADDED MAX GLAZING DIMENSION TO NOTES SHEET 1. MODIFIED JAMB BRACKET SCHEDULE. ADDED TRACK TO FLAG CONNECTION NOTE.
GRT 11/10/07


P3 MODIFIED LOUVER OPTION. ADDED TEXAS LICENSE NUMBER TO TITLE BLOCK.
GRT 9/19/08

P4 UPDATED TITLE BLOCK AND IMPACT GLAZING
GRT 4/16/12

P5 UPDATED TITLE BLOCK
ESC 10/3/17

P6 UPDATED TITLE BLOCK, REV PER ER 31052
ESC 9/25/18

P7 UPDATED NOTES ADDED LHR DETAIL ER 31052
ESC 2/12/19



PROFESSIONAL ENGINEER'S SEAL PROVIDED ONLY FOR VERIFICATION OF WINDLOAD CONSTRUCTION DETAILS.

JOHN E. SCATES, PE
2560 KING ARTHUR BLVD #124-54
LEWISVILLE, TX 75056
FL PE 51737
TX PE 56308/F2203

Wayne Dalton
GARAGE DOORS

A DIVISION OF OVERHEAD DOOR CORP
3395 ADDISON DRIVE
PENSACOLA, FLORIDA 32514
(850) 474-9890

STATIC PRESSURE RATINGS		APPROVED SIZES		SCALE: N.T.S.	SIZE: A
DESIGN (PSF):	+34.40/-38.30	MAX WIDTH:	16'-0"	DATE	NAME
TEST (PSF):	+51.60/-57.45	MAX HEIGHT:	14'-0"	DRAWN	GRT
IMPACT/CYCLIC RATED (YES/NO):	YES	MAX SECTION HEIGHT:	21"	CHECKED	MRB
MODELS 8000/8100/8200				SHEET 2 OF 2	
WINDLOAD SPECIFICATION OPTION CODE 1124				DRAWING PART NO.	REV.
				327018	P7