



1500 Brigantine Drive
Coquitlam, BC V3K 7C1

Telephone: (604) 520-3321
Facsimile: (604) 524-9186
www.intertek.com

January 15, 2016

Letter Report No. 102389845COQ-002c
Project No. G102389845

Douglas Bennion
Quad-Lock Building Systems Ltd.
7398 132 Street
Surrey, BC, V3W 4M7
Canada

Ph: 604-590-3111
Fx: 604-590-8412

email: douglas@quadlock.ocm

RE: Equivalency Letter– FL# 10431

Intertek Testing Services has reviewed ASTM E2634 (2011) “*Standard Specification for Flat Wall Insulating Concrete Form (ICF) Systems*”, and has determined that products complying with the 2011 version also comply with the 2008 version which is referenced in the 2014 Florida Building Code (FBC). Intertek has also reviewed ASTM E119 “*Test Methods for Fire Tests of Building Construction and Materials*” (2014) and UL 723 “*Standard for Test for Surface Burning Characteristics of Building Materials*” (2010), and has determined that these editions of the standards are equivalent to the 2008 editions referenced in the 2014 FBC.

If you have any questions, please do not hesitate to contact me at (604) 528-4304.

Regards,

INTERTEK TESTING SERVICES NA

Emma Amiralaei, EIT
Engineer- Evaluation Services

Peter Gildenstern, Eng.L.
Manager – Manufactured Housing



All services undertaken are subject to the following general policy: This report is for the exclusive use of Intertek Testing Services NA Ltd.'s (Intertek's) client and is provided pursuant to the agreement between Intertek and its client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the client is authorized to copy or distribute this report and then only in its entirety. Intertek must first approve any use of the Intertek name or one of its marks for the sale or advertisement of the testing materials, product or service in writing. The observations and test results in the report are relevant only to the sample tested. This report by itself does not imply that the material, product or service is or has ever been under Intertek's certification program.