#### Rule 61G20-3.015(4)(d) F.A.C. | Report No. 2744-EER, Rev. 1 | Project No. 422-0903 | 6/13/23 | Page 1 of 6

Product Manufacturer

Mitsubishi Chemical America, Alpolic Division Series ' 401 Volvo Parkway

Chesapeake, VA 23320

Product Name, Model and/or Description

Series "Alpolic and Alpolic/FR" Composite Wall Panel Systems Small Missile Impact Resistant

Code: Current Edition of the Florida Building Code including the 8th Edition (2023) Florida Building Code

Compliance Method: 61G20-3.015(4)(d) - Equivalency of Standards

Product Name, Model and/or Designation: Products covered by this evaluation include the following.

 Mitsubishi Chemical America, Alpolic Division Series "Alpolic and Alpolic/FR" Composite Wall Panel Systems – Small Missile Impact Resistant

Product Testing, Materials and Certification:

- Performance Testing per TAS 201, TAS 202 and TAS 203:
  - Test report on Small Missile Impact Test, Cyclic Wind Pressure Test, and Uniform Static Air Pressure Test on Alpolic and Alpolic/FR Composite Wall Panel Systems, prepared by Architectural Testing Inc., Report No. 01-35789.02, dated 05/31/00, signed and sealed by Allen Reeves, P.E.
  - Test report on Small Missile Impact Test, Cyclic Wind Pressure Test, and Uniform Static Air Pressure Test on Alpolic and Alpolic/FR Composite Wall Panel Systems, prepared by Architectural Testing Inc., Report No. 01-43055.01, dated January 07, 2003, signed, and sealed by Joseph A. Reed, P.E.
  - Test report on Small Missile Impact Test, Cyclic Wind Pressure Test, and Uniform Static Air Pressure Test on Alpolic and Alpolic/FR Composite Wall Panel Systems, prepared by Architectural Testing Inc., Report No. 67392.01-109-18, dated October 27, 2006, signed, and sealed by Joseph A. Reed, P.E., on May 30, 2012.
- Material Testing:
  - Southwest Research Institute, Report No. 01-8361-038, ASTM D1929-91a for Ignition Properties, 4mm Alpolic/FR, dated 10/28/96, signed by Betty J Covey and Alex B. Wenzel.
  - United States Testing Co. Inc., Report No. 100727-3, ASTM D1929-91a for Ignition Properties, 4mm Alpolic
  - Southwest Research Institute, Report No. 01-8361-320d, ASTM E84-97 for Flame Spread Index and Smoke Developed Index, 4mm Alpolic, dated 09/18/97, signed by Anthony L. Sauceda and Alex B. Wenzel.
  - Southwest Research Institute, Report No. 01-7520-359a, ASTM E84-95 for Flame Spread Index and Smoke Developed Index, 4mm Alpolic/FR, dated 09/26/96, signed by Anthony L. Sauceda and Alex B. Wenzel.
  - ATI, Report No. 01-43055.02, ASTM E8-00 for Tensile Strength, 4mm Alpolic, dated March 04, 2003, signed, and sealed by Joseph A. Reed, P.E.
  - ATI, Report No. 01-35789.03, ASTM E8-96 for Tensile Strength, 4mm Alpolic and 4mm Alpolic/FR, dated July 07, 2000, signed, and sealed by Allen N Reeves, P.E.
  - o Intertek Test Report No. E6899.01-106-31, dated 4/22/15, ASTM D635-14 Rate of Burn, 4mm Alpolic/FR.
  - US Testing Co. Test Report No. 100727-1, dated 4/12/91, ASTM D635 (year not recorded) Rate of Burn, 4mm Alpolic.
  - Spec. Data issued by Alcoa Mill Products, dated November 08, 2000, with chemical composition and mechanical properties of Aluminum Alloy 3105-H14

Testing performed to specification revision levels above predate the current edition of the Florida Building Code requirements.



Rule 61G20-3.015(4)(d) F.A.C. | Report No. 2744-EER, Rev. 1 | Project No. 422-0903 | 6/13/23 | Page 2 of 6

- Materials:
  - Alpolic and Alpolic/FR aluminum composite metal panel 4mm thick (0.157") as manufactured by Mitsubishi Chemical America, Alpolic Division, Chesapeake, VA. Core comprised of thermoplastic material. Face sheet comprised of 0.020" aluminum 3105-H14 alloy.
  - Aluminum extrusions (6063-T6).

Product Installation Instructions:

• MCCA/PTC PDG Drawing No. MPCA0002, Rev. 7, dated 6/13/23 Series "Alpolic and Alpolic/FR" Composite Wall Panel Systems – Small Missile Impact, signed and sealed by Robert. J. Amoruso, P.E. Florida No. 49752.

Engineering Analysis & Evaluation: The following evaluations, engineering and/or rational analysis/calculations have been performed.

 Product Evaluation to the current edition of the Florida Building Code as documented in PTC PDG Report No. 2744-PER, prepared by Robert J. Amoruso, P.E. in accordance with Product Approval Rule 61G20-3.005(1)(d) – Product Evaluation Report by a Licensed Professional Engineer

Equivalency Evaluation:

- Appendix 1 table shows the material testing results and ASTM revision level used in testing.
- The table below shows the TAS and ASTM revision level used in testing vs. the current edition of the Florida Building Code.

Tests Conducted	Test Report No.	TAS/ASTM Used in Testing	TAS/ASTM in 2023 FBC and/or FRC	
Performance Testing for AWS and Impact/Cyclic Loading	Architectural Testing Inc., Report No. 67392.01-109-18, 01- 35789.02 and 01-43055.01	TAS 201-94 TAS 202-94 TAS 203-94	TAS 201-94 TAS 202-94 TAS 203-94	
Ignition Properties	Southwest Research Institute, Report No. 01-8361-038 and United States Testing Co. Inc., Report No. 100727-3	ASTM D1929-91a	ASTM D1929-16	
Flame Spread Index and Smoke Developed Index	Southwest Research Institute, Report No. 01-8361-320d	ASTM E84-97	ASTM E84-18b	
Flame Spread Index and Smoke Developed Index	Southwest Research Institute, Report No. 01-7520-359a	ASTM E84-95	ASTM E84-18b	
Tensile Strength	gth ATI, Report No. 01-43055.02		n/a	
Tensile Strength	ATI, Report No. 01-35789.03	ASTM E8-96	n/a	
Rate of Burn	Intertek Test Report No. E6899.01-106-31	ASTM D635-14	ASTM D635-14	
Rate of Burn			ASTM D635-14	
Materials Report	Spec. Data issued by Alcoa Mill Products, dated January 16, 2013 with chemical composition and mechanical properties of Aluminum Alloy 3105-H14		Mill Certification	



#### Rule 61G20-3.015(4)(d) F.A.C. | Report No. 2744-EER, Rev. 1 | Project No. 422-0903 | 6/13/23 | Page 3 of 6

The ASTM specifications forming the basis for material testing of the 4mm Alpolic and 4mm Alpolic/FR panels have been reviewed against the ASTM specification revision levels currently required by the code and found that no changes exist in testing that would negate the existing test results. Therefore, compliance with the current edition of the Florida Building Code is verified.

Review of the TAS 202 and 203 testing to that required in the current edition of the Florida Building Code is verified and found to be in compliance.

#### Certificate of Independence per Product Approval Rule 61G20-3.009

PTC Product Design Group, LLC and Robert J. Amoruso, P.E. does not have, nor will acquire, any financial interest in the company manufacturing or distributing product(s) covered by this Product Evaluation Report. PTC Product Design Group, LLC and Robert J. Amoruso, P.E. do not have, nor will acquire any financial interest in any other entity involved in the approval process or testing of the product(s) covered by this Product Evaluation Report.

> Evaluated By: Robert J. Amoruso, P.E. FL P.E. License Number 49752



Rule 61G20-3.015(4)(d) F.A.C. | Report No. 2744-EER, Rev. 1 | Project No. 422-0903 | 6/13/23 | Page 4 of 6

#### **Appendix 1: Testing**

	Materials Testing						
Tests Conducted	Test Report No.	Test Report Date	ASTM Used in Testing	ASTM in Current FBC	Result	Code Compliance	Material
Performance Testing for AWS and Impact/Cyclic Loading	Architectural Testing Inc., Report No. A8556.01-109- 18, 01-35789.02 and 01- 43055.01	5/30/12, 5/31/00 and 1/7/03 respectively	TAS 202-94 TAS 203-94	TAS 202-94 TAS 203-94	+70/-90 psf	HVHZ Large and Small Missile Impact	4mm Alpolic 4mm Alpolic/FR
Ignition Properties 4mm Alpolic/FR	Southwest Research Institute, Report No. 01- 8361-038	10/28/1996	ASTM D1929- 91a	ASTM D1929- 12	Self-Ignition Temp = 837°F Flash Ignition Temp = 811°F	Self-Ignition Temp > 650 degrees Flash Ignition Temp not code requirement.	4mm Alpolic/FR
Ignition Properties 4mm Alpolic	United States Testing Co. Inc., Report No. 100727-3	4/30/91	ASTM D1929- 91a	ASTM D1929- 12	Self-Ignition Temp = 752°F Flash Ignition Temp = 716°F	Self-Ignition Temp > 650 degrees Flash Ignition Temp not code requirement.	4mm Alpolic
Flame Spread Index and Smoke Developed	Southwest Research	0/40/4007		ASTM E84-	Flame Spread Index = 0	Smoke Density < 450 or Flame Spread < 75	4mm Alpolic
Index 4mm Alpolic	Institute, Report No. 01- 8361-320d	9/18/1997	ASTM E84-97	13a Sm	Smoke Developed Index = 0		
Flame Spread Index and Smoke Developed	Southwest Research Institute, Report No. 01-	9/26/1996	ASTM E84-95	ASTM E84- 13a	Flame Spread Index = 0	Smoke Density < 450 or Flame Spread < 75	4mm Alpolic/FR
Index 4mm Alpolic/FR	7520-359a	9/20/1990	ASTIVI 284-95		Smoke Developed Index = 10		
Tensile Strength 4mm Alpolic	ATI, Report No. 01- 43055.02	3/4/2003	ASTM E8-00	n/a	Fty = 5693 psi average of two tests	Not Applicable	4mm Alpolic
Tensile Strength 4mm Alpolic & 4mm Alpolic/FR	ATI, Report No. 01- 35789.03	7/7/2000	ASTM E8-96	n/a	Ftu =7452 psi	Not Applicable	4mm Alpolic

Rule 61G20-3.015(4)(d) F.A.C. | Report No. 2744-EER, Rev. 1 | Project No. 422-0903 | 6/13/23 | Page 5 of 6

#### **Appendix 1: Testing**

Materials Testing							
Tests Conducted	Test Report No.	Test Report Date	ASTM Used in Testing	ASTM in Current FBC	Result	Code Compliance	Material
Rate of Burn 4mm Alpolic/FR	Intertek Test Report No. E6899.01-106-31	4/22/15	ASTM D635- 14	ASTM D635- 14	CC1	CC1	4mm Alpolic/FR
Rate of Burn 4mm Alpolic	US Testing Co. Test Report No. 100727-1	4/12/91	ASTM D635 (year not recorded)	ASTM D635- 14	CC1	CC1	4mm Alpolic
Materials Report	Spec. Data issued by Alcoa Mill Products, dated January 16, 2013 with chemical composition and mechanical properties of Aluminum Alloy 3105-H14	1/16/2013	Mill Certification	Mill Certification	See Report in Appendix 2	Not Applicable	Aluminum Alloy 3105-H14



0001529739 1/16/2013 6,590 -These commodities, technology and software exported from the United States in accordance with the Export Administration Regulations. Diversion contrary to U.S. Law prohibited. This certification complies with EN 10204:2004. 330351 OF -CERT NO SKID WGT SKID NO SUPERVISOR 2 SIDES DATE PAGE OUT: STANDARD MILL FINISH IN: STANDARD MILL FINISH TI 0.03 I. NON ANODIZE QUALITY CONVERSION COATED LAB ZN 0.12 EMBOSSED KREADY, MITSUBISHI CHEMICAL FUNCTIONAL PROD NI 0.005 NOT Certification of Test Results JEFF 23320 CR 0.03 #2 401 VOLVO PKWY BLDG CHESAPEAKE , VA 23 Authorized By: CHEMISTRY EXPRESSED AS % W/W FOR EACH REPORTED ELEMENT MG 0.57 MECHANICAL PROPERTIES ACCORDING TO ASTM B-557-10 CHEMICAL COMPOSITION ACCORDING TO ASTM E-1251-11 hereby certify that, unless otherwise indicated, the material covered by this report has been manufactured, inspected, testion in accordance with, and has been found to meet, the applicable equirements testime the manufactured, including any clications forming a part of the description and that samples representative of the material met the composition. Also, that meeting a part of the description and that samples to the material were the composition. Also, that meeting is not a normal contaminant alloys and neither in or any of its compounds are used in the unitart is not a normal contaminant alloys and neither in or any of its compounds are used in the unitart of our product except has the advection the structured has a mean data for the same and the interval of the regulations are used in the unitart of our product except has the advection of the transfer and we are used in the unitart of our product strept material was meeted in the unitart of the same advection of the transfer and the advection of the transfer and the same advection of the unitart of the unitart of the same advection of the transfer advection of the unitart of the same advection of the transfer advection of the unitart of the same advection of the transfer advection o 0.000.0 23.6 KSI 23.5 KSI MN 0.45 COIL OT **4IHS** 0/0 0/0 HEAD YIELD STRENGTH (OFFSET = .2%) TAIL YIELD STRENGTH (OFFSET = .2%) HEAD ELG IN 2 IN., AT FRACTURE 2.5 TAIL ELG IN 2 IN., AT FRACTURE 2.5 LENGTH CU 0.17 FORM HEAD ULTIMATE STRENGTH 24.2 KSI TAIL ULTIMATE STRENGTH 24.2 KSI 40.7500 DROP: 251641 PERMATREAT 1021B OVER PERMATREAT 1021B FE 0.40 RM212142 AL2041 Alumax Mill Products, Inc. (an Alcoa Inc. business) 1480 Manheim Pike Lancaster, Pa. 17601 H14 MITSUBISHI CHEMICAL FP AMERICA 0.50 PART NO TEMPER ЫS \* WIDTH PO NO 23320 CERTIFICATION COIL: A01 2516411 401 VOLVO PARKWAY .01900 INGOT LT7125 CHESAPEAKE, VA ALPOLIC PLANT 3105 LOT: 549165 ОF ORDER NO END ITEM NO Ò • GAUGE ALLOY Ū ∠ ∢ \* \* We J and spec note man OL Q J OS

Appendix 2: Aluminum Alloy 3105-H14 Specification Data



PTC Product Design Group, LLC | PO Box 520775 | Longwood, FL 32752-0775 321-690-1788 | FBPE Certification of Authorization No. 25935

# Rule 61G20-3.015(4)(d) F.A.C. | Report No. 2744-EER, Rev. 1 | Project No. 422-0903 | 6/13/23 | Page 6 of 6