

W. W. Schaefer Engineering & Consulting, P.A. (CA #6809)

7480 150th Court North
Palm Beach Gardens, FL 33418
Phone (561)744-3424

July 7, 2020

Re: Equivalency statement for AAMA 501 testing of the following Kawneer Company product:

- FG623 Window Wall System (LMI & SMI)

While the test reports state testing to AAMA 501-05, upon review of that testing, we find that the testing performed on the applicable products referenced here-in also meets the requirements of the current standard AAMA 501-15. Therefore, equivalency of standards has been met & reference to AAMA 501-15 is acceptable.

Sincerely,

JUL 0 7 2020

Warren W. Schaefer, P.E.
Florida P.E. #44135

