

March 6, 2026

Equivalence of Product Standards

Product Description:

Grand Vista 1100 Sliding Glass Doors, Impact or Non-Impact, as indicated in Florida Product Approval FL11271

Manufacturer:

ViWinTech, 2400 Irvin Cobb Drive, Paducah, KY 42003

Equivalent Standards:

ANSI/AAMA/NWWDA 101/I.S.2-97 w/ ASTM F842 and AAMA/WDMA/CSA
101/I.S.2/A440-08
ASTM E 1886-02 and ASTM E 1886-13a
ASTM E 1996-02 and ASTM E 1996-14a

Assessment:

The products indicated in the above-listed Florida Product Approval (FPA) have been tested and certified in various configurations in accordance with ANSI/AAMA/NWWDA 101/I.S.2-97 w/ ASTM F842, ASTM E 1886-02, and ASTM E 1996-02. I have determined that for the indicated products as defined in the Certifications, Installation Instructions, and Evaluation Reports in the above-listed FPA, the pertinent air/water/structural/FER/impact/cyclic testing performed as indicated above is equivalent to the testing performed for AAMA/WDMA/CSA 101/I.S.2/A440-08, ASTM E 1886-13a, and ASTM E 1996-14a, respectively, as referenced in the 8th Edition (2023) Florida Building Code.



Lucas Turner
2026.03.11
09:48:58
-05'00'

3/6/2026
Lucas A. Turner, P.E.
FL P.E. 58201