Amoruso Consulting Engineering, LLC
FBPE Registration No. 38327
Robert J. Amoruso, FL P.E. No. 49752

226 N. Nova Rd., #142
Ormond Beach, FL 32174
rjaengpe@gmail.com

Equivalency Evaluation Report	
Project No.: ACE-2025-131	**Report No.:** ACE-EER-1181, Rev. 0

Product Manufacturer: Regency Plus Incorporated, 2000 Locust Gap Highway, Mount Carmel, PA 17851

Product Name, Model and/or Description:

- 2000 Vinyl Tilt Double Hung Window
- 5305 Impact Vinyl Tilt Double Hung Window

Florida Product Approval No.: FL11413

Code: Current Edition of the Florida Building Code including the 9th Edition (2026) Florida Building Code

Compliance Method: Product Approval Rule 61G20-3.015(4)(d) – Equivalency of Standards

Product Name, Model and/or Designation; Test Report No. and Installation Drawing No.:

- 2000 Vinyl Tilt Double Hung Window
  - Test reports and associated laboratory drawings by National Certified Testing Laboratories, Orlando, FL.
    - NCTL-210-2661-1, dated 12/05/01 to AAMA/NWWDA 101/I.S.2-97
  - Drawing No. RPLS0049, Rev. C, dated 7/28/26, signed and sealed by Robert J. Amoruso, P.E., FL License Number 49752
- 5305 Impact Vinyl Tilt Double Hung Window
  - Test reports and associated laboratory drawings by National Certified Testing Laboratories, York, PA signed and sealed by Robert H. Zeiders, P.E.
    - NCTL-110-9867-1, dated 11/8/05 to TAS 201-94, TAS 202-94 and TAS 203-94
  - Drawing No. RPLS0050, Rev. V, dated 7/28/26, signed and sealed by Robert J. Amoruso, P.E., FL License Number 49752

Performance Testing: Performance Standards used in testing:

- AAMA/NWWDA 101/I.S.2-97
- TAS 201-94, TAS 202-94 and TAS 203-94

Component Approvals: The following MD NOA component approvals applicable to this product approval have been reviewed and found to meet the requirements of the 9th Edition (2026) Florida Building Code.

- Extruded rigid PVC by Vision Extrusions Group Limited per current Miami-Dade NOA to the current edition of the Florida Building Code. See Miami-Dade NOA listing here.
- Eastman Chemical Company (MA) Saflex PVB interlayer code conformance per current Miami-Dade NOA to the current edition of the Florida Building Code. See Miami-Dade NOA listing here.

Amoruso Consulting Engineering, LLC
FBPE Registration No. 38327
Robert J. Amoruso, FL P.E. No. 49752

226 N. Nova Rd., #142
Ormond Beach, FL 32174
rjaengpe@gmail.com

Equivalency Evaluation per Product Approval Rule 61G20-3.015(4)(d):

Performance Testing

The following table shows the performance standards used in testing and those in the current edition of the FBC.

Standard Used in Testing		Current Edition of the Florida Building Code including the 9th Edition (2026) Florida Building Code		Comments
Description	Revision Level	Building Volume (FBC)	Residential Volume (FRC)	
TAS 201	94	94	94	See Evaluation Below
TAS 202	94	94	94	
TAS 203	94	94	94	
AAMA/NWWDA 101/I.S.2	97	11	11	

TAS 201, TAS 202 & TAS 203: It has been concluded that no material or substantive revisions or changes to these referenced standards have occurred (where applicable) that affect the results of design, testing or engineering of the approved product(s).

AAMA Standard Listed Above: It has been concluded that no material or substantive revisions or changes to these referenced standards have occurred (where applicable) that affect the design, testing or engineering of the approved product(s).

Certificate of Independence per Product Approval Rule 61G20-3.009

Robert J. Amoruso, P.E., does not have, nor will he acquire, any financial interest in the company manufacturing or distributing product(s) covered by this Product Evaluation Report.

Robert J. Amoruso, P.E., does not have, nor will he acquire any financial interest in any other entity involved in the approval process or testing of the product(s) covered by this Product Evaluation Report.



Digitally signed by Robert J Amoruso
Date: 2026.08.24 15:03:47 -04'00'

Evaluated by:
Robert J. Amoruso, P.E.
FL PE License No. 49752