

Equivalency Evaluation Report	
Project No.: ACE-2025-131	Report No.: ACE-EER-1182, Rev. 0

Product Manufacturer: Regency Plus Incorporated, 2000 Locust Gap Highway, Mount Carmel, PA 17851

Product Name, Model and/or Description:

- Series Tech 5000 Impact Mullion
- Series Tech 5000 T Impact Mullion

Florida Product Approval No.: FL11479

Code: Current Edition of the Florida Building Code including the 9th Edition (2026) Florida Building Code

Compliance Method: Product Approval Rule 61G20-3.015(4)(d) – Equivalency of Standards

Product Name, Model and/or Designation; Test Report No. and Installation Drawing No.:

- Series Tech 5000 Impact Mullion
 - Test reports and associated laboratory drawings by National Certified Testing Laboratories, York, PA signed and sealed by Robert H. Zeiders, P.E.
 - NCTL-110-10616-1, AAMA/WDMA/CSA 101/I.S.2/A440-05
 - NCTL-110-10616-2, TAS 201-94, TAS 202-94 AND TAS 203-94
 - NCTL-110-10616-3, ASTM E1886-05 & ASTM E1996-04
 - Drawing No. RPLS0057, Rev. B, dated 7/28/26, signed and sealed by Robert J. Amoruso, P.E., FL License Number 49752
- Series Tech 5000 Impact T Mullion
 - Test reports and associated laboratory drawings by National Certified Testing Laboratories, York, PA signed and sealed by Robert H. Zeiders, P.E.
 - NCTL-110-10617-1, ASTM E1886-05 & ASTM E1996-04
 - NCTL-110-10617-2, AAMA 450-00
 - NCTL-110-10617-3, TAS 201-94, TAS 202-94 AND TAS 203-94
 - Drawing No. RPLS0058, Rev. B, dated 7/28/26, signed and sealed by Robert J. Amoruso, P.E., FL License Number 49752

Performance Testing: Performance Standards used in testing:

- Performance Standards used in testing for NON-HVHZ locations:
 - AAMA 450-00
 - AAMA/WDMA/CSA 101/I.S.2/A440-05
 - ASTM E1886-05
 - ASTM E1996-04
- Performance Standards used in testing for HVHZ and Non-HVHZ locations:
 - TAS 201-1994
 - TAS 202-1994

- TAS 203-1994

Performance Testing Equivalency Evaluation per Product Approval Rule 61G20-3.015(4)(d):

The table below equates performance testing standard revision levels and compares them to the revision level in the Current Edition of the Florida Building Code – Test Protocols.

HVHZ Testing	
Standard Used in Testing	Standard as Listed in 9th Edition (2026) Florida Building Code HVHZ Test Protocols
TAS 201-1994	TAS 201-1994
TAS 202-1994	TAS 202-1994
TAS 203-1994	TAS 203-1994

Based upon my review of the test reports, test methods and results as well as the standards used in testing and those currently required in the Florida Building Code and HVHZ Testing Protocols, the following is concluded.

The testing requirements in the 9th Edition (2026) Florida Building Code – Testing Protocols TAS 201, TAS 202 and TAS 203 have been met.

The table below equates performance testing standard revision levels and compares them to the revision level in the Current Edition of the Florida Building Code and/or Florida Residential Code.

Non-HVHZ Testing	
Standard Used in Testing	Standard as Listed in 9th Edition (2026) Florida Building Code – Test Protocols
AAMA 450-00	AAMA 450-10
AAMA/WDMA/CSA 101/I.S.2/A440-05	AAMA/WDMA/CSA 101/I.S.2/A440-11
ASTM E1886-05	ASTM E1886-13a
ASTM E1996-04	ASTM E1996-17

Based upon my review of the test reports, test methods and results as well as the standards used in testing and those currently required in the 9th Edition (2026) Florida Building Code, the following is concluded.


Wind Zone 4 impact resistance testing: ASTM E1996-14 moved Wind Zone 4 criteria to the non-mandatory appendix. As indicated in Appendix X4.1, ASTM E1996-17 the Wind Zone 4 requirement, though non-mandatory, is still present and may be specified when needed to meet specific building codes requirements. Those requirements are detailed in Chapter 16 of the Florida Building Code. Based on a review of the test reports, those parameters are met.

The testing requirements in the 9th Edition (2026) Florida Building Code have been met for the test standards listed above.

**Certificate of Independence per Product
Approval Rule 61G20-3.009**

Robert J. Amoruso, P.E., does not have, nor will he acquire, any financial interest in the company manufacturing or distributing product(s) covered by this Product Evaluation Report.

Robert J. Amoruso, P.E., does not have, nor will he acquire any financial interest in any other entity involved in the approval process or testing of the product(s) covered by this Product Evaluation Report.



Digitally signed
by Robert J
Amoruso
Date:
2026.08.25
10:06:58 -04'00'

Evaluated by:
Robert J. Amoruso, P.E.
FL PE License No. 49752