

Equivalency Evaluation to 5th Edition (2014) FBC

Date: June 24, 2015

PTC Report No.: 1971-EER

Report Revision No.: 3

PTC Project No.: 415-0316

Product Mfg.: Solatube International, Inc.

2210 Oak Ridge Way Vista, CA 92081

Product Name: Impact 10" 160 (DS) and 14" 290 (DS) Tubular Daylight Device - HVHZ

Product Category: Sky Lights

Product Sub-Category: | Skylight

Compliance Method: | Product Approval Rule 61G20-3.015(4)(d) – Equivalency of Standards

Prepared By: Robert J. Amoruso, P.E.

Florida P.E. License Number 49752 PTC Product Design Group, LLC

FBPE Certification of Authorization No. 25935

CERTIFICATE OF INDEPENDENCE

PTC Product Design Group, LLC and Robert J. Amoruso, P.E. do not have, nor will acquire, any financial interest in the company manufacturing or distributing product(s) covered by this Product Evaluation Report. PTC Product Design Group, LLC and Robert J. Amoruso, P.E. do not have, nor will acquire any financial interest in any other entity involved in the approval process or testing of the product(s) covered by this Product Evaluation Report.



Digitally signed by Robert J. Amoruso DN: cn=Robert J. Amoruso, o, ou=PTC Product Design Group, email=robert@ptccorp.com, c=US Date: 2015.06.30 18:43:36

-04'00'

Evaluated by: Robert J. Amoruso, P.E. Florida P.E. License Number 49752

PTC Product Design Group, LLC PO Box 520775

Longwood, FL 32752-0775

Phone: 321-690-1788 Fax: 321-690-1789 FBPE Certification of Authorization No. 25935

Project No. 415-0316 Report No. 1971-EER, Rev. 3

Page | 1

Project Scope

Evaluate equivalency of testing standards used for the performance testing of Solatube Impact 160 DS (10") and 290 DS (14") Tubular Daylight Device for conformance to the 5th Edition (2014) Florida Building Code – Building and Residential Volumes including the High Velocity Hurricane Zone (HVHZ).

Description of Product – Installation Requirements

See Reference 1 for a description of the product, its installation and other pertinent data related to its approved use.

Performance and Testing Standards

Reference 2.a conducted air, water and structural testing including impact and cyclic loading to the following standard(s).

- 1) TAS 201-94 Impact Test Procedures
- 2) TAS 202-94 Criteria for Testing Impact & Nonimpact Resistant Building Envelope Components Using Uniform Static Air Pressure
- 3) TAS 203-94 Criteria for Testing Products Subject to Cyclic Wind Pressure Loading

Reference 2.b, 2.c, 2.d, 2.e, 2.g and 2.h conducted plastics testing to the following standard(s).

- 1) ASTM G155-05a, Standard Practice for Operating Xenon Arc Light Apparatus for Exposure of Non Metallic Materials
- 2) ASTM G155-00ae1, Standard Practice for Operating Xenon Arc Light Apparatus for Exposure of Non Metallic Materials
- 3) ASTM D638-03, Standard Test Method for Tensile Properties of Plastics
- 4) ASTM D635-06, Standard Test Method for Rate of Burning and/or Extent and Time of Burning of Plastics in a Horizontal Position.
- 5) ASTM D635-74, Standard Test Method for Rate of Burning and/or Extent and Time of Burning of Plastics in a Horizontal Position.
- 6) ASTM D1929-96 (2001)e1, Standard Test Method for Determining Ignition Temperature of Plastics.
- 7) ASTM D1929-96, Standard Test Method for Determining Ignition Temperature of Plastics.
- 8) ASTM D1929-68(1975), Standard Test Method for Determining Ignition Temperature of Plastics.
- 9) ASTM E84-06, Standard Test Method for Surface Burning Characteristics of Building Materials
- 10) ASTM E84-09a, Standard Test Method for Surface Burning Characteristics of Building Materials
- 11) ASTM D 2843-99, Standard Test Method for Density of Smoke from the Burning or Decomposition of Plastics.
- 12) ASTM D 2843-93, Standard Test Method for Density of Smoke from the Burning or Decomposition of Plastics.

PTC Product Design Group, LLC PO Box 520775 Longwood, FL 32752-0775

Phone: 321-690-1788 Fax: 321-690-1789 FBPE Certification of Authorization No. 25935

Project No. 415-0316 Report No. 1971-EER, Rev. 3

Page | 2

Reference 2.f recorded ICC/FBC conforming plastics testing in the following evaluation reports.

- 1) ICC-ES Report No. ER-1084
- 2) ICC-ES Report No. ESR-1635

References and Supporting Documents

- 1) Drawings
 - a. SOLA0004, Rev. D, dated 5/11/15, signed and sealed by Robert J. Amoruso, PE, Solatube Impact 160 DS (10") and 290 DS (14") Tubular Daylight Device Installation Anchorage Details.
- 2) Testing (note that References 2.b thru 2.h have the BOM Item description and (Item No.) shown)
 - a. Architectural Testing Inc. Test Report No. 85320.01-301-18, dated 9/08/08, Solatube Impact 160 DS (10") and 290 DS (14") Tubular Daylight Device testing to TAS 201, TAS 202 and TAS 203, signed and sealed by Joshua M. Royce, P.E.
 - b. OUTER DOME (1), DOME RING (3), TOP TUBE CLIP (7) AND INNER DOME (26) testing for High Impact Acrylic PMMA (Poly(methyl methacrylate))
 - i. Intertek Test Report No. 3143957-004, dated 9/24/08, testing to ASTM G155-05a and D638-08 in accordance with ASTM D2565-99.
 - ii. SGS Test Report No. 177:013002-01-R1, dated 6/10/08, testing to ASTM D635-06.
 - iii. SGS Test Report No. 177:013002-02-R1, dated 6/10/08, testing to ASTM D1929-96.
 - iv. SWRI Test Report No. 01.12693.01.139, dated 4/5/07, testing to ASTM E84-06.
 - c. OUTER DOME (1), DOME RING (3), TOP TUBE CLIP (7) AND INNER DOME (26) testing for High Impact Acrylic PMMA (Poly(methyl methacrylate))
 - i. Architectural Testing Inc. Test Report No. 58735.01-106-18, dated 1/4/07, testing to ASTM G155-00ae1 and D638-03.
 - ii. SGS Test Report No. 177:002666-03, dated 1/2/07, testing to ASTM D635-06.
 - iii. SGS Test Report No. 177:002666-01, dated 1/13/07, testing to ASTM D1929-96(2001)e1.
 - iv. SGS Test Report No. 177:002666-02, dated 1/2/07, testing to ASTM D2843-99.
 - d. EFFECT LENS (17), PET-GAG (PET Polyethylene Terephthalate, High Frequency Welding Grade GAG) testing
 - i. SGS Test Report No. 2138368-1, dated 8/27/10, testing to ASTM D635-06.
 - ii. SGS Test Report No. 2138368-3, dated 2/2/10, testing to ASTM D1929-96(2001)e1.
 - iii. SGS Test Report No. 2138368-2, dated 8/31/10, testing to ASTM E84-09a.
 - e. CEILING RING (16) AND DRESS RING (19) testing for Medium Impact Acrylic PMMA (Poly(methyl methacrylate))
 - i. SGS Test Report No. 177:013002-01-R1, dated 6/10/08, testing to ASTM D635-06.
 - ii. SGS Test Report No. 177:013002-02-R1, dated 6/10/08, testing to ASTM D1929-96.

PTC Product Design Group, LLC PO Box 520775 Longwood, FL 32752-0775

Phone: 321-690-1788 Fax: 321-690-1789 FBPE Certification of Authorization No. 25935

Project No. 415-0316 Report No. 1971-EER, Rev. 3

Page | 3

- iii. SWRI Test Report No. 01.12693.01.139, dated 4/5/07, testing to ASTM E84-06.
- iv. Intertek Test Report No. 3143957-004, dated 9/24/08, testing to ASTM G155-05a and D638-08 in accordance with ASTM D2565-99.
- f. CEILING RING (16) AND DRESS RING (19) testing for Medium Impact Acrylic PMMA (Poly(methyl methacrylate))
 - ICC-ES Report No. ER-1084 demonstrates compliance to I-Codes for use in skylight applications. Report No. ER-1084 and 5th Edition (2014) FBC requirements same based on review of documented results.
 - ICC-ES Report No. ESR-1635 demonstrates compliance to I-Codes for use in skylight applications. Report No. ESR-1635 and 5th Edition (2014) FBC requirements same based on review of documented results.
- g. DIFFUSER PANEL (18) testing for Medium Impact Acrylic PMMA (Poly(methyl methacrylate))
 - i. SGS Test Report No. 177:013002-03-R1, dated 6/10/08, testing to ASTM D635-06.
 - ii. SGS Test Report No. 177:013002-04-R1, dated 6/10/08, testing to ASTM D1929-96.
 - iii. SWRI Test Report No. 01.13536.01.060, dated 1/30/08, testing to ASTM E84-06.
- h. DIFFUSER PANEL (18) testing for Polycarbonate
 - i. SGS Test Report No. 153367-2, dated 4/2/01, testing to ASTM D635-74.
 - ii. SGS Test Report No. 153367-1, dated 4/2/01, testing to ASTM D1929-68(1975).
 - iii. SGS Test Report No. 153367-3, dated 4/2/01, testing to ASTM D2843-93.
- 3) Reports
 - a. PTC Report No. 1971, Rev. 3, Solatube Impact 160 DS (10") and 290 DS (14") Tubular Daylight Device Evaluation Report, Dated 6/24/15, signed and sealed by Robert J. Amoruso, P.E.
- 4) 5th Edition (2014) Florida Building Code & 5th Edition (2014) Florida Residential Code
 - a. Testing and Labeling Requirements
 - i. Section 1626 Impact Tests (HVHZ WBDR)
 - ii. Section 1626.2 Large Missile Impact Tests
 - iii. Section 1710.6 Skylights and Sloped Glazing
 - iv. Section 2405 Sloped Glazing and Skylights
 - v. Section 2410.4 Product Approval Required
 - vi. Section 2610 Light-Transmitting Plastic Skylight Glazing
 - vii. Section 2610.2 Light-Transmitting Plastic Skylight Glazing, Mounting
 - viii. Section R308.6 Skylights and Sloped Glazing
 - b. Glazing Requirements
 - i. Section 2405.1 Sloped Glazing and Skylights Scope
 - ii. Section 2405.2 Allowable Glazing Materials and Limitations
 - c. Plastics Requirements
 - i. Section 2606.4 Specifications, Light-transmitting plastics
 - ii. Section 2614.2 Definitions, Approved Plastics

Equivalency Evaluation – Plastics Testing

Test Standard used	5th Edition (2014) FBC/FRC Standard Revision Level	Comments
ASTM D635-06	ASTM D635-06	Review of the revision year
ASTM D635-74		required by the code and that
		used in testing indicate no
		significant changes that would
		affect test results.
ASTM D638-03	ASTM D638-03	Same revision level used in test as
		required in code.
ASTM D1929-96 (2001)e1	ASTM D1929-96 (2001)e1	Same revision level used in test as
ASTM D1929-96		required in code.
ASTM D1929-68(1975)		OR –
		Review of the revision year
		required by the code and that
		used in testing indicate no
		significant changes that would
		affect test results.
ASTM D2843-99	ASTM D 2843- 99(2004)e01	Same revision level used in test as
ASTM D2843-93		required in code.
		OR
		Review of the revision year
		required by the code and that
		used in testing indicate no
		significant changes that would
ACTN 4 FO 4 O C	ACTNA FOA OO	affect test results.
ASTM E84-06	ASTM E84-09	Review of the revision year
ASTM E84-09a		required by the code and that
		used in testing indicate no
		significant changes that would
ACTNA C1FF OF a	ACTNA CAFE OF	affect test results.
ASTM G155-05a	ASTM G155-05a	Same revision level used in test as
ASTM G155-00ae1		required in code. OR –
		Review of the revision year
		required by the code and that
		used in testing indicate no
		significant changes that would
		affect test results.
		affect test results.

PTC Product Design Group, LLC PO Box 520775 Longwood, FL 32752-0775

Phone: 321-690-1788 Fax: 321-690-1789 FBPE Certification of Authorization No. 25935

Project No. 415-0316 Report No. 1971-EER, Rev. 3

Equivalency Evaluation – Air, Water and Structural Testing including Impact and Cyclic Loading

Reference 2.a tested uniform static air pressure in accordance with TAS-202-94, *Criteria for Testing Impact & Nonimpact Resistant Building Envelope Components Using Uniform Static Air Pressure*

- Testing to the above procedure documented in Reference 2.a is based on conformance to the 2007 FBC – Test Protocols with 2009 Supplements.
- **CONCLUSION**: Testing and documented results in Reference 2.a are compliant with the 5th Edition (2014) FBC Building Volume, Residential Volume and Test Protocols. It has been concluded that no revisions or changes to the referenced standards have occurred that affect the results of design, testing or engineering of the approved product(s).

Reference 2.a tested impact performance in accordance with TAS-201-94, Impact Test Procedures

- Testing to the above procedure documented in Reference 2.a is based on conformance to the 2007 FBC – Test Protocols with 2009 Supplements.
- **CONCLUSION**: Testing and documented results in Reference 2.a are compliant with the 5th Edition (2014) FBC Building Volume, Residential Volume and Test Protocols. It has been concluded that no revisions or changes to the referenced standards have occurred that affect the results of design, testing or engineering of the approved product(s).

Reference 2.a tested post-impact cyclic wind pressure loading performance in accordance with TAS-203-94, *Criteria for Testing Products Subject to Cyclic Wind Pressure Loading*.

- Testing to the above procedure documented in Reference 2.a is based on conformance to the 2007 FBC – Test Protocols with 2009 Supplements.
- CONCLUSION: Testing and documented results in Reference 2.a are compliant with the 5th Edition
 (2014) FBC Building Volume, Residential Volume and Test Protocols. It has been concluded that no
 revisions or changes to the referenced standards have occurred that affect the results of design,
 testing or engineering of the approved product(s).