

August 12, 2019

Equivalence of Product Standards

Product Description:

Reynobond® Composite FR and NC Panels

Manufacturer:

Arconic Architectural Products, Eastman, Georgia

Equivalent Standards:

ASTM D1929-1996 to ASTM D1929-2012
ASTM E84-2005 to ASTM E84-2013A
ASTM E119-2000A to ASTM E119-2012A

Assessment:

The product indicated above has been tested in accordance with ASTM standards D1929-96, E84-05, and E119-00A. I have determined that for the indicated products as defined in the Installation Instructions and Evaluation Reports in FL11794, that the tested standards listed above are equivalent to ASTM standards D1929-12, E84-13A, and E119-12A, respectively, as referenced in the 6th Edition (2017) Florida Building Code.

LT

8/12/2019
Lucas A. Turner, P.E.
FL P.E. 58201

