

L. Roberto Lomas P.E.

208 7th Ave
Indialantic, FL 32903
434-688-0609
rllomas@lrlomaspe.com

FL 12156 AAMA EQ Rev B

October 15, 2026

Manufacturer: ProVia Door, Inc.
2150 State Route 39
Sugarcreek, OH 44681

Product Approval:

12156.1 PRESTIGE SLIDING PATIO DOOR
12156.2 REINFORCED VINYL SLIDING GLASS DOOR Non-Impact
12156.3 REINFORCED VINYL SLIDING GLASS DOOR Impact
12156.4 REINFORCED VINYL SLIDING GLASS DOOR Impact


To whom it may concern

This is to verify that the products mentioned above were tested according to AAMA/WDMA/CSA 101/I.S.2/A440-05 and -08. I have reviewed the standard used for testing against the currently accepted standard AAMA/WDMA/CSA 101/I.S.2/A440-17. Based on my reviewing of these standards I found that the testing requirements in AAMA/WDMA/CSA 101/I.S.2/A440-05 and -08 are equivalent to the currently accepted standards.

Therefore, these products meet the testing requirements for AAMA/WDMA/CSA 101/I.S.2/A440-17.

Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which the reports are being issued.

Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).



Luis R. Lomas
FL No.: 62514
10/15/2026