

*L. Roberto Lomas P.E.*

1432 Woodford Rd  
Lewisville, NC 27023  
434-688-0609  
rllomas@lrlomaspe.com

*FL 12156 ASTM EQ*

October 6, 2020

**Manufacturer:** ProVia Door, Inc.  
2150 State Route 39  
Sugar creek, OH 44681


**Product Approval:**  
12156.4 REINFORCED VINYL SLIDING GLASS DOOR

**To whom it may concern**

This is to verify that the products mentioned above were tested according to ASTM E1886-05 and ASTM E1996-05. I have reviewed the standards used for testing against the currently accepted standards ASTM E1886-12 and ASTM E1996-12. Based on my reviewing of these standards I found that the testing requirements in ASTM E1886-05, and ASTM E1996-05 are equivalent to the currently accepted standards. Therefore, the products listed above meet the testing requirements for ASTM E1886-12 and ASTM E1996-12.

Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which the reports are being issued.

Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).



Luis R. Lomas  
FL No.: 62514  
10/15/2020