

W. W. Schaefer Engineering & Consulting, P.A. (CA #6809)

7480 150th Court North
Palm Beach Gardens, FL 33418
Phone (561)744-3424

July 9, 2020

Re: Equivalency statement for AAMA/WDMA/CSA/101/I.S.2/A440, ASTM E1886 & ASTM E1996 testing of the following Loewen Windows product:

- Aluminum Clad Wood Stormforce Impact casement window under FL13104

While the test reports state testing to AAMA/WDMA/CSA/101/I.S.2/A440-08, ASTM E1986-05 & ASTM E1996-09, upon review of that testing, we find that the testing performed on the applicable products referenced here-in also meets the requirements of the current standards AAMA/WDMA/CSA/101/I.S.2/A440-17 ASTM E1986-13a & ASTM E1996-17. Therefore, equivalency of standards has been met & reference to AAMA/WDMA/CSA/101/I.S.2/A440-17, ASTM E1986-13 & ASTM E1996-17 is acceptable.

Sincerely,

JUL 09 2020

Warren W. Schaefer, P.E.
Florida P.E. #44135

