

STRUCTURAL SOLUTIONS, P.A.*

Structural Engineering ■ Investigations ■ Consulting

October 3, 2017


Garage Doors Test Procedures
DASMA 108-2005 vs. 108-2012
DASMA 115-2005 vs. 115-2012
Project No. 17-001

To Whom It May Concern:

DASMA 108 describes the procedures to be used to test garage doors for Structural Performance Under Uniform Static Air Pressure Difference. DASMA 115 describes the procedures to be used to test garage doors for Structural Performance Under Missile Impact and Cyclic Wind Pressure.

I have reviewed the documents listed above, and I have compared the differences between the 2005 versions and the 2012 versions. With regard to the testing that Entrematic garage doors undergo, the procedures listed in the documents are essentially the same. Therefore, Entrematic doors that were tested in conformance with the earlier documents (DASMA 108-2005 and DASMA 115-2005) are considered to also comply with the later documents (DASMA 108-2012 and DASMA 115-2012).

Sincerely,



STRUCTURAL SOLUTIONS, P.A.*
Thomas L. Shelmerdine, PE
Florida PE #48579
President