August 3, 2026

Product Approval Administrator
DBPR Codes and Standards
2601 Blair Stone Road
Tallahassee, FL 32399

Regarding: ABC Supply Outdoor Solutions
FL # 13757.1 - 6.8 Accordion Shutter - EX #26-99097
FL # 13757.2 - 6.8 Streamline Shutter - EX #26-99098
FL # 13757.3 - E.A. Essential Facilities Accordion - EX #26-99099

To Whom It May Concern:

This office has reviewed test report(s) showing structural performance of the above-noted product(s). These test report(s) pertain to testing performed in accordance with the referenced standard(s) in the table shown below. The noted standard(s) are not adopted in the Florida Building Code Ninth Edition (2026); however, for the purpose of determining the performance of the product, the standard(s) are equivalent to the corresponding standard(s), which are adopted in the above-referenced building code.

Test Standard Title	Tests Performed According to:	Current Equivalent Standard in FBC 2026:
Test Method for Performance of Exterior Windows, Curtain Walls, Doors and Storm Impact Protective Systems Impacted by Missiles and Exposed to Cyclic Pressure Differentials	ASTM E1886-02 & 05 & 06	ASTM E1886 13a or 19
Specification for Performance of Exterior Windows, Curtain Walls, Doors and Impact Protective Systems Impacted by Windborne Debris in Hurricanes	ASTM E1996-02, 05, 09, & 12	ASTM E1996-17, 20 or 23
Uniform Static Structural Performance	ASTM E330-02	E330/E330M—14 or 14(2021)
Impact test procedures	TAS 201-94	TAS 201-94

Criteria for testing impact & nonimpact resistant building envelope components using uniform static air pressure	TAS 202-94	TAS 202-94
Criteria for testing products subject to cyclic wind pressure loading	TAS 203-94	TAS 203-94

Respectfully,



Digitally signed by Colby Bennardo
Date: 2026.08.12 10:22:32 -04'00'

Colby Bennardo, P.E.
ENGINEERING *EXPRESS*®
PE# 95197 | Cert. Auth. 9885

*PRINTED COPIES OF THIS DOCUMENT ARE NOT CONSIDERED SIGNED & SEALED. SIGNATURE MUST BE VERIFIED ON ANY ELECTRONIC COPIES.
***FOR FLORIDA STATEWIDE PRODUCT APPROVALS (FSAs) REGISTERED & APPROVED WITH THE STATE OF FLORIDA:** ORIGINAL, SEALED COPIES OF APPROVED FLORIDA PRODUCT APPROVALS ARE NOT REQUIRED FOR PERMIT.
SEE **ECALC.IO/SEAL** TO LEARN MORE.