

Equivalency Evaluation Report

Report No. ACE-EER-1255, Rev. 0 | Project No. ACE-2026-153 | 9/7/26 | Page 1 of 2

Manufacturer

Sunoptics, Inc
20215 Rifle Range Road
Tallassee, AL 36078

Product Series, Model and/or Description

Sunoptics Model 900MD Signature Curb Mounted Skylight

Code: Current Edition of the Florida Building Code including the 9th Edition (2026) Florida Building Code

Compliance Methods: Product Approval Rule 61G20-3.015(4)(d) – Equivalency of Standards

Performance Testing Standards: All performance standards listed below were used in testing.

- TAS201-94, Impact Test Procedures.
- TAS202-94, Criteria for Testing Impact & Non-Impact Resistant Building Envelope Components Using Uniform Static Air Pressure.
- TAS203-94, Criteria for Testing Products Subjected to Cyclic Wind Pressure Loading.

Product Testing:

- Test Report No. R9624.01-301-18-R1, dated 12/16/24 4 By Intertek Testing and Associated Laboratory Stamped Drawings, Signed and Sealed by Tyler Westerling, FL PE No. 72012.
- Test Report No. R9625.01-301-18-R0, dated 11/13/24 By Intertek Testing and Associated Laboratory Stamped Drawings, Signed and Sealed by Tyler Westerling, FL PE No. 72012.
 - Margin of Safety = 3 applied to positive load and 2 to negative load to Structural Design Pressure per FBC and MD FAQ (<http://www.miamidade.gov/building/products/skylights.asp>).

Material Certifications:

- Glazing
 - EXTERIOR 0.230" thick Palram Americas Clear polycarbonate panels per latest MD Notice of Acceptance (NOA) found [here](#).
 - INTERIOR 0.125" thick Palram Americas White polycarbonate panels per latest MD Notice of Acceptance (NOA) found [here](#).

Amoruso Consulting Engineering, LLC
FBPE Registration No. 38327
Robert J. Amoruso, FL P.E. No. 49752

226 N. Nova Rd., #142
Ormond Beach, FL 32174
rjaengpe@gmail.com

Equivalency Evaluation Report

Report No. ACE-EER-1255, Rev. 0 | Project No. ACE-2026-153 | 9/7/26 | Page 2 of 2

Performance Testing Equivalency Evaluation per Product Approval Rule 61G20-3.015(4)(d):

The table below equates performance testing standard revision levels and compares them to the revision level in the 2026 FBC – Test Protocols.

HVHZ Testing	
Standard Used in Testing	Standard as Listed in 9 th Edition (2026) FBC – Test Protocols
TAS 201-1994	TAS 201-1994
TAS 202-1994	TAS 202-1994
TAS 203-1994	TAS 203-1994

Based upon my review of the test reports, test methods and results as well as the standards used in testing and those currently required in the Florida Building, Residential Code and HVHZ Testing Protocols, the following is concluded.

- The testing requirements in the 9th Edition (2026) Florida Building Code – Testing Protocols TAS 201, TAS 202 and TAS 203 have been met.

Certificate of Independence per Product Approval Rule 61G20-3.009

Robert J. Amoruso, P.E., does not have, nor will acquire, any financial interest in the company manufacturing or distributing product(s) covered by this Product Evaluation Report.

Robert J. Amoruso, P.E., does not have, nor will acquire any financial interest in any other entity involved in the approval process or testing of the product(s) covered by this Product Evaluation Report.



Digitally
signed by
Robert J
Amoruso

Date:
2026.09.10
04:36:02
-04'00'

Evaluated by:
Robert J. Amoruso, P.E.
FL P.E. License No. 49752

Amoruso Consulting Engineering, LLC
FBPE Registration No. 38327
Robert J. Amoruso, FL P.E. No. 49752

226 N. Nova Rd., #142
Ormond Beach, FL 32174
rjaengpe@gmail.com