



PRI Construction Materials Technologies LLC

6412 Badger Drive

Tampa, FL 33610

813.621.5777

<https://www.pri-group.com/>

March 3, 2021

Michael Sullivan,
Volatile Free
19500 Janacek Court
Brookfield, WI 53045

Dear Michael,

Per your request, and as it relates to PRI Report Number VFI-048-02-01, an evaluation of ASTM D 6083: Standard Specification for Liquid Applied Acrylic Coating Used in Roofing was conducted to compare the reference year of each standard as it is adopted in the 2020 Florida Building Code – Building, 7th Edition to how it is adopted in the 2014 Florida Building Code, 5th Edition. A “statement ... that product has not been affected by changes made to the Florida Building Code since last approval” has been requested by the manufacturer. Please review and utilize the table below to suffice this request.

Standard	FBC 2014	FBC 2020	Equivalency	Technical Remarks
	Reference	Reference		
ASTM D 6083	ASTM D 6083-05	ASTM D 6083-18, Type I Classification	Yes	ASTM D 6083-18 created two classifications. Type I classification requirements are identical to ASTM D 6083-05 requirements

Should you have any questions or need anything further, please don't hesitate to contact me. Thank you.

Regards,

Brent Barbeau

Manager