

October 27, 2017

Equivalence of Product Standards

Product Description:

Mulled window and door products as shown in FL14133-R7

Manufacturer:

Marvin Windows and Doors, PO Box 100, Warroad, MN

Equivalent Standards:

AAMA 450-06 and AAMA 450-10

Assessment:

The products indicated above have been tested and certified in accordance with AAMA 450-06 Option 1 (test-only option). The 6th Edition of the Florida Building Code requires AAMA 450-10 for this standard. The primary differences between the two versions are the added requirement in 450-10 to separately qualify the individual mulled products to one of the current AAMA 101/A440 standards in addition to the 450 testing, and also that in 450-10 the reference standard was changed to AAMA/WDMA/CSA 101/I.S.2/A440-08 throughout. All of the products in FL14133-R7 are separately certified to AAMA/WDMA/CSA 101/I.S.2/A440-08 therefore this requirement is explicitly met.

I have determined that for the design of the indicated products/mullions as defined in the Installation Instructions and Certification Agency Certificates listed in Florida Product Approval FL14133-R7, that AAMA 450-06 is equivalent to AAMA 450-10 as referenced in the 6th Edition (2017) Florida Building Code.

LT

10/27/2017
Lucas A. Turner, P.E.
FL P.E. 58201



Lucas
Turner
2017-10-27
15:10+20:00