

Equivalency Evaluation Report

Report No. ACE-EER-1248, Rev. 0 | Project No. ACE-2025-134 | 8/14/26 | Page 1 of 2

Product Manufacturer

Simpson Door Company
400 W. Simpson Ave
McCleary, WA 98557

Product Name, Model and/or Description

Series "Dowel", "Transom" & "Mortise and Tenon" Wood Fixed Panel

Code: Current Edition of the Florida Building Code including the 9th Edition (2026) Florida Building Code

Compliance Method: Product Approval Rule 61G20-3.015(4)(d) – Equivalency of Standards

Product Name, Model and/or Designation – Test Report No. – Installation Drawing No.: Products covered by this evaluation include the following.

- Drawings:
 - SIMP1061, Revision D, dated 8/14/26, signed and sealed by Robert J. Amoruso, Simpson Door Company Non-Impact Fixed Glazed Wood Sidelight – Installation Anchorage Details.
- Test Reports by Construction Consulting Laboratory, International
 - CCLI-10-115, dated October 6, 2010, Series "Dowel" and Series "Mortise and Tenon" Wood Entry Doors and Sidelights, tested to the following standards:
 - ASTM E330-02
 - ASTM E547-00
 - ASTM E283-04

Equivalency Evaluation per Product Approval Rule 61G20-3.015(4)(d):

Performance Testing

The following table shows the performance standards used in testing and those in the current edition of the FBC.

Standard Used in Testing		Current Edition of the Florida Building Code including the 9th Edition (2026) Florida Building Code		Comments
Description	Revision Level	Building Volume (FBC)	Residential Volume (FRC)	
ASTM E330	02	14	14	See Evaluation Below
ASTM E283	04	04(2012)	04 (2012)	
ASTM E547	00	n/a	n/a	

Amoruso Consulting Engineering, LLC
FBPE Registration No. 38327
Robert J. Amoruso, FL P.E. No. 49752

226 N. Nova Rd., #142
Ormond Beach, FL 32174
rjaengpe@gmail.com

Equivalency Evaluation Report

Report No. ACE-EER-1248, Rev. 0 | Project No. ACE-2025-134 | 8/14/26 | Page 2 of 2

PERFORMANCE TEST STANDARDS EQUIVALENCY EVALUATION: ASTM Standards Listed Above:

Based on review of performance standards used in testing and comparing them to the current revision levels in the 9th Edition (2026) Florida Building Code, it has been concluded:

- that no material or substantive revisions or changes to these referenced standards have occurred (where applicable) that affect the results of design, testing or engineering of the approved product(s), and
- that the performance standard revision levels listed above represented in the 9th Edition (2026) Florida Building Code are met.

Certificate of Independence per Product Approval Rule 61G20-3.009

Robert J. Amoruso, P.E., does not have, nor will acquire, any financial interest in the company manufacturing or distributing product(s) covered by this Product Evaluation Report.

Robert J. Amoruso, P.E., does not have, nor will acquire any financial interest in any other entity involved in the approval process or testing of the product(s) covered by this Product Evaluation Report.



Digitally
signed by
Robert J
Amoruso
Date:
2026.09.24
10:33:44 -04'00'

Evaluated by:
Robert J. Amoruso, P.E.
FL P.E. License No. 49752

Amoruso Consulting Engineering, LLC
FBPE Registration No. 38327
Robert J. Amoruso, FL P.E. No. 49752

226 N. Nova Rd., #142
Ormond Beach, FL 32174
rjaengpe@gmail.com