

W. W. Schaefer Engineering & Consulting, P.A. (CA #6809)

7480 150th Court North
Palm Beach Gardens, FL 33418
Phone (561)744-3424

October 31, 2011

Re: Equivalency statement for the PA-201, 202 & 203 testing of the following product manufactured by Signature Door, Inc.:

- Direct Glazed Impact Wood Fixed Window

Some of the testing for the above stated product was to the PA-201, 202 & 203 standards. Upon review of that testing, we find that the testing performed also meets the requirements of the FBC required TAS-201-94, 202-94 & 203-94 standards. Therefore, equivalency of standards is satisfied and the testing is acceptable.

Sincerely,

OCT 31 2011

Warren W. Schaefer, P.E.
Florida P.E. #44135

