

EQUIVALENCY EVALUATION REPORT	
Project No.: ACE-2026-102	Report No.: ACE-EER-1130, Rev. 1

Product Description: Model "HSFAW" Impact Self-Flashing Polycarbonate Skylight

Product Manufacturer: Natural Light Energy Systems, LLC dba Kennedy Skylights, 5294 Tower Way, Sanford, FL 32773

Code Compliance Statement: This report evaluates the product(s) listed above to the requirements of FAC Product Approval Rule 61G20-3.005. This product complies with the requirements of the 9th Edition (2026) Florida Building Code including the High Velocity Hurricane Zone (HVHZ) per the product testing standards listed below.

Compliance Method: Product Approval Rule 61G20-3.015(4)(d) – Equivalency of Standards

Documentation:

1. Installation Drawing No. KENN0009-FPA, Rev. 1, signed and sealed by Robert J. Amoruso, PE.
 - a. This drawing is in conformance with the 9th Edition (2026) Florida Building Code including the High Velocity Hurricane Zone (HVHZ)
2. Test Report No. 2822T0002, dated 6/30/2025 and associated laboratory drawing by PRI Construction Materials Technologies LLC, signed and sealed by Zachary R. Priest, PE. Performance standards used in testing are:
 - a. TAS 201-94 (per 8th Edition (2023) FBC).
 - b. TAS 202-94 (per 8th Edition (2023) FBC).
 - c. TAS 203-94 (per 8th Edition (2023) FBC).
3. Calculations in support of installation requirements for KENN0009-FPA, signed and sealed by Robert J. Amoruso, PE.
4. Polycarbonate Outer Dome and Inner Panel by Palram Americas per Current Miami-Dade Notice of Acceptance (NOA).

Equivalency Evaluation:

The following table shows the performance standards used in testing and those in the current edition of the FBC.

Standard Used in Testing		Current Edition of the Florida Building Code including the 8th Edition (2023) Florida Building Code		Comments
Description	Revision Level	Building Volume (FBC)	Residential Volume (FRC)	
TAS 201	94	94	94	See Evaluation Below
TAS 202	94	94	94	
TAS 203	94	94	94	

TAS 201, TAS 202 & TAS 203: It has been concluded that no material or substantive revisions or changes to these referenced standards have occurred (where applicable) that affect the results of design, testing or engineering of the approved product(s).

**Certificate of Independence per Product
Approval Rule 61G20-3.009**

Robert J. Amoruso, P.E., does not have, nor will he acquire, any financial interest in the company manufacturing or distributing product(s) covered by this Product Evaluation Report.

Robert J. Amoruso, P.E., does not have, nor will he acquire any financial interest in any other entity involved in the approval process or testing of the product(s) covered by this Product Evaluation Report.



Digitally signed by
Robert J Amoruso
Date: 2026.09.24
06:16:58 -04'00'

Evaluated by:
Robert J. Amoruso, P.E.
FL P.E. License No. 49752