

L. Roberto Lomas P.E.

1432 Woodford Rd
Lewisville, NC 27023
434-688-0609
rllomas@lrlomaspe.com

FL16067 AAMA EQ

December 28, 2020

To whom it may concern

Manufacturer: Slocomb Windows and Doors Inc
247 Old River Rd
Wilkes-Barre, PA 18702

Product Line:

16067.1	777 PROTECH SLIDER XOX 1/3-1/3-1/3
16067.2	777 PROTECH SLIDER XOX 1/4-1/2-1/4
16067.3	777 PROTECH SLIDER XX 69X44
16067.4	777 PROTECH SLIDER XX 72X56


Letter of Equivalency of Standards

This is to verify that the products listed above were tested according to AAMA/WDMA/CSA 101/I.S.2/A440-05. I have reviewed the standard used for testing against the currently accepted standard AAMA/WDMA/CSA 101/I.S.2/A440-11. Based on my reviewing of these standards I found that the testing requirements in AAMA/WDMA/CSA 101/I.S.2/A440-05 are equivalent to the currently accepted standards. Therefore, these products meet the testing requirements for AAMA/WDMA/CSA 101/I.S.2/A440-11

Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which the reports are being issued.

Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

Sincerely



Luis R. Lomas P.E.
Florida No. 62514