



1900 NE MIAMI CT. SUITE 2-15, MIAMI, FL 33132

July 9, 2025

To: Whom it may concern

From: Hermes F. Norero, P.E.
Florida Registered Professional Engineer #73778

On behalf of: Croft, LLC
1800 N Clark Ave
Magnolia, MS 39652

Subject: Test Standard Equivalency Statement

Product: Series 20 Vinyl Single Hung Window

NOPC Number: NI015616.02, NI015616.03

Dear Sir/Madam,

This letter is issued to confirm test standard year equivalency for the referenced product. Various test standards have been evaluated for differences in the test methodology, if any, between tested editions of the test standards listed below and those editions referenced in the current Florida Building Code. **Croft, LLC** has tested their products to the following test standard edition(s):


- 1) AAMA/WDMA/CSA 101/I.S.2/A440-08

Chapter 35 of the current Florida Building Code references the following editions of the above mentioned test standards:

- 1) AAMA/WDMA/CSA 101/I.S.2/A440-17

After review of the above mentioned referenced standards and editions, it has been found that the results and tests carried out meet the requirements for compliance. All referenced standards have been found to be equivalent.

Respectfully,



Digitally signed by Hermes F. Norero, P.E.
Reason: I am approving this document
Date: 2025.07.23 10:02:45 -04'00'

Hermes F. Norero, P.E.

Florida Registered Professional Engineer #73778

Certification of Independence:

Please note that I do not have nor will I acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I do not have nor will I acquire a financial interest in any other entity involved in the approval process of the listed product(s).