

October 5, 2017

Equivalence of Product Standards

Product Description:

E44000FS Storefront, 4' x 10' max. glass size with heavy duty mullions, 4' x 8' max. glass size with standard mullions, with design pressures as shown in FPA-E44000FS.

Manufacturer:

Tubelite Inc., 3056 Walker Ridge DR. NW Suite G, Walker, Michigan 49544

Equivalent Standards:

TAS-202 and AAMA 501-05

Assessment:

The product indicated above has been tested in accordance with TAS-202. TAS-202 meets or exceeds the test requirements of ASTM E 283-04, ASTM E 331-00, and ASTM E330-02, and these are the same mandatory test standards in AAMA 501-05.

I have determined that for the indicated product as defined in the Installation Instruction drawings FPA-E44000FS and Evaluation Report E44000FS, that TAS-202 is equivalent to AAMA 501-05 as referenced in the Florida Building Code.

ZZ

10/5/2017
Lucas A. Turner, P.E.
FL P.E. 58201

